



**AGL UPSTREAM INVESTMENTS PTY LTD  
ROSALIND PARK GAS PLANT  
Monthly Continuous Air Monitoring Report**

Reporting Period: May 2018

AGL Upstream Investments Pty Ltd

ABN 58 115 063 744

Locked Bag 1837, St Leonards NSW 2065

200 George Street, Sydney NSW 2000

Telephone: 02 9921 2999 Facsimile: 02 9921 2474

Complaints Line (24 hours): 1300 799 716



## Foreword

<b>PREMISES</b>	Rosalind Park Gas Plant Lot 35 Medhurst Road GILEAD NSW 2560
<b>LICENCE DETAILS</b>	<a href="#">Environment Protection Licence 12003</a>
<b>LICENCEE</b>	AGL Upstream Investments Pty Limited
<b>LICENCEE'S ADDRESS</b>	Locked Bag 1837, North Sydney, NSW 2060
<b>REPORTING PERIOD</b>	01 May 2018 to 31 May 2018
<b>DATE of MONITORING</b>	Continuous
<b>OBTAINED DATA DATE</b>	07 June 2018
<b>REPORT DATE</b>	18 June 2018
<b>REPORT PREPARED BY</b>	Aaron Clifton Environment Business Partner

### SUMMARY OF ACTIVITY

Rosalind Park Gas Plant, located approximately 60km south west of Sydney, is a natural gas processing and treatment plant, used to process coal seam natural gas from the Camden Gas Project.

Produced natural gas is cleaned, dehydrated, compressed and odourised before being measured and transported by pipeline about 500 metres into the nearby Moomba to Sydney Natural Gas Pipeline. The premises are covered by Environment Protection Licence 12003 which includes all gas wells, gas gathering, reticulation systems, trunk lines and associated effluent storage areas and work areas of the Camden Gas Project.



This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of Environment Protection Licence (**EPL**) 12003. The Licence conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.

This report sets out the results of continuous monitoring summarized on a monthly basis. A separate report is issued for quarterly monitoring.

This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, October, 2013) (**Publication Requirements**).

## **AIR MONITORING LOCATIONS**

<b>Point</b>	<b>Location</b>	<b>Monitoring Frequency #</b>
1	Exhaust Stack 1 on Compression Engine 1	Continuous

# Monitoring is only undertaken when the compression engines are running.

## **AIR MONITORING TEST METHODS – POINT 1**

<b>Parameter</b>	<b>NSW EPA Test Method (Sampling Method)</b>	<b>Reference Method</b>
Oxides of Nitrogen	CEM-2	USEPA Performance Specification 2
Temperature	TM-2	USEPA Method 2
Moisture content	Method approved by EPA in writing	Calibration by reference to TM-22
Volumetric Flow Rate	CEM-6	USEPA Performance Specification 6
Oxygen	CEM-3	USEPA Performance Specification 3

USEPA Method refers to the US Environmental Protection Agency 2000, Code of Federal Regulations, Title 40, Part 60, Appendix A Methods.

USEPA Performance Specification refers to the US Environmental Protection Agency 2000, Code of Federal Regulations, Title 40, Part 60, Appendix B, Performance Specifications.

## Air Monitoring Results

Continuous monitoring results are based on test results obtained over a one-hour averaging period as set out in Schedule 5 of the *Protection of the Environment Operations (Clean Air) Regulation 2010 (NSW)*.

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Number of times measured during sampling period	Minimum value	Average value	Maximum value	Concentration Limit
1	Compressor Engine 1	Oxides of Nitrogen (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre	7% oxygen	CEM-2	Continuous	Compressor Engine 1 operated from 01-31 May 2018.  See Note 1.	149	255	355	461
		Temperature	Degrees Celsius		TM-2	Continuous		353	364	371	Not applicable
		Moisture	Percent		Method approved by EPA	Continuous		5.8	6.8	7.9	Not applicable
		Volumetric flow rate	Cubic metres per second		CEM-6	Continuous		2.9	2.9	3.0	Not applicable
		Oxygen	Percent		CEM-3	Continuous		10.0	10.4	11.0	Not applicable



**Notes:**

1. In accordance with Section 3.4.1 of the EPA Publication Requirements, the following data points have not been included for Monitoring Point 1 (Compressor #1 exhaust stack) as AGL knows that the data has been unable to be collected or is incorrect.

<b>Date</b>	<b>Approximate total hours</b>	<b>Pollutant</b>	<b>Justification</b>
08 May 2018	1	Moisture, Oxides of Nitrogen, Temperature, Volumetric Flowrate, Oxygen	Data unable to be collected due light levels stabilising.