

# Correction Notice.

## Annual Environmental Performance Report 2009-10 Correction Notice

Page 34 of the 2009-10 Annual Environmental Performance Report incorrectly states the following:

*Rosalind Park Gas Plant – Continuous Monitoring*

*The licence requirement (M2.1) and DA-282-6-2003-i Schedule 4 Consent Condition 58 to provide continuous monitoring of NO<sub>x</sub>, temperature, flow rate, moisture and oxygen at Point 1, 2, and 3 was successfully undertaken in 2009/2010.*

This statement is incorrect. During the reporting year, continuous monitoring was not carried out due to equipment breakdown.

Page 35 of the 2009-10 Annual Environmental Performance Report states:

*Nitrogen Oxides Generation of Gas Engines*

*Nitrogen oxide levels complied with the licence limits for all monitoring points throughout the reporting period.*

This statement relates to the quarterly monitoring results only.

Energy in  
action.®

AGL