

Correction Notice.

Annual Environmental Performance Report 2010-11 Correction Notice

Page 34 of the 2010-11 Annual Environmental Performance Report incorrectly states the following:

Rosalind Gas Plant – Continuous Monitoring

The licence requirement (M2.1) and DA-282-6-2003-i Schedule 4 Consent Condition 58 call for continuous monitoring of NOx, temperature, flow rate, moisture and oxygen at Point 1, 2, and 3. This was successfully undertaken in 2010/2011.

This statement is incorrect. During the reporting year, continuous monitoring was not carried out due to equipment breakdown.

The 2010-11 Annual Environmental Performance Report also noted that there were no non-conformances reported for the Annual Return period from 22/12/09 to 21/12/10 (pages vii and 76). The Annual Return for this period was erroneous. The Annual Return should have reported that condition M2.1 of Environmental Protection Licence 12003, which requires continuous monitoring of NOx, temperature, flow rate, moisture and oxygen at Points 1, 2 and 3, was not complied with.

Energy in
action.®

AGL