

# Monthly Data Summary

## BAYSWATER MONTHLY DATA SUMMARY OCTOBER 2015

LICENCE NO	779
LICENCE HOLDER	AGL Macquarie
REPORTING PERIOD	OCTOBER 2015

### A1 Licence Holder

Licence Number 779  
Licence HoBWer AGL Macquarie  
Trading Name (if applicable)  
ABN 18 402 904 344

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) BAYSWATER POWER STATION  
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generation

### A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works  
Sewage Treatment Systems  
Chemical Storage Facilities  
Aircraft (helicopter) facilities

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Generation of electrical power from coal	> 4,000.00	Gwh generated
Chemical Storage	> 100	Tonnes Generated or Stored
Coal Works	> 5000000	Tonnes handled

# Monthly Data Summary

## Discharge & Monitoring Point 1

### Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator hoB Wing basin and Treated Process Water Pond to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Oil and Grease	milligrams per litre	Fortnightly	4	2.5	4.4	10.0	10 mg/L
OCTOBER 2015	13/11/2015	Total suspended solids	milligrams per litre	Fortnightly	4	2.5	8.1	13.0	20 mg/L
OCTOBER 2015	13/11/2015	Volume discharge	kilolitres per week	Weekly during discharge	4	0	6,619	8,625	36,400 kL
Comments:									

## Discharge & Monitoring Point 7

### Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Conductivity	uS/cm	Weekly	4	3380	3688	3840	4500 uS/cm
OCTOBER 2015	13/11/2015	pH	pH Units	Weekly	4	8.1	8.2	8.4	6.5 - 8.5
OCTOBER 2015	13/11/2015	Volume discharge	Megalitres per month	Weekly during discharge	1		634.6		840 ML
Comments:									

## Discharge & Monitoring Point 8

### Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Conductivity	uS/cm	Continuous during discharge	1	2210	2210	2210	-
OCTOBER 2015	13/11/2015	pH	pH Units	Daily during discharge	1	7.8	7.8	7.8	6.5 - 8.5
OCTOBER 2015	13/11/2015	Total suspended solids	milligrams per litre	Monthly	1	2.5	7.8	7.8	30 mg/L
OCTOBER 2015	13/11/2015	Volume discharge	Megalitres per day	Daily during discharge	0				700 ML
Comments: No HRSTS discharge occurred during October 2015 Conductivity and pH reported here are taken during the monthly representative sampling.									

# Monthly Data Summary

## Discharge & Monitoring Point 10

Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Nitrogen Oxides	parts per million	Continuous	One hour	100.1%	133.9	263.9	505.2	700 ppm
OCTOBER 2015	13/11/2015		milligrams per cubic metre				274.8	541.7	1037.0	1500 mg/m <sup>3</sup>
OCTOBER 2015	13/11/2015	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	190.1	361.2	463.9	600 ppm
OCTOBER 2015	13/11/2015		milligrams per cubic metre				543.3	1032.3	1325.9	-
OCTOBER 2015	13/11/2015	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	2.4%	6.6%	11.7%	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-15	13/11/2015	Cadmium	milligrams per cubic metre	1	1	0.00001	1.0
Oct-15	13/11/2015	Carbon monoxide	ppm	1	1	22	
Oct-15	13/11/2015	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-15	13/11/2015	Copper	milligrams per cubic metre	1	1	0.0001	
Oct-15	13/11/2015	Hazardous substances (Metals)	milligrams per cubic metre	1	1	0.009	5
Oct-15	13/11/2015	Hydrogen chloride	milligrams per cubic metre	1	1	5.3	100
Oct-15	13/11/2015	Mercury	milligrams per cubic metre	1	1	0.00048	1.0
Oct-15	13/11/2015	Nitrogen oxides	milligrams per cubic metre	1	1	780	1500
Oct-15	13/11/2015	Solid particles	milligrams per cubic metre	1	1	9.5	100
Oct-15	13/11/2015	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	3	100
Oct-15	13/11/2015	Sulphur dioxide	milligrams per cubic metre	1	1	1000	
Oct-15	13/11/2015	Total fluoride	milligrams per cubic metre	1	1	3.2	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 1 sampled on 4 December 2014. Results not yet available for the most recent testing carried 28 Oct 2015.							

# Monthly Data Summary

## Discharge & Monitoring Point 11

Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	2.7%	4.8%	9.2%	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-15	13/11/2015	Cadmium	milligrams per cubic metre	1	1	0.00005	1.0
Oct-15	13/11/2015	Carbon monoxide	ppm	1	1	34	
Oct-15	13/11/2015	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-15	13/11/2015	Copper	milligrams per cubic metre	1	1	0.0011	
Oct-15	13/11/2015	Hazardous substances (Metals)	milligrams per cubic metre	1	1	0.037	5
Oct-15	13/11/2015	Hydrogen chloride	milligrams per cubic metre	1	1	16.0	100
Oct-15	13/11/2015	Mercury	milligrams per cubic metre	1	1	0.00140	1.0
Oct-15	13/11/2015	Nitrogen oxides	milligrams per cubic metre	1	1	670	1500
Oct-15	13/11/2015	Solid particles	milligrams per cubic metre	1	1	8.2	100
Oct-15	13/11/2015	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	55	100
Oct-15	13/11/2015	Sulphur dioxide	milligrams per cubic metre	1	1	810	
Oct-15	13/11/2015	Total fluoride	milligrams per cubic metre	1	1	6.7	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 2 tested on 16 and 17 July 2015.							

# Monthly Data Summary

## Discharge & Monitoring Point 12

Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.2%	6.3%	13.1%	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-15	13/11/2015	Cadmium	milligrams per cubic metre	1	1	0.00002	1.0
Oct-15	13/11/2015	Carbon monoxide	ppm	1	1	5.6	
Oct-15	13/11/2015	Chlorine	milligrams per cubic metre	1	1	0.0046	200
Oct-15	13/11/2015	Copper	milligrams per cubic metre	1	1	0.0011	
Oct-15	13/11/2015	Hazardous substances (Metals)	milligrams per cubic metre	1	1	0.011	5
Oct-15	13/11/2015	Hydrogen chloride	milligrams per cubic metre	1	1	12.0	100
Oct-15	13/11/2015	Mercury	milligrams per cubic metre	1	1	0.0017	1.0
Oct-15	13/11/2015	Nitrogen oxides	milligrams per cubic metre	1	1	780	1500
Oct-15	13/11/2015	Solid particles	milligrams per cubic metre	1	1	20.0	100
Oct-15	13/11/2015	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	37.00	100
Oct-15	13/11/2015	Sulphur dioxide	milligrams per cubic metre	1	1	960	
Oct-15	13/11/2015	Total fluoride	milligrams per cubic metre	1	1	13.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 3 sampled on 14 and 15 July 2015.							

# Monthly Data Summary

## Discharge & Monitoring Point 13

Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2015	13/11/2015	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.4%	5.0%	12.4%	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-15	13/11/2015	Cadmium	milligrams per cubic metre	1	1	0.00002	1.0
Oct-15	13/11/2015	Carbon monoxide	ppm	1	1	<2.9	
Oct-15	13/11/2015	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-15	13/11/2015	Copper	milligrams per cubic metre	1	1	0.0018	
Oct-15	13/11/2015	Hazardous substances (Metals)	milligrams per cubic metre	1	1	0.012	5
Oct-15	13/11/2015	Hydrogen chloride	milligrams per cubic metre	1	1	22.0	100
Oct-15	13/11/2015	Mercury	milligrams per cubic metre	1	1	0.0011	1.0
Oct-15	13/11/2015	Nitrogen oxides	milligrams per cubic metre	1	1	940	1500
Oct-15	13/11/2015	Solid particles	milligrams per cubic metre	1	1	17.0	100
Oct-15	13/11/2015	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	9.30	100
Oct-15	13/11/2015	Sulphur dioxide	milligrams per cubic metre	1	1	930	
Oct-15	13/11/2015	Total fluoride	milligrams per cubic metre	1	1	11.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 4 sampled on 21 and 22 May 2015.							

# Monthly Data Summary

<b>Details of Non-Compliance with Licence Conditions</b>	
Licence condition number not complied with	
Summary of particulars of the non-compliance ( <b>NO MORE THAN 50 WORDS</b> )	
If required, further details on particulars of non-compliance	
Date(s) when the non-compliance occurred, if applicable	
If relevant, precise location where the non-compliance occurred (attach a map or diagram)	
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance	
Cause of non-compliance	
Action taken or that will be taken to mitigate any adverse effects of the non-compliance	
Action taken or that will be taken to prevent a recurrence of the non-compliance	