

Monthly Data Summary

Bayswater Monthly Data Summary December 2014

LICENCE NO	779
LICENCE HOLDER	AGL Macquarie
REPORTING PERIOD	01 / 12 / 2014 to 31 / 12 / 2014

A1 Licence Holder

Licence Number 779
Licence Holder AGL Macquarie
Trading Name (if applicable)
ABN 18 402 904 344

A2 Premises to which Licence Applies (if applicable)

Common Name (if any) BAYSWATER POWER STATION
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

A3 Activities to which Licence Applies

Electricity Generation

A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works
Sewage Treatment Systems
Chemical Storage Facilities
Aircraft (helicopter) facilities

A5 Fee-Based Activity Classifications

Note that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Generation of electrical power from coal	> 4,000.00	Gwh generated
Chemical Storage	> 100	Tonnes Generated or Stored
Coal Works	> 5000000	Tonnes handled

Monthly Data Summary

Discharge & Monitoring Point 1

Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator holding basin to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Oil and Grease	milligrams per litre	Fortnightly	5	3.1	5.2	6.6	10 mg/L
Dec-14	31/12/2014	Total suspended solids	milligrams per litre	Fortnightly	5	0.0	2.7	6.8	20 mg/L
Comments:									

Discharge & Monitoring Point 7

Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Conductivity	uS/cm	Weekly	5	3400	3780	4100	4500
Dec-14	31/12/2014	pH	pH Units	Weekly	5	6.3	7.6	8.2	6.5 - 8.5
Comments: Minor exceedance of pH on 1 December 2014.									

Discharge & Monitoring Point 8

Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Conductivity	uS/cm	Continuous during discharge	5	2200	2200	2200	-
Dec-14	31/12/2014	pH	pH Units	Daily during discharge	5	7.9	8.10	8.4	6.5 - 8.5
Dec-14	31/12/2014	Total suspended solids	milligrams per litre	Monthly	1	2.4	2.40	2.4	30 mg/L
Comments: No HRSTS discharge during December 2014.									

Monthly Data Summary

Discharge & Monitoring Point 10

Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Nitrogen Oxides	parts per million	Continuous 1 hr Averages	99.5%	108	296	428	700
Dec-14	31/12/2014		milligrams per cubic metre			220.95	607.84	878.89	1500
Dec-14	31/12/2014	Sulphur dioxide	parts per million	Continuous 1 hr Averages	100.0%	150	332	461	600
Dec-14	31/12/2014		milligrams per cubic metre			429	949	1317	-
Dec-14	31/12/2014	Opacity	Percentage	Continuous 1 hr Averages	100%	2.7%	6.0%	11.1%	20%

Comments:

Discharge & Monitoring Point 11

Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Opacity	Percentage	Continuous 1 hr Averages	>99%	1.0%	3.0%	5.1%	20%

Comments:

Discharge & Monitoring Point 12

Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Opacity	Percentage	Continuous 1 hr Averages	>99%	3.0%	5.7%	10.2%	20%

Comments:

Monthly Data Summary

Discharge & Monitoring Point 13

Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Undifferentiated Particulates	milligrams per cubic metre	Continuous 1 hr Averages	>99%	1.7%	8.0%	3.8%	100.0
Comments:									

Volume or Mass Monitoring Summary

For each monitoring point identified in your licence complete the details of the volume or mass monitoring indicated in the tables provided below.

If volume or mass monitoring is not required by your licence, **no tables** will appear below.

Note that this does not exclude the need to conduct appropriate concentration monitoring of assessable pollutants as required by load-based licensing (if applicable).

Discharge & Monitoring Point 1

Discharge to waters

Effluent quality and volume monitoring

Discharge from Treated Process Water Pond to Tinkers Creek

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Continuous during discharge	kilolitres per week	Continuous during discharge	30	0.0	999	10,333	36,400 kL
Comments:									

Discharge & Monitoring Point 7

Discharge to waters

Effluent quality and volume monitoring

Discharge from cooling towers to Tinklers creek.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Continuous during discharge	megalitres per month	Continuous during discharge	1	39.6	39.6	39.6	840
Comments: A total of 39.6 ML discharged during December 2014.									

Discharge & Monitoring Point 8

Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme

Discharge from Lake Liddell To Hunter River

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Dec-14	31/12/2014	Continuous during discharge	megalitres per block	Continuous during discharge	0	0	0	0	700
Comments: There were no HRSTS discharges during December 2014									

Monthly Data Summary

C2

Details of Non-Compliance with Licence

Licence condition number not complied with
Condition L 3.6
Summary of particulars of the non-compliance (NO MORE THAN 50 WORDS)
Routine water quality sampling conducted on 1 December 2014 at EPL Point 7 returned a reading of pH 6.3. The licence limit is a pH range between 6.5 and 8.5.
If required, further details on particulars of non-compliance
Date(s) when the non-compliance occurred, if applicable
1-Dec-14
If relevant, precise location where the non-compliance occurred (attach a map or diagram)
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
Cause of non-compliance
Under investigation.
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
As required under Pollution Reduction Program 2, EPL Point 7 has realtime monitoring for pH. This allows for beter investigation into sources of water with criteria outside the licenced limits.
Action taken or that will be taken to prevent a recurrence of the non-compliance
Investigation into the source of the water below licenced pH limits is ongoing.