

# Monthly Data Summary

## BAYSWATER MONTHLY DATA SUMMARY FEBRUARY 2018

LICENCE NO	779
LICENCE HOLDER	AGL Macquarie
REPORTING PERIOD	FEBRUARY 2018

### A1 Licence Holder

Licence Number	779
Licence Holder	AGL Macquarie
Trading Name (if applicable)	
ABN	18 402 904 344

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any)	BAYSWATER POWER STATION
Premises	NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generation

### A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works  
Sewage Treatment Systems  
Chemical Storage Facilities  
Aircraft (helicopter) facilities

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Generation of electrical power from coal	> 4,000.00	Gwh generated
Chemical Storage	> 100	Tonnes Generated or Stored
Coal Works	> 5000000	Tonnes handled

# Monthly Data Summary

## Discharge & Monitoring Point 1

### Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator hoB Wing basin and Treated Process Water Pond to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Oil and Grease	milligrams per litre	Fortnightly	4	<5	2.5	<5	10 mg/L
FEBRUARY 2018	14/03/2018	Total suspended solids	milligrams per litre	Fortnightly	4	1.0	4.0	11.0	20 mg/L
FEBRUARY 2018	14/03/2018	Volume discharge	kilolitres per week	Weekly during discharge	4	0	13,794	16,770	36,400 kL
Comments:									

## Discharge & Monitoring Point 7

### Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Conductivity	uS/cm	Continuous	99.9%	265.0	3293.7	4046.0	4500 uS/cm
FEBRUARY 2018	14/03/2018	pH	pH Units	Continuous	99.9%	6.6	7.9	8.3	6.5 - 8.5
FEBRUARY 2018	14/03/2018	Volume discharge	Megalitres per month	Weekly during discharge	18		198.4		840 ML
Comments:									

## Discharge & Monitoring Point 8

### Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Conductivity	uS/cm	Continuous during discharge	1	2630.0	2630.0	2630.0	-
FEBRUARY 2018	14/03/2018	pH	pH Units	Daily during discharge	1	7.9	7.9	7.9	6.5 - 8.5
FEBRUARY 2018	14/03/2018	Total suspended solids	milligrams per litre	Monthly	1	<5	2.5	<5	30 mg/L
FEBRUARY 2018	14/03/2018	Volume discharge	Megalitres per day	Daily during discharge	-	-	-	-	700 ML
Comments: HRSTS Discharge did not occur during February 2018. Results from routine monthly sampling									

# Monthly Data Summary

## Discharge & Monitoring Point 17

### Discharge to waters

Ravensworth void. Inlet point located on the Void 4 pontoon pump system

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Conductivity	uS/cm	Continuous during discharge	1	7500.0	7500.0	7500.0	-
FEBRUARY 2018	14/03/2018	pH	pH Units	Daily during discharge	1	8.8	8.8	8.8	6.5 - 9.5
FEBRUARY 2018	14/03/2018	Total suspended solids	milligrams per litre	Monthly	1	20	20	20	30 mg/L
FEBRUARY 2018	14/03/2018	Boron	milligrams per litre	Weekly during discharge	1	3.1	3.1	3.1	0.81
FEBRUARY 2018	14/03/2018	Cadmium	milligrams per litre	Weekly during discharge	1	0.0001	0.0001	0.0001	0.0003
FEBRUARY 2018	14/03/2018	Copper	milligrams per litre	Weekly during discharge	1	<0.001	0.0005	<0.001	0.001
FEBRUARY 2018	14/03/2018	Iron	milligrams per litre	Weekly during discharge	1	<0.05	0.025	<0.05	0.27
FEBRUARY 2018	14/03/2018	Molybdenum	milligrams per litre	Weekly during discharge	1	0.39	0.39	0.39	0.29
FEBRUARY 2018	14/03/2018	Nickel	milligrams per litre	Weekly during discharge	1	0.009	0.009	0.009	0.19
FEBRUARY 2018	14/03/2018	Silver	milligrams per litre	Weekly during discharge	1	<0.0001	0.0001	<0.0001	0.0005
FEBRUARY 2018	14/03/2018	Volume discharge	Megalitres per day	Daily during discharge	-	-	-	-	20 ML
Comments:	HRSTS Discharge did not occur during February 2018. Results from routine monthly sampling								

## Discharge & Monitoring Point 18

### Discharge to waters

Discharge from Bayswater Ash Dam unlined flood pillway located near left abutment

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Conductivity	uS/cm	Weekly during discharge	0				-
FEBRUARY 2018	14/03/2018	pH	pH Units	Weekly during discharge	0				6.5 - 9.5
FEBRUARY 2018	14/03/2018	Total suspended solids	milligrams per litre	Weekly during discharge	0				30 mg/L
FEBRUARY 2018	14/03/2018	Boron	milligrams per litre	Weekly during discharge	0				0.81
FEBRUARY 2018	14/03/2018	Cadmium	milligrams per litre	Weekly during discharge	0				0.0003
FEBRUARY 2018	14/03/2018	Copper	milligrams per litre	Weekly during discharge	0				0.001

# Monthly Data Summary

FEBRUARY 2018	14/03/2018	Iron	milligrams per litre	Weekly during discharge	0				0.27
FEBRUARY 2018	14/03/2018	Molybdenum	milligrams per litre	Weekly during discharge	0				0.29
FEBRUARY 2018	14/03/2018	Nickel	milligrams per litre	Weekly during discharge	0				0.19
FEBRUARY 2018	14/03/2018	Silver	milligrams per litre	Weekly during discharge	0				0.0005
Comments:	Discharge did not occur during February 2018.								

# Monthly Data Summary

## Discharge & Monitoring Point 10

### Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Nitrogen Oxides	parts per million	Continuous	One hour	97.3%	114.6	254.1	484.6	-
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				235.2	521.5	994.7	1500 mg/m <sup>3</sup>
FEBRUARY 2018	14/03/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	177.7	239.9	341.2	600 ppm
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				507.8	685.7	975.0	-
FEBRUARY 2018	14/03/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	2.3%	3.9%	8.0%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	15/11/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Oct-17	15/11/2017	Carbon monoxide	ppm	1	1	<2	
Oct-17	15/11/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-17	15/11/2017	Copper	milligrams per cubic metre	1	1	0.0005	
Oct-17	15/11/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.013	5
Oct-17	15/11/2017	Hydrogen chloride	milligrams per cubic metre	1	1	15.0	100
Oct-17	15/11/2017	Mercury	milligrams per cubic metre	1	1	0.00180	1.0
Oct-17	15/11/2017	Nitrogen oxides	milligrams per cubic metre	1	1	850	1500
Oct-17	15/11/2017	Solid particles	milligrams per cubic metre	1	1	45.0	100
Oct-17	15/11/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	20.00	100
Oct-17	15/11/2017	Sulphur dioxide	milligrams per cubic metre	1	1	950	
Oct-17	15/11/2017	Total fluoride	milligrams per cubic metre	1	1	9.9	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 1 tested on 10 October 2017.							

# Monthly Data Summary

## Discharge & Monitoring Point 11

Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Nitrogen Oxides	parts per million	Continuous	One hour	100.0%	131.0	204.5	302.6	-
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				269.0	419.7	621.1	1500 mg/m <sup>3</sup>
FEBRUARY 2018	14/03/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	199.8	245.5	342.0	600 ppm
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				570.9	701.8	977.4	-
FEBRUARY 2018	14/03/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.1%	4.8%	11.2%	-
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	15/11/2017	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-17	15/11/2017	Carbon monoxide	ppm	1	1	3	
Oct-17	15/11/2017	Chlorine	milligrams per cubic metre	1	1	<0.007	200
Oct-17	15/11/2017	Copper	milligrams per cubic metre	1	1	0.0004	
Oct-17	15/11/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.0096	5
Oct-17	15/11/2017	Hydrogen chloride	milligrams per cubic metre	1	1	14.0	100
Oct-17	15/11/2017	Mercury	milligrams per cubic metre	1	1	0.00089	1.0
Oct-17	15/11/2017	Nitrogen oxides	milligrams per cubic metre	1	1	620	1500
Oct-17	15/11/2017	Solid particles	milligrams per cubic metre	1	1	41.0	100
Oct-17	15/11/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	3.00	100
Oct-17	15/11/2017	Sulphur dioxide	milligrams per cubic metre	1	1	970	
Oct-17	15/11/2017	Total fluoride	milligrams per cubic metre	1	1	9.2	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 2 tested on 12 October 2018							

# Monthly Data Summary

## Discharge & Monitoring Point 12

Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Nitrogen Oxides	parts per million	Continuous	One hour	100.0%	164.7	304.9	429.0	-
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				338.1	625.8	880.5	1500 mg/m <sup>3</sup>
FEBRUARY 2018	14/03/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	227.6	308.4	389.6	600 ppm
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				650.4	881.3	1113.5	-
FEBRUARY 2018	14/03/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.6%	4.9%	10.8%	-
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
May-17	3/07/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
May-17	3/07/2017	Carbon monoxide	ppm	1	1	97	
May-17	3/07/2017	Chlorine	milligrams per cubic metre	1	1	<0.006	200
May-17	3/07/2017	Copper	milligrams per cubic metre	1	1	0.0007	
May-17	3/07/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.011	5
May-17	3/07/2017	Hydrogen chloride	milligrams per cubic metre	1	1	22.0	100
May-17	3/07/2017	Mercury	milligrams per cubic metre	1	1	0.00130	1.0
May-17	3/07/2017	Nitrogen oxides	milligrams per cubic metre	1	1	720	1500
May-17	3/07/2017	Solid particles	milligrams per cubic metre	1	1	24.0	100
May-17	3/07/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.90	100
May-17	3/07/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1100	
May-17	3/07/2017	Total fluoride	milligrams per cubic metre	1	1	11.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 3 tested on 30 May 2017							

# Monthly Data Summary

## Discharge & Monitoring Point 13

### Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
FEBRUARY 2018	14/03/2018	Nitrogen Oxides	parts per million	Continuous	One hour	99.1%	125.1	237.0	347.6	-
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				256.8	486.4	713.5	1500 mg/m <sup>3</sup>
FEBRUARY 2018	14/03/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	158.8	256.0	377.7	600 ppm
FEBRUARY 2018	14/03/2018		milligrams per cubic metre				454.0	731.7	1079.6	-
FEBRUARY 2018	14/03/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.8%	4.4%	8.2%	-
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Jul-17	5/09/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Jul-17	5/09/2017	Carbon monoxide	ppm	1	1	90	
Jul-17	5/09/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Jul-17	5/09/2017	Copper	milligrams per cubic metre	1	1	0.0017	
Jul-17	5/09/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.025	5
Jul-17	5/09/2017	Hydrogen chloride	milligrams per cubic metre	1	1	17.0	100
Jul-17	5/09/2017	Mercury	milligrams per cubic metre	1	1	0.00061	1.0
Jul-17	5/09/2017	Nitrogen oxides	milligrams per cubic metre	1	1	650	1500
Jul-17	5/09/2017	Solid particles	milligrams per cubic metre	1	1	48.0	100
Jul-17	5/09/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	2.40	100
Jul-17	5/09/2017	Sulphur dioxide	milligrams per cubic metre	1	1	750	
Jul-17	5/09/2017	Total fluoride	milligrams per cubic metre	1	1	10.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 4 tested on 27 July 2017							



# Monthly Data Summary

<b>Details of Non-Compliance with Licence Conditions</b>
Licence condition number not complied with
N/A
Summary of particulars of the non-compliance ( <b>NO MORE THAN 50 WORDS</b> )
If required, further details on particulars of non-compliance
-
Date(s) when the non-compliance occurred, if applicable
If relevant, precise location where the non-compliance occurred (attach a map or diagram)
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
-
Cause of non-compliance
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
Action taken or that will be taken to prevent a recurrence of the non-compliance