

# Monthly Data Summary

## BAYSWATER MONTHLY DATA SUMMARY JANUARY 2019

LICENCE NO	779
LICENCE HOLDER	AGL Macquarie
REPORTING PERIOD	JANUARY 2019

### A1 Licence Holder

Licence Number 779  
Licence Holder AGL Macquarie  
Trading Name (if applicable)  
ABN 18 402 904 344

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) BAYSWATER POWER STATION  
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generation

### A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works  
Sewage Treatment Systems  
Chemical Storage Facilities  
Aircraft (helicopter) facilities

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Generation of electrical power from coal	> 4,000.00	Gwh generated
Chemical Storage	> 100	Tonnes Generated or Stored
Coal Works	> 5000000	Tonnes handled

# Monthly Data Summary

## Discharge & Monitoring Point 1

### Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator hoBWinng basin and Treated Process Water Pond to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Oil and Grease	milligrams per litre	Fortnightly	5	<5	2.5	<5	10 mg/L
JANUARY 2019	15/02/2019	Total suspended solids	milligrams per litre	Fortnightly	5	<1	3.3	7.0	20 mg/L
JANUARY 2019	15/02/2019	Volume discharge	kilolitres per week	Weekly during discharge	4	0	15,490	18,180	36,400 KL
Comments:									

## Discharge & Monitoring Point 7

### Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Continuous	99.3%	362.0	3495.4	10166.3	4500 uS/cm
JANUARY 2019	15/02/2019	pH	pH Units	Continuous	99.3%	7.1	8.1	8.3	6.5 - 8.5
JANUARY 2019	15/02/2019	Volume discharge	Megalitres per month	Weekly during discharge	22	350.0			840 ML
Comments:									

## Discharge & Monitoring Point 8

### Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Continuous during discharge	1	2700.0	2700.0	2700.0	-
JANUARY 2019	15/02/2019	pH	pH Units	Daily during discharge	1	8.0	8.0	8.0	6.5 - 8.5
JANUARY 2019	15/02/2019	Total suspended solids	milligrams per litre	Monthly	1	<5	2.5	<5	30 mg/L
JANUARY 2019	15/02/2019	Volume discharge	Megalitres per day	Daily during discharge	-	-	-	-	700 ML
Comments: HRSTS discharge did not occur during January 2019. Results obtained from regular monthly sampling									

# Monthly Data Summary

## Discharge & Monitoring Point 17

### Discharge to waters

#### Ravenworth void. Inlet point located on the Void 4 pontoon pump system

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Continuous during discharge	1	7730.0	7730.0	7730.0	-
JANUARY 2019	15/02/2019	pH	pH Units	Daily during discharge	1	8.7	8.7	8.7	6.5 - 9.5
JANUARY 2019	15/02/2019	Total suspended solids	milligrams per litre	Monthly	1	<5	2.5	<5	30 mg/L
JANUARY 2019	15/02/2019	Boron	milligrams per litre	Weekly during discharge	1	3.4	3.4	3.4	0.81
JANUARY 2019	15/02/2019	Cadmium	milligrams per litre	Weekly during discharge	1	0.0	0.0	0.0	0.0003
JANUARY 2019	15/02/2019	Copper	milligrams per litre	Weekly during discharge	1	<0.001	0.0	<0.001	0.001
JANUARY 2019	15/02/2019	Iron	milligrams per litre	Weekly during discharge	1	0.0	0.0	0.0	0.27
JANUARY 2019	15/02/2019	Molybdenum	milligrams per litre	Weekly during discharge	1	0.3	0.3	0.3	0.29
JANUARY 2019	15/02/2019	Nickel	milligrams per litre	Weekly during discharge	1	0.0	0.0	0.0	0.19
JANUARY 2019	15/02/2019	Silver	milligrams per litre	Weekly during discharge	1	<0.001	0.0	<0.001	0.0005
JANUARY 2019	15/02/2019	Volume discharge	Megalitres per day	Daily during discharge	-	-	-	-	20 ML
Comments:	HRSTS discharge did not occur during January 2019. Results obtained from regular monthly sampling								

## Discharge & Monitoring Point 18

### Discharge to waters

#### Discharge from Bayswater Ash Dam unlined flood pillway located near left abutment

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Conductivity	uS/cm	Weekly during discharge	0				-
JANUARY 2019	15/02/2019	pH	pH Units	Weekly during discharge	0				6.5 - 9.5
JANUARY 2019	15/02/2019	Total suspended solids	milligrams per litre	Weekly during discharge	0				30 mg/L
JANUARY 2019	15/02/2019	Boron	milligrams per litre	Weekly during discharge	0				0.81
JANUARY 2019	15/02/2019	Cadmium	milligrams per litre	Weekly during discharge	0				0.0003
JANUARY 2019	15/02/2019	Copper	milligrams per litre	Weekly during discharge	0				0.001

# Monthly Data Summary

JANUARY 2019	15/02/2019	Iron	milligrams per litre	Weekly during discharge	0				0.27
JANUARY 2019	15/02/2019	Molybdenum	milligrams per litre	Weekly during discharge	0				0.29
JANUARY 2019	15/02/2019	Nickel	milligrams per litre	Weekly during discharge	0				0.19
JANUARY 2019	15/02/2019	Silver	milligrams per litre	Weekly during discharge	0				0.0005
Comments:	Discharge did not occur during January 2019								

# Monthly Data Summary

## Discharge & Monitoring Point 10

### Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	parts per million	Continuous	One hour	98.7%	101.1	186.6	243.0	-
JANUARY 2019	15/02/2019		milligrams per cubic metre				207.4			383.0
JANUARY 2019	15/02/2019	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	131.2	180.0	234.9	600 ppm
JANUARY 2019	15/02/2019		milligrams per cubic metre				374.8			514.4
JANUARY 2019	15/02/2019	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.7%	3.4%	6.3%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-18	26/11/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Oct-18	26/11/2018	Carbon monoxide	ppm	1	1	4	
Oct-18	26/11/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-18	26/11/2018	Copper	milligrams per cubic metre	1	1	0.0013	
Oct-18	26/11/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.016	5
Oct-18	26/11/2018	Hydrogen chloride	milligrams per cubic metre	1	1	11.0	100
Oct-18	26/11/2018	Mercury	milligrams per cubic metre	1	1	0.00100	1.0
Oct-18	26/11/2018	Nitrogen oxides	milligrams per cubic metre	1	1	860	1500
Oct-18	26/11/2018	Solid particles	milligrams per cubic metre	1	1	15.0	100
Oct-18	26/11/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	3.10	100
Oct-18	26/11/2018	Sulphur dioxide	milligrams per cubic metre	1	1	930	
Oct-18	26/11/2018	Total fluoride	milligrams per cubic metre	1	1	8.5	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 1.							

# Monthly Data Summary

## Discharge & Monitoring Point 11

### Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	parts per million	Continuous	One hour	89.6%	109.1	255.5	343.2	-
JANUARY 2019	15/02/2019		milligrams per cubic metre				224.0	524.4	704.4	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	186.4	255.1	311.2	600 ppm
JANUARY 2019	15/02/2019		milligrams per cubic metre				532.9	729.0	889.6	-
JANUARY 2019	15/02/2019	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	1.3%	3.8%	8.8%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-18	26/11/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Oct-18	26/11/2018	Carbon monoxide	ppm	1	1	<2	
Oct-18	26/11/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-18	26/11/2018	Copper	milligrams per cubic metre	1	1	0.0008	
Oct-18	26/11/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.038	5
Oct-18	26/11/2018	Hydrogen chloride	milligrams per cubic metre	1	1	8.5	100
Oct-18	26/11/2018	Mercury	milligrams per cubic metre	1	1	0.00160	1.0
Oct-18	26/11/2018	Nitrogen oxides	milligrams per cubic metre	1	1	760	1500
Oct-18	26/11/2018	Solid particles	milligrams per cubic metre	1	1	17.0	100
Oct-18	26/11/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	3.10	100
Oct-18	26/11/2018	Sulphur dioxide	milligrams per cubic metre	1	1	760	
Oct-18	26/11/2018	Total fluoride	milligrams per cubic metre	1	1	5.9	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 2.							

# Monthly Data Summary

## Discharge & Monitoring Point 12

### Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	parts per million	Continuous	One hour	96.5%	101.2	338.3	487.0	-
JANUARY 2019	15/02/2019		milligrams per cubic metre				207.7	694.3	999.6	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019	Sulphur dioxide	parts per million	Continuous	One hour	96.5%	101.2	330.7	433.6	600 ppm
JANUARY 2019	15/02/2019		milligrams per cubic metre				289.2	945.3	1239.2	-
JANUARY 2019	15/02/2019	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	2.3%	5.6%	11.1%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Apr-18	18/05/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Apr-18	18/05/2018	Carbon monoxide	ppm	1	1	61	
Apr-18	18/05/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Apr-18	18/05/2018	Copper	milligrams per cubic metre	1	1	0.0009	
Apr-18	18/05/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.015	5
Apr-18	18/05/2018	Hydrogen chloride	milligrams per cubic metre	1	1	14.0	100
Apr-18	18/05/2018	Mercury	milligrams per cubic metre	1	1	0.00140	1.0
Apr-18	18/05/2018	Nitrogen oxides	milligrams per cubic metre	1	1	610	1500
Apr-18	18/05/2018	Solid particles	milligrams per cubic metre	1	1	34.0	100
Apr-18	18/05/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	4.50	100
Apr-18	18/05/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1100	
Apr-18	18/05/2018	Total fluoride	milligrams per cubic metre	1	1	12.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 3.							

# Monthly Data Summary

## Discharge & Monitoring Point 13

### Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
JANUARY 2019	15/02/2019	Nitrogen Oxides	parts per million	Continuous	One hour	99.5%	136.8	228.6	286.2	-
JANUARY 2019	15/02/2019		milligrams per cubic metre				280.7	469.2	587.4	1500 mg/m <sup>3</sup>
JANUARY 2019	15/02/2019	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	208.3	279.8	362.2	600 ppm
JANUARY 2019	15/02/2019		milligrams per cubic metre				595.4	799.7	1035.3	-
JANUARY 2019	15/02/2019	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	2.7%	5.6%	11.8%	-
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Apr-18	10/08/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Apr-18	10/08/2018	Carbon monoxide	ppm	1	1	2	
Apr-18	10/08/2018	Chlorine	milligrams per cubic metre	1	1	<0.006	200
Apr-18	10/08/2018	Copper	milligrams per cubic metre	1	1	0.0012	
Apr-18	10/08/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.016	5
Apr-18	10/08/2018	Hydrogen chloride	milligrams per cubic metre	1	1	15.0	100
Apr-18	10/08/2018	Mercury	milligrams per cubic metre	1	1	0.00340	1.0
Apr-18	10/08/2018	Nitrogen oxides	milligrams per cubic metre	1	1	650	1500
Apr-18	10/08/2018	Solid particles	milligrams per cubic metre	1	1	31.0	100
Apr-18	10/08/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	2.20	100
Apr-18	10/08/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1200	
Apr-18	10/08/2018	Total fluoride	milligrams per cubic metre	1	1	11.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 4.							



# Monthly Data Summary

Details of Non-Compliance with Licence Conditions	
Licence condition number not complied with	
L3.6	
Summary of particulars of the non-compliance ( <b>NO MORE THAN 50 WORDS</b> )	
On 26 January 2019 at approximately 3:55pm EPL point 7 exceeded the electrical conductivity (EC) limit of 4500, recording a high of 10166 $\mu\text{S}/\text{cm}$ at 4:10pm. Normal EC readings returned at 4:35pm. There was no actual or material environmental harm.	
If required, further details on particulars of non-compliance	
-	
Date(s) when the non-compliance occurred, if applicable	
26-Jan-19	
If relevant, precise location where the non-compliance occurred (attach a map or diagram)	
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance	
-	
Cause of non-compliance	
A pump flange gasket failed spraying waste water out onto the road where it was able to enter station drains	
Action taken or that will be taken to mitigate any adverse effects of the non-compliance	
The system was shut down and full blowdown of all units was initiated.	
Action taken or that will be taken to prevent a recurrence of the non-compliance	
Repairs carried out on pipework	