

# Monthly Data Summary

## LIDDELL MONTHLY DATA SUMMARY DECEMBER 2018

LICENCE NO	2122
LICENCE HOLDER	AGL MACQUARIE
REPORTING PERIOD	DECEMBER 2018

### A1 Licence Holder

Licence Number 2122  
Licence Holder AGL MACQUARIE  
Trading Name (if applicable)  
ABN 18 167 859 494

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION  
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generating Works  
Coal Works

### A4 Other Activities (if applicable)

Helicopter-related facilities  
Chemical storage  
Operation of Emergency 1.5 MW diesel generator  
Operation of Gas turbine  
Sewage treatment  
Waste storage

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Coal works	> 5,000,000.00	T handled
Generation of electrical power from coal	> 4,000.00	Gwh generated

# Monthly Data Summary

## Discharge & Monitoring Point 7

301204 East 6416350 North

Discharge to Air

In the flue gases of unit 1 boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	272.7	617.9	800.8	1500 mg/m <sup>3</sup>
DECEMBER 2018	15/01/2019		parts per million				132.9	301.0	390.2	700 ppm
DECEMBER 2018	15/01/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	715.7	929.1	1091.1	
DECEMBER 2018	15/01/2019		parts per million				250.4	325.1	381.8	600 ppm
DECEMBER 2018	15/01/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	1.6	4.4	7.8	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-18	8/11/2018	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-18	8/11/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-18	8/11/2018	Copper	milligrams per cubic metre	1	1	0.0017	
Oct-18	8/11/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.058	5
Oct-18	8/11/2018	Hydrogen chloride	milligrams per cubic metre	1	1	26.0	100
Oct-18	8/11/2018	Mercury	milligrams per cubic metre	1	1	0.00330	1.0
Oct-18	8/11/2018	Nitrogen oxides	milligrams per cubic metre	1	1	810	1500
Oct-18	8/11/2018	Solid particles	milligrams per cubic metre	1	1	5.5	100
Oct-18	8/11/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	2.000	100
Oct-18	8/11/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1200	
Oct-18	8/11/2018	Total fluoride	milligrams per cubic metre	1	1	12.0	50
Oct-18	8/11/2018	Volatile organic compounds	milligrams per cubic metre	1	1	<0.03	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.							

# Monthly Data Summary

## Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	216	561	691	1500 mg/m <sup>3</sup>
DECEMBER 2018	15/01/2019		parts per million				105	274	337	700 ppm
DECEMBER 2018	15/01/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	673	867	1056	
DECEMBER 2018	15/01/2019		parts per million				236	303	369	600 ppm
DECEMBER 2018	15/01/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	4.3	6.2	15.9	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Mar-18	12/04/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Mar-18	12/04/2018	Chlorine	milligrams per cubic metre	1	1	<0.007	200
Mar-18	12/04/2018	Copper	milligrams per cubic metre	1	1	0.0040	
Mar-18	12/04/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.019	5
Mar-18	12/04/2018	Hydrogen chloride	milligrams per cubic metre	1	1	8.7	100
Mar-18	12/04/2018	Mercury	milligrams per cubic metre	1	1	<0.00080	1.0
Mar-18	12/04/2018	Nitrogen oxides	milligrams per cubic metre	1	1	550	1500
Mar-18	12/04/2018	Solid particles	milligrams per cubic metre	1	1	37.0	100
Mar-18	12/04/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.880	100
Mar-18	12/04/2018	Sulphur dioxide	milligrams per cubic metre	1	1	900	
Mar-18	12/04/2018	Total fluoride	milligrams per cubic metre	1	1	8.2	50
Mar-18	12/04/2018	Volatile organic compounds	milligrams per cubic metre	1	1	0.940	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.							

# Monthly Data Summary

## Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	319.2	591.7	723.1	1500 mg/m <sup>3</sup>
DECEMBER 2018	15/01/2019		parts per million				155.5			288.3
DECEMBER 2018	15/01/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	712.2	1003.3	1194.7	
DECEMBER 2018	15/01/2019		parts per million				249.2			351.0
DECEMBER 2018	15/01/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	89.9%	0.1	4.9	13.9	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	1/12/2017	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-17	1/12/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-17	1/12/2017	Copper	milligrams per cubic metre	1	1	0.0037	
Oct-17	1/12/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.02	5
Oct-17	1/12/2017	Hydrogen chloride	milligrams per cubic metre	1	1	20.0	100
Oct-17	1/12/2017	Mercury	milligrams per cubic metre	1	1	0.00051	1.0
Oct-17	1/12/2017	Nitrogen oxides	milligrams per cubic metre	1	1	770	1500
Oct-17	1/12/2017	Solid particles	milligrams per cubic metre	1	1	42.0	100
Oct-17	1/12/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.700	100
Oct-17	1/12/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1300	
Oct-17	1/12/2017	Total fluoride	milligrams per cubic metre	1	1	9.8	50
Oct-17	1/12/2017	Volatile organic compounds	milligrams per cubic metre	1	1	<0.02	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.							

# Monthly Data Summary

## Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	365.7	560.5	687.2	1500 mg/m <sup>3</sup>
DECEMBER 2018	15/01/2019		parts per million				178.2	273.1	334.8	700 ppm
DECEMBER 2018	15/01/2019	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	711.6	920.8	1078.2	
DECEMBER 2018	15/01/2019		parts per million				249.0	322.2	377.3	600 ppm
DECEMBER 2018	15/01/2019	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	2.2	5.8	14.8	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-18	29/11/2018	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-18	29/11/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-18	29/11/2018	Copper	milligrams per cubic metre	1	1	0.0007	
Oct-18	29/11/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.013	5
Oct-18	29/11/2018	Hydrogen chloride	milligrams per cubic metre	1	1	21.0	100
Oct-18	29/11/2018	Mercury	milligrams per cubic metre	1	1	0.00037	1.0
Oct-18	29/11/2018	Nitrogen oxides	milligrams per cubic metre	1	1	540	1500
Oct-18	29/11/2018	Solid particles	milligrams per cubic metre	1	1	16.0	100
Oct-18	29/11/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.900	100
Oct-18	29/11/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1100	
Oct-18	29/11/2018	Total fluoride	milligrams per cubic metre	1	1	11.0	50
Oct-18	29/11/2018	Volatile organic compounds	milligrams per cubic metre	1	1	<0.2	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.							

# Monthly Data Summary

## Discharge & Monitoring Point 12

Discharge to waters <301204 East 6416350 North> Update

Liddell Outfall Canal

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Ammonia	milligrams per litre	Fortnightly	2	0.01	0.035	0.06	-
DECEMBER 2018	15/01/2019	Antimony	milligrams per litre	Fortnightly	2	0.008	0.0085	0.009	
DECEMBER 2018	15/01/2019	Arsenic	milligrams per litre	Fortnightly	2	0.007	0.0075	0.008	-
DECEMBER 2018	15/01/2019	Barium	milligrams per litre	Fortnightly	2	0.109	0.11	0.111	
DECEMBER 2018	15/01/2019	Beryllium	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
DECEMBER 2018	15/01/2019	Boron	milligrams per litre	Fortnightly	2	1.28	1.32	1.36	
DECEMBER 2018	15/01/2019	Cadmium	milligrams per litre	Fortnightly	2	<0.0001	0.00005	<0.0001	-
DECEMBER 2018	15/01/2019	Chlorine	milligrams per litre	Fortnightly	2	0.05	0.115	0.18	
DECEMBER 2018	15/01/2019	Chromium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
DECEMBER 2018	15/01/2019	Chromium (total)	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	
DECEMBER 2018	15/01/2019	Cobalt	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Conductivity	uS/cm	Fortnightly	2	2810.0	2815.0	2820.0	
DECEMBER 2018	15/01/2019	Copper	milligrams per litre	Fortnightly	2	0.004	0.005	0.006	-
DECEMBER 2018	15/01/2019	Flouride	milligrams per litre	Fortnightly	2	1.24	1.26	1.28	
DECEMBER 2018	15/01/2019	Lead	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
DECEMBER 2018	15/01/2019	Manganese	milligrams per litre	Fortnightly	2	0.009	0.011	0.013	
DECEMBER 2018	15/01/2019	Mercury	milligrams per litre	Fortnightly	2	<0.0001	<0.0001	<0.0001	-
DECEMBER 2018	15/01/2019	Methylene Blue Active Substance	milligrams per litre	Fortnightly	2	<0.1	<0.1	<0.1	
DECEMBER 2018	15/01/2019	Molybdenum	milligrams per litre	Fortnightly	2	0.125	0.126	0.127	-

# Monthly Data Summary

DECEMBER 2018	15/01/2019	Nickel	milligrams per litre	Fortnightly	2	0.005	0.005	0.005	
DECEMBER 2018	15/01/2019	Nitrogen (total)	milligrams per litre	Fortnightly	2	0.4	0.45	0.5	-
DECEMBER 2018	15/01/2019	Oil and Grease	milligrams per litre	Weekly	4	<5	<5	<5	
DECEMBER 2018	15/01/2019	pH	pH Units	Daily	31	8.1	8.4	8.6	-
DECEMBER 2018	15/01/2019	Phosphorus	milligrams per litre	Fortnightly	2	<0.01	0.0125	0.02	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Selenium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
DECEMBER 2018	15/01/2019	Sulfur	milligrams per litre	Fortnightly	2	649	703.5	758	
DECEMBER 2018	15/01/2019	Temperature	milligrams per litre	Fortnightly	2	30.8	31.6	32.4	
DECEMBER 2018	15/01/2019	Tin	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Total Dissolved Solids	milligrams per litre	Fortnightly	2	1920	1930	1940	
DECEMBER 2018	15/01/2019	Total Organic Carbon	milligrams per litre	Fortnightly	2	6	6	6	-
DECEMBER 2018	15/01/2019	TSS	milligrams per litre	Fortnightly	2	2	3	4	
DECEMBER 2018	15/01/2019	Vanadium	milligrams per litre	Fortnightly	2	0.01	0.015	0.02	-
DECEMBER 2018	15/01/2019	Zinc	milligrams per litre	Fortnightly	2	<0.005	<0.005	<0.005	
Comments									

# Monthly Data Summary

Comments									
<b>Discharge &amp; Monitoring Point 13</b>									
Discharge to waters <301204 East 6416350 North> Update									
Liddell Oil and Grit Trap									
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Ammonia	milligrams per litre	Fortnightly	2	0.38	0.705	1.03	-
DECEMBER 2018	15/01/2019	Antimony	milligrams per litre	Fortnightly	2	0.007	0.008	0.009	
DECEMBER 2018	15/01/2019	Arsenic	milligrams per litre	Fortnightly	2	0.007	0.007	0.007	-
DECEMBER 2018	15/01/2019	Barium	milligrams per litre	Fortnightly	2	0.1	0.1025	0.105	
DECEMBER 2018	15/01/2019	Beryllium	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Boron	milligrams per litre	Fortnightly	2	1.2	1.235	1.27	
DECEMBER 2018	15/01/2019	Cadmium	milligrams per litre	Fortnightly	2	<0.0001	0.00005	<0.0001	-
DECEMBER 2018	15/01/2019	Chlorine	milligrams per litre	Fortnightly	2	0.07	0.085	0.1	
DECEMBER 2018	15/01/2019	Chromium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
DECEMBER 2018	15/01/2019	Chromium (total)	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	
DECEMBER 2018	15/01/2019	Cobalt	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Conductivity	uS/cm	Fortnightly	2	2630.0	2690.0	2750.0	
DECEMBER 2018	15/01/2019	Copper	milligrams per litre	Fortnightly	2	0.009	0.0105	0.012	-
DECEMBER 2018	15/01/2019	Flouride	milligrams per litre	Fortnightly	2	1.11	1.2	1.29	
DECEMBER 2018	15/01/2019	Lead	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Manganese	milligrams per litre	Fortnightly	2	0.012	0.015	0.018	
DECEMBER 2018	15/01/2019	Mercury	milligrams per litre	Fortnightly	2	<0.0001	<0.0001	<0.0001	-
DECEMBER 2018	15/01/2019	Methylene Blue Active Substance	milligrams per litre	Fortnightly	2	<0.1	<0.1	<0.1	
DECEMBER 2018	15/01/2019	Molybdenum	milligrams per litre	Fortnightly	2	0.116	0.1185	0.121	-
DECEMBER 2018	15/01/2019	Nickel	milligrams per litre	Fortnightly	2	0.004	0.005	0.006	



# Monthly Data Summary

DECEMBER 2018	15/01/2019	Nitrogen (total)	milligrams per litre	Fortnightly	2	1	1.2	1.4	-
DECEMBER 2018	15/01/2019	Oil and Grease	milligrams per litre	Weekly	4	<5	<5	<5	
DECEMBER 2018	15/01/2019	pH	pH Units	Daily	31	7.1	8.2	8.7	-
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Phosphorus	milligrams per litre	Fortnightly	2	0.01	0.015	0.02	
DECEMBER 2018	15/01/2019	Selenium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
DECEMBER 2018	15/01/2019	Sulfur	milligrams per litre	Fortnightly	2	644	663	682	
DECEMBER 2018	15/01/2019	Temperature	milligrams per litre	Fortnightly	2	26.9	28.55	30.2	
DECEMBER 2018	15/01/2019	Tin	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Total Dissolved Solids	milligrams per litre	Fortnightly	2	1830	1855	1880	
DECEMBER 2018	15/01/2019	Total Organic Carbon	milligrams per litre	Fortnightly	2	5	7	9	-
DECEMBER 2018	15/01/2019	TSS	milligrams per litre	Fortnightly	2	5	17.5	30	
DECEMBER 2018	15/01/2019	Vanadium	milligrams per litre	Fortnightly	2	0.01	0.01	0.01	-
DECEMBER 2018	15/01/2019	Zinc	milligrams per litre	Fortnightly	2	0.007	0.007	0.007	
Comments									

## Discharge & Monitoring Point 14

Discharge to waters <301204 East 6416350 North> Update

The skimmer dam overflow spillway, located at the left abutment of the skimmer dam.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	Arsenic	milligrams per litre	Weekly	4	0.052	0.0595	0.067	-
DECEMBER 2018	15/01/2019	Boron	milligrams per litre	Weekly	4	1.74	1.85	1.95	
DECEMBER 2018	15/01/2019	Cadmium	milligrams per litre	Weekly	4	<0.0001	<0.0001	0.0001	-
DECEMBER 2018	15/01/2019	Chromium	milligrams per litre	Weekly	4	<0.01	0.005	<0.01	-
DECEMBER 2018	15/01/2019	Chromium (total)	milligrams per litre	Weekly	4	0.001	0.00225	0.003	

# Monthly Data Summary

DECEMBER 2018	15/01/2019	Conductivity	uS/cm	Weekly	4	2820.0	2937.5	3060.0	
DECEMBER 2018	15/01/2019	Copper	milligrams per litre	Weekly	4	<0.001	<0.001	0.002	-
DECEMBER 2018	15/01/2019	Flouride	milligrams per litre	Weekly	4	2.3	2.475	2.6	
DECEMBER 2018	15/01/2019	Lead	milligrams per litre	Weekly	4	<0.001	<0.001	<0.001	-
DECEMBER 2018	15/01/2019	Mercury	milligrams per litre	Weekly	4	<0.0001	<0.0001	<0.0001	-
DECEMBER 2018	15/01/2019	Oil and Grease	milligrams per litre	Weekly	4	<5	<5	<5	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2018	15/01/2019	pH	pH Units	Weekly	4	7.9	8.2	8.4	-
DECEMBER 2018	15/01/2019	Selenium	milligrams per litre	Weekly	4	0.03	0.0375	0.04	-
DECEMBER 2018	15/01/2019	TSS	milligrams per litre	Weekly	4	3	5.5	8	
DECEMBER 2018	15/01/2019	Zinc	milligrams per litre	Weekly	4	<0.005	0.004	0.008	
Comments									

# Monthly Data Summary

## Details of Non-Compliance with Licence

Licence condition number not complied with
Condition O3
Summary of particulars of the non-compliance <b>(NO MORE THAN 50 WORDS)</b>
Fugitive dust was sighted blowing from the Liddell Ash Dam in a south-easterly direction
If required, further details on particulars of non-compliance
-
Date(s) when the non-compliance occurred, if applicable
2-Dec-18
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
N/A
Cause of non-compliance
High winds mobilised flyash from a small section of the Ash Dam. At the time of the event hot winds with speeds greater than 65km/hr were recorded at Liddell Power Station.
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
Water was applied to the area.
Action taken or that will be taken to prevent a recurrence of the non-compliance
An investigation has been initiated.

# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary



# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary

# Monthly Data Summary