



**AGL UPSTREAM INVESTMENTS PTY LTD
ROSALIND PARK GAS PLANT
Monthly Continuous Air Monitoring Report**

Reporting Period: June 2017

AGL Upstream Investments Pty Ltd
ABN 58 115 063 744
Locked Bag 1837, St Leonards NSW 2065
200 George Street, Sydney NSW 2000
Telephone: 02 9921 2999 Facsimile: 02 9921 2474
Complaints Line (24 hours): 1300 799 716



Foreword

| | |
|---------------------------|--|
| PREMISES | Rosalind Park Gas Plant Lot 35 Medhurst Road GILEAD NSW 2560 |
| LICENCE DETAILS | <u>Environment Protection Licence 12003</u> |
| LICENCEE | AGL Upstream Investments Pty Limited |
| LICENCEE'S ADDRESS | Locked Bag 1837, North Sydney, NSW 2060 |
| REPORTING PERIOD | 01 June 2017 to 30 June 2017 |
| DATE of MONITORING | Continuous |
| OBTAINED DATA DATE | 05 July 2017 |
| REPORT DATE | 19 July 2017 |
| REPORT PREPARED BY | Aaron Clifton Environment Business Partner |

SUMMARY OF ACTIVITY

Rosalind Park Gas Plant, located approximately 60km south west of Sydney, is a natural gas processing and treatment plant, used to process coal seam natural gas from the Camden Gas Project.

Produced natural gas is cleaned, dehydrated, compressed and odourised before being measured and transported by pipeline about 500 metres into the nearby Moomba to Sydney Natural Gas Pipeline. The premises are covered by Environment Protection Licence 12003 which includes all gas wells, gas gathering, reticulation systems, trunk lines and associated effluent storage areas and work areas of the Camden Gas Project.



This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of the Environment Protection Licence. The Licence conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.

This report sets out the results of continuous monitoring summarized on a monthly basis. A separate report is issued for quarterly monitoring.

This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, October, 2013) (**Publication Requirements**).

AIR MONITORING LOCATIONS

| Point | Location | Monitoring Frequency |
|-------|---|----------------------|
| 1 | Exhaust Stack 1 on Compression Engine 1 | Continuous |
| 2 | Exhaust Stack 2 on Compression Engine 2 | Continuous |
| 3 | Exhaust Stack 3 on Compression Engine 3 | Continuous |

Note: monitoring is only undertaken when the compression engines are running.

AIR MONITORING TEST METHODS – POINTS 1, 2 and 3

| Parameter | NSW EPA Test Method (Sampling Method) | Reference Method |
|----------------------|---------------------------------------|-----------------------------------|
| Oxides of Nitrogen | CEM-2 | USEPA Performance Specification 2 |
| Temperature | TM-2 | USEPA Method 2 |
| Moisture content | Method approved by EPA in writing | Calibration by reference to TM-22 |
| Volumetric Flow Rate | CEM-6 | USEPA Performance Specification 6 |
| Oxygen | CEM-3 | USEPA Performance Specification 3 |

USEPA Method refers to the US Environmental Protection Agency 2000, Code of Federal Regulations, Title 40, Part 60, Appendix A Methods.

USEPA Performance Specification refers to the US Environmental Protection Agency 2000, Code of Federal Regulations, Title 40, Part 60, Appendix B, Performance Specifications.

Air Monitoring Results

Continuous monitoring results are based on test results obtained over a one-hour averaging period as set out in Schedule 5 of the *Protection of the Environment Operations (Clean Air) Regulation 2010 (NSW)*.

| Monitoring Point | Description | Pollutant | Units of measure | Oxygen correction | Sampling method | Monitoring frequency required by licence | Number of times measured during sampling period | Minimum value | Average value | Maximum value | Concentration Limit |
|------------------|---------------------|--|----------------------------|-------------------|------------------------|--|--|---------------|---------------|---------------|---------------------|
| 1 | Compressor Engine 1 | Oxides of Nitrogen (as NO ₂ equivalent) | Milligrams per cubic metre | 7% oxygen | CEM-2 | Continuous | Compressor Engine 1 operated from 01-30 June 2017. | See Note 1 | See Note 1 | See Note 1 | 461 |
| | | Temperature | Degrees Celsius | | TM-2 | Continuous | See Note 1 | See Note 1 | See Note 1 | See Note 1 | Not applicable |
| | | Moisture | Percent | | Method approved by EPA | Continuous | | See Note 1 | See Note 1 | See Note 1 | Not applicable |
| | | Volumetric flow rate | Cubic metres per second | | CEM-6 | Continuous | | See Note 1 | See Note 1 | See Note 1 | Not applicable |
| | | Oxygen | Percent | | CEM-3 | Continuous | | See Note 1 | See Note 1 | See Note 1 | Not applicable |
| 2 | Compressor Engine 2 | Oxides of Nitrogen (as NO ₂ equivalent) | Milligrams per cubic metre | 7% oxygen | CEM-2 | Continuous | Compressor Engine 2 occasionally operated between 1-2, 6, 26-28 June 2017. | 26.86 | 170.58 | 253.62 | 461 |
| | | Temperature | Degrees Celsius | | TM-2 | Continuous | See Note 2. | 342.58 | 403.20 | 494.42 | Not applicable |
| | | Moisture | Percent | | Method approved by EPA | Continuous | | See Note 2 | See Note 2 | See Note 2 | Not applicable |
| | | Volumetric flow rate | Cubic metres per second | | CEM-6 | Continuous | | See Note 2 | See Note 2 | See Note 2 | Not applicable |
| | | Oxygen | Percent | | CEM-3 | Continuous | | 0.93 | 2.04 | 3.39 | Not applicable |
| 3 | Compressor Engine 3 | Oxides of Nitrogen (as NO ₂ equivalent) | Milligrams per cubic metre | 7% oxygen | CEM-2 | Continuous | Compressor Engine 3 occasionally operated between 1-26, 28-30 June 2017. | 5.61 | 25.59 | 183.05 | 461 |
| | | Temperature | Degrees Celsius | | TM-2 | Continuous | See Note 3. | 298.43 | 382.03 | 518.21 | Not applicable |
| | | Moisture | Percent | | Method approved by EPA | Continuous | | See Note 3 | See Note 3 | See Note 3 | Not applicable |
| | | Volumetric flow rate | Cubic metres per second | | CEM-6 | Continuous | | See Note 3 | See Note 3 | See Note 3 | Not applicable |
| | | Oxygen | Percent | | CEM-3 | Continuous | | 0.81 | 2.05 | 3.33 | Not applicable |



Notes:

1. The following data points have not yet been included for Monitoring Point 1 (Compressor #1 exhaust stack).

| Date | Approximate total hours | Pollutant | Justification |
|-----------------|--------------------------------|---|---|
| 01-30 June 2017 | 720 | Oxides of Nitrogen, Moisture, Oxygen, Temperature, Volumetric Flow Rate | Data unable to be reported to date as AGL is waiting on external contractors to issue updated monitoring results. |

2. The CEMS of Compressor Engine 2 was operating for 45 minutes of every one hour period. The remaining 15 minute period was down time for cleaning purposes.

In accordance with Section 3.4.1 of the EPA Publication Requirements, the following data points have not been included for Monitoring Point 2 (Compressor #2 exhaust stack) as AGL knows that the data has been unable to be collected or is incorrect.

| Date | Approximate total hours | Pollutant | Justification |
|-------------------------|--------------------------------|---|---|
| 1-2, 6, 26-28 June 2017 | 658 | Volumetric Flow Rate, Moisture | Data unable to be collected due to component failure. AGL has been unable to repair the failed component and is trialing alternative monitoring methods in consultation with the EPA. |
| 27 and 28 June 2017 | 2 | Oxides of Nitrogen, Oxygen, Temperature | Data unable to be collected due to component failure. AGL was able to repair the failed component. |



3. The CEMS of Compressor Engine 3 was operating for 45 minutes of every one hour period. The remaining 15 minute period was down time for cleaning purposes.

In accordance with Section 3.4.1 of the EPA Publication Requirements, the following data points have not been included for Monitoring Point 3 (Compressor #3 exhaust stack) as AGL knows that the data has been unable to be collected or is incorrect.

| Date | Approximate total hours | Pollutant | Justification |
|--------------------------|--------------------------------|-----------------------------------|---|
| 1-26, 28-30 June 2017 | 673 | Volumetric Flow Rate, Moisture | Data unable to be collected due to component failure. AGL has been unable to repair the failed component and is trialing alternative monitoring methods in consultation with the EPA. |