

# Monthly Data Summary

## LIDDELL MONTHLY DATA SUMMARY SEPTEMBER 2018

LICENCE NO	2122
LICENCE HOLDER	AGL MACQUARIE
REPORTING PERIOD	SEPTEMBER 2018

### A1 Licence Holder

Licence Number 2122  
Licence Holder AGL MACQUARIE  
Trading Name (if applicable)  
ABN 18 167 859 494

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION  
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generating Works  
Coal Works

### A4 Other Activities (if applicable)

Helicopter-related facilities  
Chemical storage  
Operation of Emergency 1.5 MW diesel generator  
Operation of Gas turbine  
Sewage treatment  
Waste storage

### A5 Fee-Based Activity Classifications

Note that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Coal works	> 5,000,000.00	T handled
Generation of electrical power from coal	> 4,000.00	Gwh generated

# Monthly Data Summary

## Discharge & Monitoring Point 7

301204 East 6416350 North

### Discharge to Air

In the flue gases of unit 1boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	307.4	653.9	795.7	1500 mg/m <sup>3</sup>
SEPTEMBER 2018	15/10/2018		parts per million				149.7	318.6	387.7	700 ppm
SEPTEMBER 2018	15/10/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	655.1	918.9	1181.0	
SEPTEMBER 2018	15/10/2018		parts per million				229.2	321.5	413.2	600 ppm
SEPTEMBER 2018	15/10/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	0.7	2.2	7.1	20%
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Jul-17	5/09/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Jul-17	5/09/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Jul-17	5/09/2017	Copper	milligrams per cubic metre	1	1	0.0029	
Jul-17	5/09/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.014	5
Jul-17	5/09/2017	Hydrogen chloride	milligrams per cubic metre	1	1	5.7	100
Jul-17	5/09/2017	Mercury	milligrams per cubic metre	1	1	0.00140	1.0
Jul-17	5/09/2017	Nitrogen oxides	milligrams per cubic metre	1	1	660	1500
Jul-17	5/09/2017	Solid particles	milligrams per cubic metre	1	1	24.0	100
Jul-17	5/09/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.100	100
Jul-17	5/09/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1100	
Jul-17	5/09/2017	Total fluoride	milligrams per cubic metre	1	1	3.9	50
Jul-17	5/09/2017	Volatile organic compounds	milligrams per cubic metre	1	1	0.012	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	393	628	802	1500 mg/m <sup>3</sup>
SEPTEMBER 2018	15/10/2018		parts per million				192	306	391	700 ppm
SEPTEMBER 2018	15/10/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	654	857	1090	
SEPTEMBER 2018	15/10/2018		parts per million				229	300	381	600 ppm
SEPTEMBER 2018	15/10/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	2.7	4.9	14.7	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Mar-18	12/04/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Mar-18	12/04/2018	Chlorine	milligrams per cubic metre	1	1	<0.007	200
Mar-18	12/04/2018	Copper	milligrams per cubic metre	1	1	0.0040	
Mar-18	12/04/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.019	5
Mar-18	12/04/2018	Hydrogen chloride	milligrams per cubic metre	1	1	8.7	100
Mar-18	12/04/2018	Mercury	milligrams per cubic metre	1	1	<0.00080	1.0
Mar-18	12/04/2018	Nitrogen oxides	milligrams per cubic metre	1	1	550	1500
Mar-18	12/04/2018	Solid particles	milligrams per cubic metre	1	1	37.0	100
Mar-18	12/04/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.880	100
Mar-18	12/04/2018	Sulphur dioxide	milligrams per cubic metre	1	1	900	
Mar-18	12/04/2018	Total fluoride	milligrams per cubic metre	1	1	8.2	50
Mar-18	12/04/2018	Volatile organic compounds	milligrams per cubic metre	1	1	0.940	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour					1500 mg/m <sup>3</sup>
SEPTEMBER 2018	15/10/2018		parts per million							700 ppm
SEPTEMBER 2018	15/10/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour					
SEPTEMBER 2018	15/10/2018		parts per million							600 ppm
SEPTEMBER 2018	15/10/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour					20%
Comments:	Unit was out of service for the entire monitoring period									

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	1/12/2017	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-17	1/12/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-17	1/12/2017	Copper	milligrams per cubic metre	1	1	0.0037	
Oct-17	1/12/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.02	5
Oct-17	1/12/2017	Hydrogen chloride	milligrams per cubic metre	1	1	20.0	100
Oct-17	1/12/2017	Mercury	milligrams per cubic metre	1	1	0.00051	1.0
Oct-17	1/12/2017	Nitrogen oxides	milligrams per cubic metre	1	1	770	1500
Oct-17	1/12/2017	Solid particles	milligrams per cubic metre	1	1	42.0	100
Oct-17	1/12/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.700	100
Oct-17	1/12/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1300	
Oct-17	1/12/2017	Total fluoride	milligrams per cubic metre	1	1	9.8	50
Oct-17	1/12/2017	Volatile organic compounds	milligrams per cubic metre	1	1	<0.02	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	425.8	569.2	710.3	1500 mg/m <sup>3</sup>
SEPTEMBER 2018	15/10/2018		parts per million				207.5	277.3	346.1	700 ppm
SEPTEMBER 2018	15/10/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	712.6	910.5	1145.1	
SEPTEMBER 2018	15/10/2018		parts per million				249.3	318.6	400.6	600 ppm
SEPTEMBER 2018	15/10/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	3.4	7.8	16.3	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Dec-17	15/01/2018	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Dec-17	15/01/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Dec-17	15/01/2018	Copper	milligrams per cubic metre	1	1	0.0058	
Dec-17	15/01/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.015	5
Dec-17	15/01/2018	Hydrogen chloride	milligrams per cubic metre	1	1	6.6	100
Dec-17	15/01/2018	Mercury	milligrams per cubic metre	1	1	0.00190	1.0
Dec-17	15/01/2018	Nitrogen oxides	milligrams per cubic metre	1	1	845	1500
Dec-17	15/01/2018	Solid particles	milligrams per cubic metre	1	1	24.0	100
Dec-17	15/01/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	5.500	100
Dec-17	15/01/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1000	
Dec-17	15/01/2018	Total fluoride	milligrams per cubic metre	1	1	3.2	50
Dec-17	15/01/2018	Volatile organic compounds	milligrams per cubic metre	1	1	<0.07	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 12

Discharge to waters <301204 East 6416350 North> Update

Liddell Outfall Canal

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Ammonia	milligrams per litre	Fortnightly	2	0.02	0.045	0.07	-
SEPTEMBER 2018	15/10/2018	Antimony	milligrams per litre	Fortnightly	2	0.009	0.0095	0.01	
SEPTEMBER 2018	15/10/2018	Arsenic	milligrams per litre	Fortnightly	2	0.006	0.0065	0.007	-
SEPTEMBER 2018	15/10/2018	Barium	milligrams per litre	Fortnightly	2	0.103	0.1065	0.11	
SEPTEMBER 2018	15/10/2018	Beryllium	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
SEPTEMBER 2018	15/10/2018	Boron	milligrams per litre	Fortnightly	2	1.19	1.2	1.21	
SEPTEMBER 2018	15/10/2018	Cadmium	milligrams per litre	Fortnightly	2	<0.0001	0.00005	<0.0001	-
SEPTEMBER 2018	15/10/2018	Chlorine	milligrams per litre	Fortnightly	2	0	0.065	0.13	
SEPTEMBER 2018	15/10/2018	Chromium	milligrams per litre	Fortnightly	2	<0.01	0.005	<0.01	-
SEPTEMBER 2018	15/10/2018	Chromium (total)	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	
SEPTEMBER 2018	15/10/2018	Cobalt	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
SEPTEMBER 2018	15/10/2018	Conductivity	uS/cm	Fortnightly	2	2590.0	2665.0	2740.0	
SEPTEMBER 2018	15/10/2018	Copper	milligrams per litre	Fortnightly	2	0.004	0.0045	0.005	-
SEPTEMBER 2018	15/10/2018	Flouride	milligrams per litre	Fortnightly	2	1.64	1.66	1.68	
SEPTEMBER 2018	15/10/2018	Lead	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
SEPTEMBER 2018	15/10/2018	Manganese	milligrams per litre	Fortnightly	2	0.008	0.0085	0.009	
SEPTEMBER 2018	15/10/2018	Mercury	milligrams per litre	Fortnightly	2	<0.0001	0.00005	<0.0001	-
SEPTEMBER 2018	15/10/2018	Methylene Blue Active Substance	milligrams per litre	Fortnightly	2	<0.1	0.05	<0.1	
SEPTEMBER 2018	15/10/2018	Molybdenum	milligrams per litre	Fortnightly	2	0.119	0.1235	0.128	-

# Monthly Data Summary

SEPTEMBER 2018	15/10/2018	Nickel	milligrams per litre	Fortnightly	2	0.005	0.0055	0.006	
SEPTEMBER 2018	15/10/2018	Nitrogen (total)	milligrams per litre	Fortnightly	2	0.3	0.5	0.7	-
SEPTEMBER 2018	15/10/2018	Oil and Grease	milligrams per litre	Weekly	4	<5	2.5	<5	
SEPTEMBER 2018	15/10/2018	pH	pH Units	Daily	30	8.1	8.4	8.5	-
SEPTEMBER 2018	15/10/2018	Phosphorus	milligrams per litre	Fortnightly	2	0.01	0.015	0.02	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Selenium	milligrams per litre	Fortnightly	2	<0.01	0.005	<0.01	-
SEPTEMBER 2018	15/10/2018	Sulfur	milligrams per litre	Fortnightly	2	580	608	636	
SEPTEMBER 2018	15/10/2018	Temperature	milligrams per litre	Fortnightly	2	23.6	23.75	23.9	
SEPTEMBER 2018	15/10/2018	Tin	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
SEPTEMBER 2018	15/10/2018	Total Dissolved Solids	milligrams per litre	Fortnightly	2	1500	1530	1560	
SEPTEMBER 2018	15/10/2018	Total Organic Carbon	milligrams per litre	Fortnightly	2	6	6.5	7	-
SEPTEMBER 2018	15/10/2018	TSS	milligrams per litre	Fortnightly	2	1	2	3	
SEPTEMBER 2018	15/10/2018	Vanadium	milligrams per litre	Fortnightly	2	0.01	0.01	0.01	-
SEPTEMBER 2018	15/10/2018	Zinc	milligrams per litre	Fortnightly	2	<0.005	0.0025	<0.005	
Comments									

# Monthly Data Summary

Comments																		
<b>Discharge &amp; Monitoring Point 13</b>																		
Discharge to waters <301204 East 6416350 North> Update																		
Liddell Oil and Grit Trap																		
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit									
SEPTEMBER 2018	15/10/2018	Ammonia	milligrams per litre	Fortnightly	2	0.03	0.055	0.08	-									
SEPTEMBER 2018	15/10/2018	Antimony	milligrams per litre	Fortnightly	2	0.009	0.0095	0.01										
SEPTEMBER 2018	15/10/2018	Arsenic	milligrams per litre	Fortnightly	2	0.006	0.0065	0.007	-									
SEPTEMBER 2018	15/10/2018	Barium	milligrams per litre	Fortnightly	2	0.1	0.1015	0.103										
SEPTEMBER 2018	15/10/2018	Beryllium	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-									
SEPTEMBER 2018	15/10/2018	Boron	milligrams per litre	Fortnightly	2	1.14	1.19	1.24										
SEPTEMBER 2018	15/10/2018	Cadmium	milligrams per litre	Fortnightly	2	<0.0001	0.00005	<0.0001	-									
SEPTEMBER 2018	15/10/2018	Chlorine	milligrams per litre	Fortnightly	2	0.04	0.065	0.09										
SEPTEMBER 2018	15/10/2018	Chromium	milligrams per litre	Fortnightly	2	<0.01	0.005	<0.01	-									
SEPTEMBER 2018	15/10/2018	Chromium (total)	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001										
SEPTEMBER 2018	15/10/2018	Cobalt	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-									
SEPTEMBER 2018	15/10/2018	Conductivity	uS/cm	Fortnightly	2	2450.0	2525.0	2600.0										
SEPTEMBER 2018	15/10/2018	Copper	milligrams per litre	Fortnightly	2	0.005	0.005	0.005	-									
SEPTEMBER 2018	15/10/2018	Flouride	milligrams per litre	Fortnightly	2	1.52	1.77	2.02										
SEPTEMBER 2018	15/10/2018	Lead	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-									
SEPTEMBER 2018	15/10/2018	Manganese	milligrams per litre	Fortnightly	2	0.01	0.01	0.01										
SEPTEMBER 2018	15/10/2018	Mercury	milligrams per litre	Fortnightly	2	<0.0001	0.00005	<0.0001	-									
SEPTEMBER 2018	15/10/2018	Methylene Blue Active Substance	milligrams per litre	Fortnightly	2	<0.1	0.05	<0.1										
SEPTEMBER 2018	15/10/2018	Molybdenum	milligrams per litre	Fortnightly	2	0.113	0.1155	0.118	-									
SEPTEMBER 2018	15/10/2018	Nickel	milligrams per litre	Fortnightly	2	0.006	0.006	0.006										

# Monthly Data Summary

SEPTEMBER 2018	15/10/2018	Nitrogen (total)	milligrams per litre	Fortnightly	2	0.3	0.35	0.4	-
SEPTEMBER 2018	15/10/2018	Oil and Grease	milligrams per litre	Weekly	4	<5	2.5	<5	
SEPTEMBER 2018	15/10/2018	pH	pH Units	Daily	30	7	8.31	8.6	-
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Phosphorus	milligrams per litre	Fortnightly	2	0.01	0.015	0.02	
SEPTEMBER 2018	15/10/2018	Selenium	milligrams per litre	Fortnightly	2	<0.01	0.005	<0.01	-
SEPTEMBER 2018	15/10/2018	Sulfur	milligrams per litre	Fortnightly	2	528	547.5	567	
SEPTEMBER 2018	15/10/2018	Temperature	milligrams per litre	Fortnightly	2	18.1	18.4	18.7	
SEPTEMBER 2018	15/10/2018	Tin	milligrams per litre	Fortnightly	2	<0.001	0.0005	<0.001	-
SEPTEMBER 2018	15/10/2018	Total Dissolved Solids	milligrams per litre	Fortnightly	2	1640	1680	1720	
SEPTEMBER 2018	15/10/2018	Total Organic Carbon	milligrams per litre	Fortnightly	2	6	6.5	7	-
SEPTEMBER 2018	15/10/2018	TSS	milligrams per litre	Fortnightly	2	5	6	7	
SEPTEMBER 2018	15/10/2018	Vanadium	milligrams per litre	Fortnightly	2	0.01	0.01	0.01	-
SEPTEMBER 2018	15/10/2018	Zinc	milligrams per litre	Fortnightly	2	<0.005	0.0025	<0.005	
Comments									

## Discharge & Monitoring Point 14

Discharge to waters <301204 East 6416350 North> Update

The skimmer dam overflow spillway, located at the left abutment of the skimmer dam.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	Arsenic	milligrams per litre	Weekly	4	0.056	0.065	0.083	-
SEPTEMBER 2018	15/10/2018	Boron	milligrams per litre	Weekly	4	0.34	1.3475	1.82	
SEPTEMBER 2018	15/10/2018	Cadmium	milligrams per litre	Weekly	4	<0.0001	0.00005	<0.0001	-
SEPTEMBER 2018	15/10/2018	Chromium	milligrams per litre	Weekly	4	0.002	0.0025	0.003	-
SEPTEMBER 2018	15/10/2018	Chromium (total)	milligrams per litre	Weekly	4	<0.01	0.005	<0.01	

# Monthly Data Summary

SEPTEMBER 2018	15/10/2018	Conductivity	uS/cm	Weekly	4	2650.0	2695.0	2800.0	
SEPTEMBER 2018	15/10/2018	Copper	milligrams per litre	Weekly	4	<0.001	0.002375	0.004	-
SEPTEMBER 2018	15/10/2018	Flouride	milligrams per litre	Weekly	4	2.3	2.425	2.6	
SEPTEMBER 2018	15/10/2018	Lead	milligrams per litre	Weekly	4	<0.001	0.0005	<0.001	-
SEPTEMBER 2018	15/10/2018	Mercury	milligrams per litre	Weekly	4	<0.0001	0.00005	<0.0001	-
SEPTEMBER 2018	15/10/2018	Oil and Grease	milligrams per litre	Weekly	4	<5	2.5	<5	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
SEPTEMBER 2018	15/10/2018	pH	pH Units	Weekly	4	8.2	8.3	8.4	-
SEPTEMBER 2018	15/10/2018	Selenium	milligrams per litre	Weekly	4	0.04	0.0525	0.07	-
SEPTEMBER 2018	15/10/2018	TSS	milligrams per litre	Weekly	4	<1	2.125	4	
SEPTEMBER 2018	15/10/2018	Zinc	milligrams per litre	Weekly	4	<0.005	0.004875	0.012	
Comments									

# Monthly Data Summary

## Details of Non-Compliance with Licence

Licence condition number not complied with

N/A

Summary of particulars of the non-compliance (**NO MORE THAN 50 WORDS**)

If required, further details on particulars of non-compliance

-

Date(s) when the non-compliance occurred, if applicable

If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance

Cause of non-compliance

Action taken or that will be taken to mitigate any adverse effects of the non-compliance

Action taken or that will be taken to prevent a recurrence of the non-compliance