

# Monthly Data Summary

## LIDDELL MONTHLY DATA SUMMARY OCTOBER 2018

LICENCE NO	2122
LICENCE HOLDER	AGL MACQUARIE
REPORTING PERIOD	OCTOBER 2018

### A1 Licence Holder

Licence Number 2122  
 Licence Holder AGL MACQUARIE  
 Trading Name (if applicable)  
 ABN 18 167 859 494

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION  
 Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generating Works  
 Coal Works

### A4 Other Activities (if applicable)

Helicopter-related facilities  
 Chemical storage  
 Operation of Emergency 1.5 MW diesel generator  
 Operation of Gas turbine  
 Sewage treatment  
 Waste storage

### A5 Fee-Based Activity Classifications

Note that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Coal works	> 5,000,000.00	T handled
Generation of electrical power from coal	> 4,000.00	Gwh generated

# Monthly Data Summary

## Discharge & Monitoring Point 7

301204 East 6416350 North

### Discharge to Air

In the flue gases of unit 1boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	529.9	664.6	843.3	1500 mg/m <sup>3</sup>
OCTOBER 2018	15/11/2018		parts per million				258.2	323.8	410.9	700 ppm
OCTOBER 2018	15/11/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	686.9	898.1	1277.1	
OCTOBER 2018	15/11/2018		parts per million				240.3	314.2	446.9	600 ppm
OCTOBER 2018	15/11/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	1.1	2.6	11.0	20%
<b>Comments:</b>										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>			
Jul-17	5/09/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0			
Jul-17	5/09/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200			
Jul-17	5/09/2017	Copper	milligrams per cubic metre	1	1	0.0029				
Jul-17	5/09/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.014	5			
Jul-17	5/09/2017	Hydrogen chloride	milligrams per cubic metre	1	1	5.7	100			
Jul-17	5/09/2017	Mercury	milligrams per cubic metre	1	1	0.00140	1.0			
Jul-17	5/09/2017	Nitrogen oxides	milligrams per cubic metre	1	1	660	1500			
Jul-17	5/09/2017	Solid particles	milligrams per cubic metre	1	1	24.0	100			
Jul-17	5/09/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.100	100			
Jul-17	5/09/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1100				
Jul-17	5/09/2017	Total fluoride	milligrams per cubic metre	1	1	3.9	50			
Jul-17	5/09/2017	Volatile organic compounds	milligrams per cubic metre	1	1	0.012				
<b>Comments:</b>										
Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.										

# Monthly Data Summary

## Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	298	551	670	1500 mg/m <sup>3</sup>
OCTOBER 2018	15/11/2018		parts per million				145	268	327	700 ppm
OCTOBER 2018	15/11/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	672	902	1206	
OCTOBER 2018	15/11/2018		parts per million				235	316	422	600 ppm
OCTOBER 2018	15/11/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	3.2	5.3	8.4	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Mar-18	12/04/2018	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Mar-18	12/04/2018	Chlorine	milligrams per cubic metre	1	1	<0.007	200
Mar-18	12/04/2018	Copper	milligrams per cubic metre	1	1	0.0040	
Mar-18	12/04/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.019	5
Mar-18	12/04/2018	Hydrogen chloride	milligrams per cubic metre	1	1	8.7	100
Mar-18	12/04/2018	Mercury	milligrams per cubic metre	1	1	<0.00080	1.0
Mar-18	12/04/2018	Nitrogen oxides	milligrams per cubic metre	1	1	550	1500
Mar-18	12/04/2018	Solid particles	milligrams per cubic metre	1	1	37.0	100
Mar-18	12/04/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.880	100
Mar-18	12/04/2018	Sulphur dioxide	milligrams per cubic metre	1	1	900	
Mar-18	12/04/2018	Total fluoride	milligrams per cubic metre	1	1	8.2	50
Mar-18	12/04/2018	Volatile organic compounds	milligrams per cubic metre	1	1	0.940	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	-	-	-	-	1500 mg/m <sup>3</sup>
OCTOBER 2018	15/11/2018		parts per million				-	-	-	700 ppm
OCTOBER 2018	15/11/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	-	-	-	-	
OCTOBER 2018	15/11/2018		parts per million				-	-	-	600 ppm
OCTOBER 2018	15/11/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	-	-	-	-	20%
Comments:	Unit was out of service during October									

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	1/12/2017	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Oct-17	1/12/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-17	1/12/2017	Copper	milligrams per cubic metre	1	1	0.0037	
Oct-17	1/12/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.02	5
Oct-17	1/12/2017	Hydrogen chloride	milligrams per cubic metre	1	1	20.0	100
Oct-17	1/12/2017	Mercury	milligrams per cubic metre	1	1	0.00051	1.0
Oct-17	1/12/2017	Nitrogen oxides	milligrams per cubic metre	1	1	770	1500
Oct-17	1/12/2017	Solid particles	milligrams per cubic metre	1	1	42.0	100
Oct-17	1/12/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.700	100
Oct-17	1/12/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1300	
Oct-17	1/12/2017	Total fluoride	milligrams per cubic metre	1	1	9.8	50
Oct-17	1/12/2017	Volatile organic compounds	milligrams per cubic metre	1	1	<0.02	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	443.1	559.9	727.3	1500 mg/m <sup>3</sup>
OCTOBER 2018	15/11/2018		parts per million				215.9	272.8	354.4	700 ppm
OCTOBER 2018	15/11/2018	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	666.6	874.7	1145.6	
OCTOBER 2018	15/11/2018		parts per million				233.2	306.0	400.8	600 ppm
OCTOBER 2018	15/11/2018	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	3.6	6.9	12.8	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Dec-17	15/01/2018	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0
Dec-17	15/01/2018	Chlorine	milligrams per cubic metre	1	1	0.0	200
Dec-17	15/01/2018	Copper	milligrams per cubic metre	1	1	0.0058	
Dec-17	15/01/2018	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.015	5
Dec-17	15/01/2018	Hydrogen chloride	milligrams per cubic metre	1	1	6.6	100
Dec-17	15/01/2018	Mercury	milligrams per cubic metre	1	1	0.00190	1.0
Dec-17	15/01/2018	Nitrogen oxides	milligrams per cubic metre	1	1	845	1500
Dec-17	15/01/2018	Solid particles	milligrams per cubic metre	1	1	24.0	100
Dec-17	15/01/2018	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	5.500	100
Dec-17	15/01/2018	Sulphur dioxide	milligrams per cubic metre	1	1	1000	
Dec-17	15/01/2018	Total fluoride	milligrams per cubic metre	1	1	3.2	50
Dec-17	15/01/2018	Volatile organic compounds	milligrams per cubic metre	1	1	<0.07	
Comments:	Monitoring of emission from each of the 4 boilers for the substances in this table is required annually.						

# Monthly Data Summary

## Discharge & Monitoring Point 12

Discharge to waters <301204 East 6416350 North> Update

Liddell Outfall Canal

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Ammonia	milligrams per litre	Fortnightly	2	0.02	0.02	0.02	-
OCTOBER 2018	15/11/2018	Antimony	milligrams per litre	Fortnightly	2	0.01	0.012	0.014	
OCTOBER 2018	15/11/2018	Arsenic	milligrams per litre	Fortnightly	2	0.006	0.006	0.006	-
OCTOBER 2018	15/11/2018	Barium	milligrams per litre	Fortnightly	2	0.107	0.108	0.109	
OCTOBER 2018	15/11/2018	Beryllium	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
OCTOBER 2018	15/11/2018	Boron	milligrams per litre	Fortnightly	2	1.22	1.23	1.24	
OCTOBER 2018	15/11/2018	Cadmium	milligrams per litre	Fortnightly	2	<0.0001	<0.0001	<0.0001	-
OCTOBER 2018	15/11/2018	Chlorine	milligrams per litre	Fortnightly	2	0	0.04	0.08	
OCTOBER 2018	15/11/2018	Chromium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
OCTOBER 2018	15/11/2018	Chromium (total)	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	
OCTOBER 2018	15/11/2018	Cobalt	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
OCTOBER 2018	15/11/2018	Conductivity	uS/cm	Fortnightly	2	2580.0	2660.0	2740.0	
OCTOBER 2018	15/11/2018	Copper	milligrams per litre	Fortnightly	2	0.005	0.005	0.005	-
OCTOBER 2018	15/11/2018	Flouride	milligrams per litre	Fortnightly	2	1.17	1.39	1.61	
OCTOBER 2018	15/11/2018	Lead	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
OCTOBER 2018	15/11/2018	Manganese	milligrams per litre	Fortnightly	2	0.01	0.0115	0.013	
OCTOBER 2018	15/11/2018	Mercury	milligrams per litre	Fortnightly	2	<0.0001	<0.0001	<0.0001	-
OCTOBER 2018	15/11/2018	Methylene Blue Active Substance	milligrams per litre	Fortnightly	2	<0.1	<0.01	<0.1	
OCTOBER 2018	15/11/2018	Molybdenum	milligrams per litre	Fortnightly	2	0.119	0.1205	0.122	-

# Monthly Data Summary

OCTOBER 2018	15/11/2018	Nickel	milligrams per litre	Fortnightly	2	0.006	0.006	0.006	
OCTOBER 2018	15/11/2018	Nitrogen (total)	milligrams per litre	Fortnightly	2	0.4	0.5	0.6	-
OCTOBER 2018	15/11/2018	Oil and Grease	milligrams per litre	Weekly	5	<5	<5	<5	
OCTOBER 2018	15/11/2018	pH	pH Units	Daily	31	8.0	8.3	8.5	-
OCTOBER 2018	15/11/2018	Phosphorus	milligrams per litre	Fortnightly	2	<0.01	0.0125	0.02	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Selenium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
OCTOBER 2018	15/11/2018	Sulfur	milligrams per litre	Fortnightly	2	575	589.5	604	
OCTOBER 2018	15/11/2018	Temperature	milligrams per litre	Fortnightly	2	23.9	25.65	27.4	
OCTOBER 2018	15/11/2018	Tin	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
OCTOBER 2018	15/11/2018	Total Dissolved Solids	milligrams per litre	Fortnightly	2	1800	1835	1870	
OCTOBER 2018	15/11/2018	Total Organic Carbon	milligrams per litre	Fortnightly	2	6	6.5	7	-
OCTOBER 2018	15/11/2018	TSS	milligrams per litre	Fortnightly	2	1	1.5	2	
OCTOBER 2018	15/11/2018	Vanadium	milligrams per litre	Fortnightly	2	0.01	0.01	0.01	-
OCTOBER 2018	15/11/2018	Zinc	milligrams per litre	Fortnightly	2	<0.005	0.00525	0.008	
Comments									

# Monthly Data Summary

Comments																		
<b>Discharge &amp; Monitoring Point 13</b>																		
Discharge to waters <301204 East 6416350 North> Update																		
Liddell Oil and Grit Trap																		
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit									
OCTOBER 2018	15/11/2018	Ammonia	milligrams per litre	Fortnightly	2	0.02	0.03	0.04	-									
OCTOBER 2018	15/11/2018	Antimony	milligrams per litre	Fortnightly	2	0.01	0.0115	0.013										
OCTOBER 2018	15/11/2018	Arsenic	milligrams per litre	Fortnightly	2	0.006	0.0065	0.007	-									
OCTOBER 2018	15/11/2018	Barium	milligrams per litre	Fortnightly	2	0.1	0.104	0.108										
OCTOBER 2018	15/11/2018	Beryllium	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-									
OCTOBER 2018	15/11/2018	Boron	milligrams per litre	Fortnightly	2	1.2	1.22	1.24										
OCTOBER 2018	15/11/2018	Cadmium	milligrams per litre	Fortnightly	2	<0.0001	<0.0001	<0.0001	-									
OCTOBER 2018	15/11/2018	Chlorine	milligrams per litre	Fortnightly	2	0.08	0.085	0.09										
OCTOBER 2018	15/11/2018	Chromium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-									
OCTOBER 2018	15/11/2018	Chromium (total)	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001										
OCTOBER 2018	15/11/2018	Cobalt	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-									
OCTOBER 2018	15/11/2018	Conductivity	uS/cm	Fortnightly	2	2440.0	2525.0	2610.0										
OCTOBER 2018	15/11/2018	Copper	milligrams per litre	Fortnightly	2	0.005	0.0055	0.006	-									
OCTOBER 2018	15/11/2018	Flouride	milligrams per litre	Fortnightly	2	1.3	1.45	1.6										
OCTOBER 2018	15/11/2018	Lead	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-									
OCTOBER 2018	15/11/2018	Manganese	milligrams per litre	Fortnightly	2	0.009	0.0105	0.012										
OCTOBER 2018	15/11/2018	Mercury	milligrams per litre	Fortnightly	2	<0.0001	<0.0001	<0.0001	-									
OCTOBER 2018	15/11/2018	Methylene Blue Active Substance	milligrams per litre	Fortnightly	2	<0.1	<0.1	<0.1										
OCTOBER 2018	15/11/2018	Molybdenum	milligrams per litre	Fortnightly	2	0.116	0.12	0.124	-									
OCTOBER 2018	15/11/2018	Nickel	milligrams per litre	Fortnightly	2	0.005	0.0055	0.006										

# Monthly Data Summary

OCTOBER 2018	15/11/2018	Nitrogen (total)	milligrams per litre	Fortnightly	2	0.5	0.5	0.5	-
OCTOBER 2018	15/11/2018	Oil and Grease	milligrams per litre	Weekly	5	<5	<5	<5	
OCTOBER 2018	15/11/2018	pH	pH Units	Daily	31	7	8.18	8.5	-
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Phosphorus	milligrams per litre	Fortnightly	2	<0.01	0.0175	0.03	
OCTOBER 2018	15/11/2018	Selenium	milligrams per litre	Fortnightly	2	<0.01	<0.01	<0.01	-
OCTOBER 2018	15/11/2018	Sulfur	milligrams per litre	Fortnightly	2	530	535	540	
OCTOBER 2018	15/11/2018	Temperature	milligrams per litre	Fortnightly	2	21.2	21.65	22.1	
OCTOBER 2018	15/11/2018	Tin	milligrams per litre	Fortnightly	2	<0.001	<0.001	<0.001	-
OCTOBER 2018	15/11/2018	Total Dissolved Solids	milligrams per litre	Fortnightly	2	1520	1715	1910	
OCTOBER 2018	15/11/2018	Total Organic Carbon	milligrams per litre	Fortnightly	2	6	6.5	7	-
OCTOBER 2018	15/11/2018	TSS	milligrams per litre	Fortnightly	2	2	2.5	3	
OCTOBER 2018	15/11/2018	Vanadium	milligrams per litre	Fortnightly	2	0.01	0.01	0.01	-
OCTOBER 2018	15/11/2018	Zinc	milligrams per litre	Fortnightly	2	<0.005	<0.005	<0.005	
Comments									

## Discharge & Monitoring Point 14

Discharge to waters <301204 East 6416350 North> Update

The skimmer dam overflow spillway, located at the left abutment of the skimmer dam.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	Arsenic	milligrams per litre	Weekly	5	0.043	0.059	0.09	-
OCTOBER 2018	15/11/2018	Boron	milligrams per litre	Weekly	5	1.84	1.978	2.39	
OCTOBER 2018	15/11/2018	Cadmium	milligrams per litre	Weekly	5	<0.0001	0.0001	0.0001	-
OCTOBER 2018	15/11/2018	Chromium	milligrams per litre	Weekly	5	<0.01	<0.01	<0.01	-
OCTOBER 2018	15/11/2018	Chromium (total)	milligrams per litre	Weekly	5	0.003	0.0042	0.007	

# Monthly Data Summary

OCTOBER 2018	15/11/2018	Conductivity	uS/cm	Weekly	5	2670.0	2704.0	2770.0	
OCTOBER 2018	15/11/2018	Copper	milligrams per litre	Weekly	5	<0.001	0.001	0.002	-
OCTOBER 2018	15/11/2018	Flouride	milligrams per litre	Weekly	5	1.7	2.24	2.5	
OCTOBER 2018	15/11/2018	Lead	milligrams per litre	Weekly	5	<0.001	<0.001	<0.001	-
OCTOBER 2018	15/11/2018	Mercury	milligrams per litre	Weekly	5	<0.0001	<0.0001	<0.0001	-
OCTOBER 2018	15/11/2018	Oil and Grease	milligrams per litre	Weekly	5	<5	<5	<5	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
OCTOBER 2018	15/11/2018	pH	pH Units	Weekly	5	8.2	8.3	8.4	-
OCTOBER 2018	15/11/2018	Selenium	milligrams per litre	Weekly	5	0.02	0.036	0.06	-
OCTOBER 2018	15/11/2018	TSS	milligrams per litre	Weekly	5	2	2.8	3	
OCTOBER 2018	15/11/2018	Zinc	milligrams per litre	Weekly	5	<0.005	<0.005	<0.005	
Comments									

# Monthly Data Summary

## Details of Non-Compliance with Licence

Licence condition number not complied with

N/A

Summary of particulars of the non-compliance (**NO MORE THAN 50 WORDS**)

If required, further details on particulars of non-compliance

-

Date(s) when the non-compliance occurred, if applicable

If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance

Cause of non-compliance

Action taken or that will be taken to mitigate any adverse effects of the non-compliance

Action taken or that will be taken to prevent a recurrence of the non-compliance