

# Monthly Data Summary

## LIDDELL MONTHLY DATA SUMMARY DECEMBER 2019

LICENCE NO	2122
LICENCE HOLDER	AGL MACQUARIE
REPORTING PERIOD	DECEMBER 2019

### A1 Licence Holder

Licence Number 2122  
 Licence Holder AGL MACQUARIE  
 Trading Name (if applicable)  
 ABN 18 167 859 494

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION  
 Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generating Works  
 Coal Works

### A4 Other Activities (if applicable)

Helicopter-related facilities  
 Chemical storage  
 Operation of Emergency 1.5 MW diesel generator  
 Operation of Gas turbine  
 Sewage treatment  
 Waste storage

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Coal works	> 5,000,000.00	T handled
Generation of electrical power from coal	> 4,000.00	Gwh generated

# Monthly Data Summary

## Discharge & Monitoring Point 7

301204 East 6416350 North

### Discharge to Air

In the flue gases of unit 1 boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	296.5	576.7	795.3	1500 mg/m <sup>3</sup>
DECEMBER 2019	15/01/2020		parts per million				144.5	281.0	387.5	700 ppm
DECEMBER 2019	15/01/2020	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	608.7	824.5	1152.5	
DECEMBER 2019	15/01/2020		parts per million				213.0	288.5	403.3	600 ppm
DECEMBER 2019	15/01/2020	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	1.8	4.6	13.1	20%
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>			
Oct-19	25/11/2019	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0			
Oct-19	25/11/2019	Chlorine	milligrams per cubic metre	1	1	0.0	200			
Oct-19	25/11/2019	Copper	milligrams per cubic metre	1	1	0.0017				
Oct-19	25/11/2019	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.012	5			
Oct-19	25/11/2019	Hydrogen chloride	milligrams per cubic metre	1	1	11.0	100			
Oct-19	25/11/2019	Mercury	milligrams per cubic metre	1	1	0.00059	1.0			
Oct-19	25/11/2019	Nitrogen oxides	milligrams per cubic metre	1	1	680	1500			
Oct-19	25/11/2019	Solid particles	milligrams per cubic metre	1	1	13.0	100			
Oct-19	25/11/2019	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	0.950	100			
Oct-19	25/11/2019	Sulphur dioxide	milligrams per cubic metre	1	1	830				
Oct-19	25/11/2019	Total fluoride	milligrams per cubic metre	1	1	7.7	50			
Oct-19	25/11/2019	Volatile organic compounds	milligrams per cubic metre	1	1	0.670				
Comments:		Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 1.								

# Monthly Data Summary

## Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	93.5%	288	553	778	1500 mg/m3
DECEMBER 2019	15/01/2020		parts per million				140	270	379	700 ppm
DECEMBER 2019	15/01/2020	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	93.4%	753	951	1296	
DECEMBER 2019	15/01/2020		parts per million				264	333	453	600 ppm
DECEMBER 2019	15/01/2020	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	2.2	4.3	10.9	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Apr-19	14/05/2019	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Apr-19	14/05/2019	Chlorine	milligrams per cubic metre	1	1	<0.008	200
Apr-19	14/05/2019	Copper	milligrams per cubic metre	1	1	0.0029	
Apr-19	14/05/2019	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.067	5
Apr-19	14/05/2019	Hydrogen chloride	milligrams per cubic metre	1	1	27.0	100
Apr-19	14/05/2019	Mercury	milligrams per cubic metre	1	1	0.00047	1.0
Apr-19	14/05/2019	Nitrogen oxides	milligrams per cubic metre	1	1	800	1500
Apr-19	14/05/2019	Solid particles	milligrams per cubic metre	1	1	30.0	100
Apr-19	14/05/2019	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	11.000	100
Apr-19	14/05/2019	Sulphur dioxide	milligrams per cubic metre	1	1	1200	
Apr-19	14/05/2019	Total fluoride	milligrams per cubic metre	1	1	15.0	50
Apr-19	14/05/2019	Volatile organic compounds	milligrams per cubic metre	1	1	<0.02	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 2.							

# Monthly Data Summary

## Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	469.1	605.2	883.8	1500 mg/m3
DECEMBER 2019	15/01/2020		parts per million				228.6	294.8	430.6	700 ppm
DECEMBER 2019	15/01/2020	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	699.7	901.9	1325.9	
DECEMBER 2019	15/01/2020		parts per million				244.8	315.6	463.9	600 ppm
DECEMBER 2019	15/01/2020	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	1.5	3.0	10.2	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>			
Mar-19	9/05/2019	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0			
Mar-19	9/05/2019	Chlorine	milligrams per cubic metre	1	1	0.1	200			
Mar-19	9/05/2019	Copper	milligrams per cubic metre	1	1	0.0009				
Mar-19	9/05/2019	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.013	5			
Mar-19	9/05/2019	Hydrogen chloride	milligrams per cubic metre	1	1	25.0	100			
Mar-19	9/05/2019	Mercury	milligrams per cubic metre	1	1	0.00043	1.0			
Mar-19	9/05/2019	Nitrogen oxides	milligrams per cubic metre	1	1	690	1500			
Mar-19	9/05/2019	Solid particles	milligrams per cubic metre	1	1	9.7	100			
Mar-19	9/05/2019	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.600	100			
Mar-19	9/05/2019	Sulphur dioxide	milligrams per cubic metre	1	1	1100				
Mar-19	9/05/2019	Total fluoride	milligrams per cubic metre	1	1	13.0	50			
Mar-19	9/05/2019	Volatile organic compounds	milligrams per cubic metre	1	1	<0.02				
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 3.										

# Monthly Data Summary

## Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Nitrogen Oxides	milligrams per cubic metre	Continuous	One hour	>99%	272.8	594.1	793.0	1500 mg/m3
DECEMBER 2019	15/01/2020		parts per million				132.9	289.4	386.3	700 ppm
DECEMBER 2019	15/01/2020	Sulphur dioxide	milligrams per cubic metre	Continuous	One hour	>99%	695.1	911.7	1359.5	
DECEMBER 2019	15/01/2020		parts per million				243.2	319.0	475.7	600 ppm
DECEMBER 2019	15/01/2020	Opacity - Undifferentiated particles	Percent	Continuous	One hour	>99%	5.9	8.1	12.5	20%
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-19	29/10/2019	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Oct-19	29/10/2019	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-19	29/10/2019	Copper	milligrams per cubic metre	1	1	0.0015	
Oct-19	29/10/2019	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.014	5
Oct-19	29/10/2019	Hydrogen chloride	milligrams per cubic metre	1	1	16.0	100
Oct-19	29/10/2019	Mercury	milligrams per cubic metre	1	1	0.00077	1.0
Oct-19	29/10/2019	Nitrogen oxides	milligrams per cubic metre	1	1	790	1500
Oct-19	29/10/2019	Solid particles	milligrams per cubic metre	1	1	41.0	100
Oct-19	29/10/2019	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.700	100
Oct-19	29/10/2019	Sulphur dioxide	milligrams per cubic metre	1	1	950	
Oct-19	29/10/2019	Total fluoride	milligrams per cubic metre	1	1	8.8	50
Oct-19	29/10/2019	Volatile organic compounds	milligrams per cubic metre	1	1	0.089	
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. In most years one boiler is tested each quarter. This table contains the latest results from Boiler 4.							

## Discharge & Monitoring Point 12

Discharge to waters <301204 East 6416350 North> Update

# Monthly Data Summary

Liddell Outfall Canal

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Ammonia	milligrams per litre	Fortnightly	3	<0.01	0.01	0.02	-
DECEMBER 2019	15/01/2020	Antimony	milligrams per litre	Fortnightly	3	0.009	0.009	0.009	
DECEMBER 2019	15/01/2020	Arsenic	milligrams per litre	Fortnightly	3	0.007	0.007333333	0.008	-
DECEMBER 2019	15/01/2020	Barium	milligrams per litre	Fortnightly	3	0.119	0.119333333	0.12	
DECEMBER 2019	15/01/2020	Beryllium	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Boron	milligrams per litre	Fortnightly	3	1.32	1.37	1.4	
DECEMBER 2019	15/01/2020	Cadmium	milligrams per litre	Fortnightly	3	<0.0001	6.66667E-05	0.0001	-
DECEMBER 2019	15/01/2020	Chlorine	milligrams per litre	Fortnightly	3	0.07	0.093333333	0.12	
DECEMBER 2019	15/01/2020	Chromium	milligrams per litre	Fortnightly	3	<0.01	0.005	<0.01	-
DECEMBER 2019	15/01/2020	Chromium (total)	milligrams per litre	Fortnightly	3	<0.001	0.000666667	0.001	
DECEMBER 2019	15/01/2020	Cobalt	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Conductivity	uS/cm	Fortnightly	3	2760.0	2913.3	2990.0	
DECEMBER 2019	15/01/2020	Copper	milligrams per litre	Fortnightly	3	0.003	0.003666667	0.004	-
DECEMBER 2019	15/01/2020	Flouride	milligrams per litre	Fortnightly	3	0.39	1.213333333	1.73	
DECEMBER 2019	15/01/2020	Lead	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Manganese	milligrams per litre	Fortnightly	3	0.01	0.012666667	0.016	
DECEMBER 2019	15/01/2020	Mercury	milligrams per litre	Fortnightly	3	<0.0001	0.00005	<0.0001	-
DECEMBER 2019	15/01/2020	Methylene Blue Active Substance	milligrams per litre	Fortnightly	3	<0.1	0.05	<0.1	
DECEMBER 2019	15/01/2020	Molybdenum	milligrams per litre	Fortnightly	3	0.13	0.131333333	0.134	-
DECEMBER 2019	15/01/2020	Nickel	milligrams per litre	Fortnightly	3	0.004	0.004666667	0.005	
DECEMBER 2019	15/01/2020	Nitrogen (total)	milligrams per litre	Fortnightly	3	0.3	0.366666667	0.4	-
DECEMBER 2019	15/01/2020	Oil and Grease	milligrams per litre	Weekly	5	<5	2.5	<5	
DECEMBER 2019	15/01/2020	pH	pH Units	Daily	31	8.4	8.4	8.6	-
DECEMBER 2019	15/01/2020	Phosphorus	milligrams per litre	Fortnightly	3	0.03	0.036666667	0.05	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Selenium	milligrams per litre	Fortnightly	3	<0.01	0.005	<0.01	-

# Monthly Data Summary

DECEMBER 2019	15/01/2020	Sulfur	milligrams per litre	Fortnightly	3	650	750	830	
DECEMBER 2019	15/01/2020	Temperature	milligrams per litre	Fortnightly	3	27.6	30.3	32.4	
DECEMBER 2019	15/01/2020	Tin	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Total Dissolved Solids	milligrams per litre	Fortnightly	3	1950	2036.666667	2160	
DECEMBER 2019	15/01/2020	Total Organic Carbon	milligrams per litre	Fortnightly	3	8	8	8	-
DECEMBER 2019	15/01/2020	TSS	milligrams per litre	Fortnightly	3	2	3.333333333	5	
DECEMBER 2019	15/01/2020	Vanadium	milligrams per litre	Fortnightly	3	0.01	0.016666667	0.02	-
DECEMBER 2019	15/01/2020	Zinc	milligrams per litre	Fortnightly	3	<0.005	0.0025	<0.005	
Comments									

# Monthly Data Summary

Comments									
<b>Discharge &amp; Monitoring Point 13</b>									
Discharge to waters <301204 East 6416350 North> Update									
Liddell Oil and Grit Trap									
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Ammonia	milligrams per litre	Fortnightly	3	<0.01	0.006666667	0.01	-
DECEMBER 2019	15/01/2020	Antimony	milligrams per litre	Fortnightly	3	0.008	0.008666667	0.009	
DECEMBER 2019	15/01/2020	Arsenic	milligrams per litre	Fortnightly	3	0.006	0.007	0.008	-
DECEMBER 2019	15/01/2020	Barium	milligrams per litre	Fortnightly	3	0.112	0.114333333	0.117	
DECEMBER 2019	15/01/2020	Beryllium	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Boron	milligrams per litre	Fortnightly	3	1.23	1.263333333	1.29	
DECEMBER 2019	15/01/2020	Cadmium	milligrams per litre	Fortnightly	3	<0.0001	0.00005	<0.0001	-
DECEMBER 2019	15/01/2020	Chlorine	milligrams per litre	Fortnightly	3	0.05	0.073333333	0.11	
DECEMBER 2019	15/01/2020	Chromium	milligrams per litre	Fortnightly	3	<0.01	0.005	<0.01	-
DECEMBER 2019	15/01/2020	Chromium (total)	milligrams per litre	Fortnightly	3	<0.001	0.000666667	0.001	
DECEMBER 2019	15/01/2020	Cobalt	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Conductivity	uS/cm	Fortnightly	3	2620.0	2780.0	2870.0	
DECEMBER 2019	15/01/2020	Copper	milligrams per litre	Fortnightly	3	0.003	0.004	0.005	-
DECEMBER 2019	15/01/2020	Flouride	milligrams per litre	Fortnightly	3	1.13	1.353333333	1.52	
DECEMBER 2019	15/01/2020	Lead	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Manganese	milligrams per litre	Fortnightly	3	0.011	0.014666667	0.018	
DECEMBER 2019	15/01/2020	Mercury	milligrams per litre	Fortnightly	3	<0.0001	0.00005	<0.0001	-
DECEMBER 2019	15/01/2020	Methylene Blue Active Substance	milligrams per litre	Fortnightly	3	<0.1	0.05	<0.1	
DECEMBER 2019	15/01/2020	Molybdenum	milligrams per litre	Fortnightly	3	0.119	0.124666667	0.128	-
DECEMBER 2019	15/01/2020	Nickel	milligrams per litre	Fortnightly	3	0.004	0.004333333	0.005	
DECEMBER 2019	15/01/2020	Nitrogen (total)	milligrams per litre	Fortnightly	3	0.3	0.366666667	0.4	-
DECEMBER 2019	15/01/2020	Oil and Grease	milligrams per litre	Weekly	5	<5	2.5	<5	
DECEMBER 2019	15/01/2020	pH	pH Units	Daily	31	8.3	8.5	8.7	-
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit

# Monthly Data Summary

DECEMBER 2019	15/01/2020	Phosphorus	milligrams per litre	Fortnightly	3	0.03	0.04	0.05	
DECEMBER 2019	15/01/2020	Selenium	milligrams per litre	Fortnightly	3	<0.01	0.005	<0.01	-
DECEMBER 2019	15/01/2020	Sulfur	milligrams per litre	Fortnightly	3	500	640	700	
DECEMBER 2019	15/01/2020	Temperature	milligrams per litre	Fortnightly	3	23	25.23333333	26.7	
DECEMBER 2019	15/01/2020	Tin	milligrams per litre	Fortnightly	3	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Total Dissolved Solids	milligrams per litre	Fortnightly	3	1750	1896.666667	2120	
DECEMBER 2019	15/01/2020	Total Organic Carbon	milligrams per litre	Fortnightly	3	7	7.666666667	8	-
DECEMBER 2019	15/01/2020	TSS	milligrams per litre	Fortnightly	3	5	9.666666667	18	
DECEMBER 2019	15/01/2020	Vanadium	milligrams per litre	Fortnightly	3	0.01	0.013333333	0.02	-
DECEMBER 2019	15/01/2020	Zinc	milligrams per litre	Fortnightly	3	<0.005	0.003666667	0.006	
Comments									

## Discharge & Monitoring Point 14

Discharge to waters <301204 East 6416350 North> Update

The skimmer dam overflow spillway, located at the left abutment of the skimmer dam.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	Arsenic	milligrams per litre	Weekly	5	0.026	0.042	0.063	-
DECEMBER 2019	15/01/2020	Boron	milligrams per litre	Weekly	5	1.81	1.974	2.41	
DECEMBER 2019	15/01/2020	Cadmium	milligrams per litre	Weekly	5	<0.0001	0.00012	0.0002	-
DECEMBER 2019	15/01/2020	Chromium	milligrams per litre	Weekly	5	<0.01	0.005	<0.01	-
DECEMBER 2019	15/01/2020	Chromium (total)	milligrams per litre	Weekly	5	<0.001	0.0031	0.006	
DECEMBER 2019	15/01/2020	Conductivity	uS/cm	Weekly	5	2820.0	3216.0	3450.0	
DECEMBER 2019	15/01/2020	Copper	milligrams per litre	Weekly	5	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Flouride	milligrams per litre	Weekly	5	2.4	2.9	3.6	
DECEMBER 2019	15/01/2020	Lead	milligrams per litre	Weekly	5	<0.001	0.0005	<0.001	-
DECEMBER 2019	15/01/2020	Mercury	milligrams per litre	Weekly	5	<0.0001	0.00005	<0.0001	-
DECEMBER 2019	15/01/2020	Oil and Grease	milligrams per litre	Weekly	5	<5	2.5	<5	
Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
DECEMBER 2019	15/01/2020	pH	pH Units	Weekly	5	8.2	8.3	8.3	-

# Monthly Data Summary

DECEMBER 2019	15/01/2020	Selenium	milligrams per litre	Weekly	5	0.02	0.04	0.08	-
DECEMBER 2019	15/01/2020	TSS	milligrams per litre	Weekly	5	4	5.2	7	
DECEMBER 2019	15/01/2020	Zinc	milligrams per litre	Weekly	5	<0.005	0.0025	<0.005	
Comments									

# Monthly Data Summary

## Details of Non-Compliance with Licence

Licence condition number not complied with

N/A

Summary of particulars of the non-compliance **(NO MORE THAN 50 WORDS)**

If required, further details on particulars of non-compliance

-

Date(s) when the non-compliance occurred, if applicable

If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance

Cause of non-compliance

Action taken or that will be taken to mitigate any adverse effects of the non-compliance

Action taken or that will be taken to prevent a recurrence of the non-compliance

# Monthly Data Summary

# Monthly Data Summary