

Monthly Data Summary

Environmental Protection Licence 2122

AGL Macquarie - Liddell Power Station

Monitoring Period

AUGUST 2020



EPA Identification Number 3

Air emission monitoring - Combined air emissions from boiler 1 via Points 7 and 8 to Point 1

Pollutant	Unit of measure	No. of samples required by licence	Date capture %	Lowest sample value	Mean of sample values	Highest sample value	100th percentile concentration limits
Nitrogen Oxides	mg/m ³	Continuous	100.0%	317.9	443.9	518.0	1500 mg/m ³
Sulfur Dioxide	mg/m ³	Continuous	100.0%	426.2	601.2	869.4	1700 mg/m ³

In addition to the 100th percentile concentration limits, 99th percentile concentration limits of 1100 mg/m³ and 1400 mg/m³ apply to Nitrogen oxides and Sulfur dioxide, respectively.

Pollutant	Unit of measure	No. of samples required by licence	Date of sample	Most recent result	100th percentile concentration limits
Cadmium	mg/m ³	Six monthly	31/08/2020	0.00008	0.2 mg/m ³
Chlorine	mg/m ³	Six monthly	31/08/2020	0.13000	20 mg/m ³
Fluorine	mg/m ³	Six monthly	31/08/2020	12.00000	20 mg/m ³
Hydrogen chloride	mg/m ³	Six monthly	31/08/2020	19.00000	50 mg/m ³
Mercury	mg/m ³	Six monthly	31/08/2020	0.00081	0.05 mg/m ³
Solid Particles	mg/m ³	Quarterly	31/08/2020	104.50000	50 mg/m ³
Sulfuric acid mist and sulfur trioxide (as SO ₃)	mg/m ³	Six monthly	31/08/2020	1.20000	100 mg/m ³
Type 1 and Type 2 substances in aggregate	mg/m ³	Six monthly	31/08/2020	0.03925	0.75 mg/m ³
Volatile organic compounds as n-propane equivalent	mg/m ³	Six monthly	31/08/2020	0.16000	10 mg/m ³

Measured concentrations from the boiler's A and B ducts are used to calculate the concentrations from the boiler. Some of the duct concentrations for some substances are reported as less than the relevant Limit of Detection, in which case the calculation uses 50% of the Limit of Detection value, in accordance with LBL Protocol rules.

The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

EPA Identification Number 4

Air emission monitoring - Combined air emissions from boiler 2 via Points 9 and 10 to Point 1

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value	100th percentile concentration limits
Nitrogen Oxides	mg/m ³	Continuous		0.0		0.0	1500 mg/m ³
Sulfur Dioxide	mg/m ³	Continuous		0.0		0.0	1700 mg/m ³

In addition to the 100th percentile concentration limits, 99th percentile concentration limits of 1100 mg/m³ and 1400 mg/m³ apply to Nitrogen oxides and Sulfur dioxide, respectively .

Pollutant	Unit of measure	No. of samples required by licence	Date of sample	Most recent result	100th percentile concentration limits
Cadmium	mg/m ³	Six monthly	15/09/2020	0.00010	0.2 mg/m ³
Chlorine	mg/m ³	Six monthly	10/03/2020	0.03900	20 mg/m ³
Fluorine	mg/m ³	Six monthly	10/03/2020	7.50000	20 mg/m ³
Hydrogen chloride	mg/m ³	Six monthly	10/03/2020	5.80000	50 mg/m ³
Mercury	mg/m ³	Six monthly	15/09/2020	0.00014	0.05 mg/m ³
Solid Particles	mg/m ³	Quarterly	15/09/2020	57.44444	50 mg/m ³
Sulfuric acid mist and sulfur trioxide (as SO ₃)	mg/m ³	Six monthly	10/03/2020	1.40000	100 mg/m ³
Type 1 and Type 2 substances in aggregate	mg/m ³	Six monthly	15/09/2020	0.02733	0.75 mg/m ³
Volatile organic compounds as n-propane equivalent	mg/m ³	Six monthly	10/03/2020	0.02000	10 mg/m ³

Measured concentrations from the boiler's A and B ducts are used to calculate the concentrations from the boiler. Some of the duct concentrations for some substances are reported as less than the relevant Limit of Detection, in which case the calculation uses 50% of the Limit of Detection value, in accordance with LBL Protocol rules.

The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

EPA Identification Number 5

Air emission monitoring - Combined air emissions from boiler 3 via Points 11 and 12 to Point 2

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value	100th percentile concentration limits
Nitrogen Oxides	mg/m ³	Continuous	100.0%	281.7	478.1	636.1	1500 mg/m ³
Sulfur Dioxide	mg/m ³	Continuous	100.0%	545.7	887.0	1097.9	1700 mg/m ³

In addition to the 100th percentile concentration limits, 99th percentile concentration limits of 1100 mg/m³ and 1400 mg/m³ apply to Nitrogen oxides and Sulfur dioxide, respectively .

Pollutant	Unit of measure	No. of samples required by licence	Date of sample	Most recent result	100th percentile concentration limits
Cadmium	mg/m ³	Six monthly	15/09/2020	0.00012	0.2 mg/m ³
Chlorine	mg/m ³	Six monthly	28/05/2020	0.00770	20 mg/m ³
Fluorine	mg/m ³	Six monthly	28/05/2020	9.00000	20 mg/m ³
Hydrogen chloride	mg/m ³	Six monthly	28/05/2020	13.00000	50 mg/m ³
Mercury	mg/m ³	Six monthly	15/09/2020	0.00015	0.05 mg/m ³
Solid Particles	mg/m ³	Quarterly	15/09/2020	44.17949	50 mg/m ³
Sulfuric acid mist and sulfur trioxide (as SO ₃)	mg/m ³	Six monthly	28/05/2020	3.40000	100 mg/m ³
Type 1 and Type 2 substances in aggregate	mg/m ³	Six monthly	15/09/2020	0.00846	0.75 mg/m ³
Volatile organic compounds as n-propane equivalent	mg/m ³	Six monthly	28/05/2020	0.02000	10 mg/m ³

Measured concentrations from the boiler's A and B ducts are used to calculate the concentrations from the boiler. Some of the duct concentrations for some substances are reported as less than the relevant Limit of Detection, in which case the calculation uses 50% of the Limit of Detection value, in accordance with LBL Protocol rules.

The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

EPA Identification Number 6

Air emission monitoring - Combined air emissions from boiler 4 via Points 13 and 14 to Point 2

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value	100th percentile concentration limits
Nitrogen Oxides	mg/m ³	Continuous	100.0%	305.4	467.7	648.7	1500 mg/m ³
Sulfur Dioxide	mg/m ³	Continuous	100.0%	631.2	814.7	1101.8	1700 mg/m ³

In addition to the 100th percentile concentration limits, 99th percentile concentration limits of 1100 mg/m³ and 1400 mg/m³ apply to Nitrogen oxides and Sulfur dioxide, respectively .

Pollutant	Unit of measure	No. of samples required by licence	Date of sample	Most recent result	100th percentile concentration limits
Cadmium	mg/m ³	Six monthly	16/09/2020	0.00010	0.2 mg/m ³
Chlorine	mg/m ³	Six monthly	16/09/2020	0.06900	20 mg/m ³
Fluorine	mg/m ³	Six monthly	16/09/2020	11.00000	20 mg/m ³
Hydrogen chloride	mg/m ³	Six monthly	16/09/2020	17.00000	50 mg/m ³
Mercury	mg/m ³	Six monthly	16/09/2020	0.00113	0.05 mg/m ³
Solid Particles	mg/m ³	Quarterly	16/09/2020	31.06818	50 mg/m ³
Sulfuric acid mist and sulfur trioxide (as SO ₃)	mg/m ³	Six monthly	16/09/2020	47.00000	100 mg/m ³
Type 1 and Type 2 substances in aggregate	mg/m ³	Six monthly	16/09/2020	0.01135	0.75 mg/m ³
Volatile organic compounds as n-propane equivalent	mg/m ³	Six monthly	16/09/2020	0.16000	10 mg/m ³

Measured concentrations from the boiler's A and B ducts are used to calculate the concentrations from the boiler. Some of the duct concentrations for some substances are reported as less than the relevant Limit of Detection, in which case the calculation uses 50% of the Limit of Detection value, in accordance with LBL Protocol rules.

The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

EPA Identification Number 7

Air emission monitoring - Boiler number 1 exhaust - duct A

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Nitrogen Oxides	mg/m ³	Continuous	100.0%	317.9	443.9	518.0
Sulfur Dioxide	mg/m ³	Continuous	100.0%	426.2	601.2	869.4
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	percent	degrees Celsius				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m ³	Six monthly	2	31/08/2020	<0.0002
Chlorine	mg/m ³	Six monthly			
Fluorine	mg/m ³	Six monthly			
Hydrogen chloride	mg/m ³	Six monthly			
Mercury	mg/m ³	Six monthly	2	31/08/2020	0.00120
Solid Particles	mg/m ³	Quarterly	3	31/08/2020	170.00000
Sulfuric acid mist and sulfur trioxide (as SO ₃)	mg/m ³	Six monthly			
Type 1 and Type 2 substances in aggregate	mg/m ³	Six monthly	2	31/08/2020	<0.1
Volatile organic compounds as n-propane equivalent	mg/m ³	Six monthly			
Carbon dioxide	percent	Six monthly	2	31/08/2020	0.00000

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 8

Air emission monitoring - Boiler number 1 exhaust - duct B

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	degrees Celsius	Continuous				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	2	22/10/2019	<0.0002
Mercury	mg/m3	Six monthly	2	11/03/2021	<0.0002
Solid Particles	mg/m3	Quarterly	3	11/03/2021	15.00000
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	2	11/03/2021	<0.016

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 9

Air emission monitoring - Boiler number 2 exhaust - duct A

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Flow	cubic metres per second	Continuous	Continuous			
Moisture	percent	Continuous	Continuous			
Oxygen	percent	Continuous	Continuous			
Temperature	degrees Celsius	Continuous	Continuous			

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	2	4/04/2019	<0.0002
Mercury	mg/m3	Six monthly	2	10/03/2021	0.00180
Solid Particles	mg/m3	Quarterly	3	2/06/2021	46.00000
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	2	10/03/2021	<0.028

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 10

Air emission monitoring - Boiler number 2 exhaust - duct B

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Nitrogen Oxides	mg/m3	Continuous		0.0		0.0
Sulfur Dioxide	mg/m3	Continuous		0.0		0.0
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	degrees Celsius	Continuous				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	2	2/06/2021	0.00000
Chlorine	mg/m3	Six monthly			
Fluorine	mg/m3	Six monthly			
Hydrogen chloride	mg/m3	Six monthly			
Mercury	mg/m3	Six monthly	2	2/06/2021	0.00000
Solid Particles	mg/m3	Quarterly	3	2/06/2021	34.00000
Sulfuric acid mist and sulfur trioxide (as SO3)	mg/m3	Six monthly			
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	2	2/06/2021	0.00000
Volatile organic compounds as n-propane equivalent	mg/m3	Six monthly			
Carbon dioxide	percent	Six monthly	2	2/06/2021	9.50000

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 11

Air emission monitoring - Boiler number 3 exhaust - duct A

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Nitrogen Oxides	mg/m3	Continuous	100.0%	281.7	478.1	636.1
Sulfur Dioxide	mg/m3	Continuous	100.0%	545.7	887.0	1097.9
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	degrees Celsius	Continuous				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	1	3/06/2021	0.00000
Chlorine	mg/m3	Six monthly			
Fluorine	mg/m3	Six monthly			
Hydrogen chloride	mg/m3	Six monthly			
Mercury	mg/m3	Six monthly	1	3/06/2021	0.00000
Solid Particles	mg/m3	Quarterly	2	3/06/2021	28.00000
Sulfuric acid mist and sulfur trioxide (as SO3)	mg/m3	Six monthly			
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	1	3/06/2021	0.00000
Volatile organic compounds as n-propane equivalent	mg/m3	Six monthly			
Carbon dioxide	percent	Six monthly	1	3/06/2021	10.30000

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 12

Air emission monitoring - Boiler number 3 exhaust - duct B

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	degrees Celsius	Continuous				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	1	26/03/2019	<0.0002
Mercury	mg/m3	Six monthly	1	15/09/2020	<0.0003
Solid Particles	mg/m3	Quarterly	2	3/06/2021	42.00000
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	1	15/09/2020	<0.014

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 13

Air emission monitoring - Boiler number 4 exhaust - duct A

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	degrees Celsius	Continuous				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	2	9/03/2021	<0.0003
Mercury	mg/m3	Six monthly	2	9/03/2021	<0.0003
Solid Particles	mg/m3	Quarterly	4	1/06/2021	9.90000
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	2	9/03/2021	<0.023

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 14

Air emission monitoring - Boiler number 4 exhaust - duct B

Pollutant	Unit of measure	No. of samples required by licence	Data capture %	Lowest sample value	Mean of sample	Highest sample value
Nitrogen Oxides	mg/m3	Continuous	100.0%	305.4	467.7	648.7
Sulfur Dioxide	mg/m3	Continuous	100.0%	631.2	814.7	1101.8
Flow	cubic metres per second	Continuous				
Moisture	percent	Continuous				
Oxygen	percent	Continuous				
Temperature	degrees Celsius	Continuous				

Pollutant	Unit of measure	No. of samples required by licence	# No. of samples collected and analysed	Date of sample	Most recent result
Cadmium	mg/m3	Six monthly	2	17/11/2020	0.00000
Chlorine	mg/m3	Six monthly			
Fluorine	mg/m3	Six monthly			
Hydrogen chloride	mg/m3	Six monthly			
Mercury	mg/m3	Six monthly	2	17/11/2020	0.00000
Solid Particles	mg/m3	Quarterly	4	1/06/2021	5.00000
Sulfuric acid mist and sulfur trioxide (as SO3)	mg/m3	Six monthly			
Type 1 and Type 2 substances in aggregate	mg/m3	Six monthly	2	17/11/2020	0.00000
Volatile organic compounds as n-propane equivalent	mg/m3	Six monthly			
Carbon dioxide	percent	Six monthly	2	1/06/2021	10.30000

A less than sign, "<", before a result in the table above indicates that the measured result was less than the relevant Limit of Detection for that test. The Station's Environment Protection Licence requires that Solid Particles are sampled from the A and B ducts 4 times per year each (once in each quarter). Other substances listed in the table are sampled twice per year. The table includes the most recent results available.

Number of samples from the duct in the year to date

EPA Identification Number 16

Discharge to waters - Discharge quality monitoring

Discharge of cooling water from the cooling water outlet canal to Lake Liddell

Pollutant	Unit of measure	No. of samples required by licence	No. of samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value
Ammonia	mg/L	Fortnightly	2	<0.01	0.03	0.05
Antimony	mg/L	Fortnightly	2	0.007	0.01	0.007
Arsenic	mg/L	Fortnightly	2	0.006	0.01	0.006
Barium	mg/L	Fortnightly	2	0.099	0.10	0.101
Beryllium	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Boron	mg/L	Fortnightly	2	1.15	1.16	1.16
Cadmium	mg/L	Fortnightly	2	<0.0001	0.00	<0.0001
Chlorine	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Chromium (trivalent)	mg/L	Fortnightly	2	<0.01	0.01	<0.01
Chromium (VI) compounds	mg/L	Fortnightly	2	<0.01	0.01	<0.01
Cobalt	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Conductivity	µS/cm	Fortnightly	2	2790	2795	2800
Copper	mg/L	Fortnightly	2	0.003	0.00	0.003
Fluoride	mg/L	Fortnightly	2	1.58	1.61	1.64
Lead	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Manganese	mg/L	Fortnightly	2	0.006	0.01	0.006
Mercury	mg/L	Fortnightly	2	<0.0001	0.00	<0.0001
Methyl Blue Active Substances	mg/L	Fortnightly	2	<0.1	0.05	<0.1
Molybdenum	mg/L	Fortnightly	2	0.108	0.11	0.112
Nickel	mg/L	Fortnightly	2	0.005	0.01	0.006
Nitrogen	mg/L	Fortnightly	2	0.3	0.35	0.4
Oil and Grease	mg/L	Weekly during any discharge	4	<5	2.5	<5
pH	mg/L	Daily during any discharge	31	7.9	8.5	8.7
Phosphorus	mg/L	Fortnightly	2	0.02	0.03	0.03
Selenium	mg/L	Fortnightly	2	<0.01	0.01	<0.01
Sulfur	mg/L	Fortnightly	2	620	650.00	680
Temperature	degrees Celsius	Fortnightly	2	17.4	18.1	18.8
Tin	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Total dissolved solids	mg/L	Fortnightly	2	1800	1815	1830
Total organic carbon	mg/L	Fortnightly	2	8	8	8
Total suspended solids	mg/L	Fortnightly	2	3	4	5
Vanadium	mg/L	Fortnightly	2	0.01	0.01	0.01
Zinc	mg/L	Fortnightly	2	<0.005	0.00	<0.005

EPA Identification Number 17

Discharge to waters - Discharge quality monitoring

Discharge from oil and grit trap weir overflow to Lake Liddell

Pollutant	Unit of measure	No. of samples required by licence	No. of samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value
Ammonia	mg/L	Fortnightly	2	<0.01	0.01	0.02
Antimony	mg/L	Fortnightly	2	0.006	0.01	0.006
Arsenic	mg/L	Fortnightly	2	0.005	0.01	0.005
Barium	mg/L	Fortnightly	2	0.092	0.09	0.092
Beryllium	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Boron	mg/L	Fortnightly	2	1.03	1.07	1.1
Cadmium	mg/L	Fortnightly	2	<0.0001	0.00	<0.0001
Chlorine	mg/L	Fortnightly	2	0.07	0.08	0.08
Chromium (trivalent)	mg/L	Fortnightly	2	<0.01	0.01	<0.01
Chromium (VI) compounds	mg/L	Fortnightly	2	<0.01	0.01	<0.01
Cobalt	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Conductivity	µS/cm	Fortnightly	2	2420	2470	2520
Copper	mg/L	Fortnightly	2	0.004	0.01	0.007
Fluoride	mg/L	Fortnightly	2	1.34	1.36	1.37
Lead	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Manganese	mg/L	Fortnightly	2	0.006	0.01	0.014
Mercury	mg/L	Fortnightly	2	<0.0001	0.00	<0.0001
Methyl Blue Active Substances	mg/L	Fortnightly	2	<0.1	0.05	<0.1
Molybdenum	mg/L	Fortnightly	2	0.094	0.10	0.103
Nickel	mg/L	Fortnightly	2	0.004	0.01	0.006
Nitrogen	mg/L	Fortnightly	2	0.3	0.35	0.4
Oil and Grease	mg/L	Weekly during any discharge	4	<5	2.5	<5
pH	mg/L	Daily during any discharge	31	8.4	8.6	8.7
Phosphorus	mg/L	Fortnightly	2	0.03	0.03	0.03
Selenium	mg/L	Fortnightly	2	<0.01	0.01	<0.01
Sulfur	mg/L	Fortnightly	2	590	590.00	590
Temperature	degrees Celsius	Fortnightly	2	14.5	15.45	16.4
Tin	mg/L	Fortnightly	2	<0.001	0.00	<0.001
Total dissolved solids	mg/L	Fortnightly	2	1580	1650	1720
Total organic carbon	mg/L	Fortnightly	2	8	8	8
Total suspended solids	mg/L	Fortnightly	2	4	11	18
Vanadium	mg/L	Fortnightly	2	0.01	0.01	0.01
Zinc	mg/L	Fortnightly	2	<0.005	0.01	0.024

EPA Identification Number 18

Discharge to waters - Discharge quality monitoring and Volume monitoring

Discharge from skimmer dam overflow spillway to Lake Liddell

Pollutant	Unit of measure	No. of samples required by licence	No. of samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value
Arsenic	mg/L	Weekly during any discharge	4	0.026	0.059	0.087
Boron	mg/L	Weekly during any discharge	4	1.98	2.105	2.17
Cadmium	mg/L	Weekly during any discharge	4	0.0001	0.00015	0.0002
Chromium (trivalent)	mg/L	Weekly during any discharge	1	<0.01	0.005	<0.01
Chromium (VI) compounds	mg/L	Weekly during any discharge	4	<0.01	0.00625	0.01
Copper	mg/L	Weekly during any discharge	4	<0.001	0.001125	0.003
Electrical conductivity	µS/cm	Weekly during any discharge	4	2920	2967.5	3080
Fluoride	mg/L	Weekly during any discharge	4	2.2	3.075	3.6
Lead	mg/L	Weekly during any discharge	4	<0.001	0.0005	<0.001
Mercury	mg/L	Weekly during any discharge	4	<0.0001	0.00005	<0.0001
Oil and Grease	mg/L	Weekly during any discharge	4	<5	4	8
pH		Weekly during any discharge	4	8.3	8.4	8.4
Selenium	mg/L	Weekly during any discharge	4	0.04	0.0725	0.1
Total suspended solids	mg/L	Weekly during any discharge	4	<5	8	16
Zinc	mg/L	Weekly during any discharge	4	<0.005	0.0025	<0.005
Volume	kilolitres per day	Daily	25	28000	489320	2793000

EPA Identification Number 19

Discharge utilisation area - Volume monitoring

Discharge of effluent from the final pond of the sewage treatment system adjacent to utilisation area.

Pollutant	Unit of measure	No. of samples required by licence	No. of samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value
Volume	kilolitres per day	Daily	31	0.36	64.14	176.17

Details of Non-Compliance with Licence Conditions
Licence condition number not complied with
Summary of particulars of the non-compliance (NO MORE THAN 50 WORDS)
If required, further details on particulars of non-compliance
Date(s) when the non-compliance occurred, if applicable
If relevant, precise location where the non-compliance occurred (attach a map or diagram)
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
Cause of non-compliance
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
Action taken or that will be taken to prevent a recurrence of the non-compliance