Bayswater Monthly Data Summary April 2015

LICENCE NO	779
LICENCE HOLDER	AGL Macquarie
REPORTING PERIOD	01 / 4 / 2015 to 30 / 4/ 2015

A1 Licence Holder

Licence Number 779

Licence Holder AGL Macquarie

Trading Name (if applicable)

ABN 18 402 904 344

A2 Premises to which Licence Applies (if applicable)

Common Name (if any) BAYSWATER POWER STATION

Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

A3 Activities to which Licence Applies

Electricity Generation

A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works

Sewage Treatment Systems

Chemical Storage Facilities

Aircraft (helicopter) facilities

A5 Fee-Based Activity Classifications

Fee-based activity	Activity scale	Unit of measure
Generation of electrical power from coal	> 4,000.00	Gwh generated
Chemical Storage	> 100	Tonnes Generated or Stored
Coal Works	> 5000000	Tonnes handled

Discharge & Monitoring Point 1

Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator holding basin to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Oil and Grease	milligrams per litre	Fortnightly	4	4.5	4.9	5.0	10 mg/L
Apr-15	15/05/2015	Total suspended solids	milligrams per litre	Fortnightly	4	4.0	4.6	5.0	20 mg/L
Comments:									

Discharge & Monitoring Point 7

Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit		
Apr-15	15/05/2015	Conductivity	uS/cm	Weekly	4	3000	3575	3900	4500		
Apr-15	15/05/2015	рН	pH Units	Weekly	4	7.5	7.6	7.7	6.5 - 8.5		
Comments:	Comments:										

Discharge & Monitoring Point 8

Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Conductivity	uS/cm	Continuous during disharge	3	2200	2200	2200	
Apr-15	15/05/2015	рН	pH Units	Daily during discharge	3	8.1	8.20	8.2	6.5 - 8.5
Apr-15	15/05/2015	Total suspended solids	milligrams per litre	Monthly	3	2	3.00	5	30 mg/L
Comments: A total of 1148.1 ML discharged under HRSTS for April 2015.									

Discharge & Monitoring Point 10

Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	
Apr-15	15/05/2015	A111	parts per million			91	193	408	700	
Apr-15	15/05/2015	Nitrogen Oxides	milligrams per cubic metre	Continuous 1 hr Averages	100.0%	186.98	396.91	837.12	1500	
Apr-15	15/05/2015	Sulphur dioxide	parts per million		Continuous 1 hr Averages 100.0%	135	322	391	600	
Apr-15	15/05/2015	Sulphur dioxide	milligrams per cubic metre	Continuous 1 nr Averages		384	919	1118	•	
Apr-15	15/05/2015	Opacity	Percentage	Continuous 1 hr Averages	99%	2.1%	5.1%	9.8%	20%	
Comments:	Comments:									

Discharge & Monitoring Point 11

Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed (%)	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Opacity	Percentage	Continuous 1 hr Averages	100	1.2%	2.8%	5.7%	20%
Comments:									

Discharge & Monitoring Point 12

Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Opacity	Percentage	Continuous 1 hr Averages	>99%	2.6%	6.5%	15.1%	20%
Comments:									

Discharge & Monitoring Point 13

Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed (%)	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Undifferentiated Particulates	milligrams per cubic metre	Continuous 1 hr Averages	100	1.2%	6.7%	3.3%	100.0
Comments:									

Volume or Mass Monitoring Summary

For each monitoring point identified in your licence complete the details of the volume or mass monitoring indicated in the tables provided below.

If volume or mass monitoring is not required by your licence, no tables will appear below.

Note that this does not exclude the need to conduct appropriate concentration monitoring of assessable pollutants as required by load-based licensing (if applicable).

Discharge & Monitoring Point 1

Discharge to waters

Effluent quality and volume monitoring

Discharge from Treated Process Water Pond to Tinkers Creek

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Continuous during discharge	kilolitres per week	Continuous during discharge	5	6,022.0	1,272	10,556	36,400 kL
Comments:									

Discharge & Monitoring Point 7

Discharge to waters Effluent quality and volume monitoring

Discharge from cooling towers to Tinklers creek.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit
Apr-15	15/05/2015	Continuous during discharge	megalitres per month	Continuous during discharge	1	447.5	447.5	447.5	840
Comments: A tota	Comments: A total of 447.5 ML dicharged during April 2015.								

Discharge & Monitoring Point 8

Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme

Discharge from Lake Liddell To Hunter River

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	
Apr-15	15/05/2015	Continuous during discharge	megalitres per block	Continuous during discharge	0	51	287	400	700	
Comments: A tota	Community, A total of 4440 4 MJ dispharend under UDCTS for Antil 2045									

C2 Details of Non-Compliance with Licence

Licence condition number not complied with
Condition L3.6
Summary of particulars of the non-compliance (NO MORE THAN 50 WORDS)
High pH was recorded at EPL Point 7 and on investigation it was found that ammonia had entered the storm water system.
If required, further details on particulars of non-compliance
-
Date(s) when the non-compliance occurred, if applicable
9-Apr-15
If relevant, precise location where the non-compliance occurred (attach a map or diagram)
-
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
-
Cause of non-compliance
Under investigation.
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
Action taken or that will be taken to prevent a recurrence of the non-compliance