

# Monthly Data Summary

## BAYSWATER MONTHLY DATA SUMMARY APRIL 2018

LICENCE NO	779
LICENCE HOLDER	AGL Macquarie
REPORTING PERIOD	APRIL 2018

### A1 Licence Holder

Licence Number 779  
Licence Holder AGL Macquarie  
Trading Name (if applicable)  
ABN 18 402 904 344

### A2 Premises to which Licence Applies (if applicable)

Common Name (if any) BAYSWATER POWER STATION  
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

### A3 Activities to which Licence Applies

Electricity Generation

### A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works  
Sewage Treatment Systems  
Chemical Storage Facilities  
Aircraft (helicopter) facilities

### A5 Fee-Based Activity Classifications

**Note** that the fee based activity classification is used to calculate the administrative fee.

Fee-based activity	Activity scale	Unit of measure
Generation of electrical power from coal	> 4,000.00	Gwh generated
Chemical Storage	> 100	Tonnes Generated or Stored
Coal Works	> 5000000	Tonnes handled

# Monthly Data Summary

## Discharge & Monitoring Point 1

### Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator hoBWinng basin and Treated Process Water Pond to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Oil and Grease	milligrams per litre	Fortnightly	4	<5	2.5	<5	10 mg/L
APRIL 2018	15/05/2018	Total suspended solids	milligrams per litre	Fortnightly	4	1.0	4.0	6.0	20 mg/L
APRIL 2018	15/05/2018	Volume discharge	kilolitres per week	Weekly during discharge	5	0	12,230	19,078	36,400 kL
Comments:									

## Discharge & Monitoring Point 7

### Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Conductivity	uS/cm	Continuous	0.993	10.0	2697.0	3947.9	4500 uS/cm
APRIL 2018	15/05/2018	pH	pH Units	Continuous	0.993	7.0	8.0	8.5	6.5 - 8.5
APRIL 2018	15/05/2018	Volume discharge	Megalitres per month	Weekly during discharge	12		256.0		840 ML
Comments:									

## Discharge & Monitoring Point 8

### Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurment frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Conductivity	uS/cm	Continuous during discharge	1	2670.0	2670.0	2670.0	-
APRIL 2018	15/05/2018	pH	pH Units	Daily during discharge	1	8.2	8.2	8.2	6.5 - 8.5
APRIL 2018	15/05/2018	Total suspended solids	milligrams per litre	Monthly	1	8.0	8.0	8.0	30 mg/L
APRIL 2018	15/05/2018	Volume discharge	Megalitres per day	Daily during discharge	-	-	-	-	700 ML
Comments: HRSTS Discharge did not occur during April 2018. Results obtained from routine monthly sampling									

# Monthly Data Summary

## Discharge & Monitoring Point 17

### Discharge to waters

#### Ravensthorpe void. Inlet point located on the Void 4 pontoon pump system

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Conductivity	uS/cm	Continuous during discharge	1	7470.0	7470.0	7470.0	-
APRIL 2018	15/05/2018	pH	pH Units	Daily during discharge	1	8.8	8.8	8.8	6.5 - 9.5
APRIL 2018	15/05/2018	Total suspended solids	milligrams per litre	Monthly	1	13.0	13.0	13.0	30 mg/L
APRIL 2018	15/05/2018	Boron	milligrams per litre	Weekly during discharge	1	3.3	3.3	3.3	0.81
APRIL 2018	15/05/2018	Cadmium	milligrams per litre	Weekly during discharge	1	<0.0001	0.0	<0.0001	0.0003
APRIL 2018	15/05/2018	Copper	milligrams per litre	Weekly during discharge	1	<0.001	0.0	<0.001	0.001
APRIL 2018	15/05/2018	Iron	milligrams per litre	Weekly during discharge	1	0.0	0.0	0.0	0.27
APRIL 2018	15/05/2018	Molybdenum	milligrams per litre	Weekly during discharge	1	0.4	0.4	0.4	0.29
APRIL 2018	15/05/2018	Nickel	milligrams per litre	Weekly during discharge	1	0.0	0.0	0.0	0.19
APRIL 2018	15/05/2018	Silver	milligrams per litre	Weekly during discharge	1	<0.0001	0.0	<0.0001	0.0005
APRIL 2018	15/05/2018	Volume discharge	Megalitres per day	Daily during discharge	-	-	-	-	20 ML
Comments:	HRSTS Discharge did not occur during April 2018. Results obtained from routine monthly sampling								

## Discharge & Monitoring Point 18

### Discharge to waters

#### Discharge from Bayswater Ash Dam unlined flood pillway located near left abutment

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Samples collected and analysed	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Conductivity	uS/cm	Weekly during discharge	0				-
APRIL 2018	15/05/2018	pH	pH Units	Weekly during discharge	0				6.5 - 9.5
APRIL 2018	15/05/2018	Total suspended solids	milligrams per litre	Weekly during discharge	0				30 mg/L
APRIL 2018	15/05/2018	Boron	milligrams per litre	Weekly during discharge	0				0.81
APRIL 2018	15/05/2018	Cadmium	milligrams per litre	Weekly during discharge	0				0.0003
APRIL 2018	15/05/2018	Copper	milligrams per litre	Weekly during discharge	0				0.001

# Monthly Data Summary

APRIL 2018	15/05/2018	Iron	milligrams per litre	Weekly during discharge	0				0.27
APRIL 2018	15/05/2018	Molybdenum	milligrams per litre	Weekly during discharge	0				0.29
APRIL 2018	15/05/2018	Nickel	milligrams per litre	Weekly during discharge	0				0.19
APRIL 2018	15/05/2018	Silver	milligrams per litre	Weekly during discharge	0				0.0005
Comments:	Discharge did not occur during April 2018								

# Monthly Data Summary

## Discharge & Monitoring Point 10

### Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Nitrogen Oxides	parts per million	Continuous	One hour	71.9%	100.5	110.5	164.8	-
APRIL 2018	15/05/2018		milligrams per cubic metre				206.2			226.8
APRIL 2018	15/05/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.9%	116.4	261.7	343.2	600 ppm
APRIL 2018	15/05/2018		milligrams per cubic metre				332.7			747.8
APRIL 2018	15/05/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.9%	1.5%	2.1%	3.3%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
Oct-17	15/11/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
Oct-17	15/11/2017	Carbon monoxide	ppm	1	1	<2	
Oct-17	15/11/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200
Oct-17	15/11/2017	Copper	milligrams per cubic metre	1	1	0.0005	
Oct-17	15/11/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.013	5
Oct-17	15/11/2017	Hydrogen chloride	milligrams per cubic metre	1	1	15.0	100
Oct-17	15/11/2017	Mercury	milligrams per cubic metre	1	1	0.00180	1.0
Oct-17	15/11/2017	Nitrogen oxides	milligrams per cubic metre	1	1	850	1500
Oct-17	15/11/2017	Solid particles	milligrams per cubic metre	1	1	45.0	100
Oct-17	15/11/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	20.00	100
Oct-17	15/11/2017	Sulphur dioxide	milligrams per cubic metre	1	1	950	
Oct-17	15/11/2017	Total fluoride	milligrams per cubic metre	1	1	9.9	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 1 tested on 10 October 2017.							

# Monthly Data Summary

## Discharge & Monitoring Point 11

### Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Nitrogen Oxides	parts per million	Continuous	One hour	100.0%	101.4	226.7	345.8	-
APRIL 2018	15/05/2018		milligrams per cubic metre				208.2	465.4	709.8	1500 mg/m <sup>3</sup>
APRIL 2018	15/05/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	202.8	264.4	320.0	600 ppm
APRIL 2018	15/05/2018		milligrams per cubic metre				579.6	755.8	914.6	-
APRIL 2018	15/05/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	3.3%	6.0%	11.5%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>			
Oct-17	15/11/2017	Cadmium	milligrams per cubic metre	1	1	<0.0001	1.0			
Oct-17	15/11/2017	Carbon monoxide	ppm	1	1	3				
Oct-17	15/11/2017	Chlorine	milligrams per cubic metre	1	1	<0.007	200			
Oct-17	15/11/2017	Copper	milligrams per cubic metre	1	1	0.0004				
Oct-17	15/11/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.0096	5			
Oct-17	15/11/2017	Hydrogen chloride	milligrams per cubic metre	1	1	14.0	100			
Oct-17	15/11/2017	Mercury	milligrams per cubic metre	1	1	0.00089	1.0			
Oct-17	15/11/2017	Nitrogen oxides	milligrams per cubic metre	1	1	620	1500			
Oct-17	15/11/2017	Solid particles	milligrams per cubic metre	1	1	41.0	100			
Oct-17	15/11/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	3.00	100			
Oct-17	15/11/2017	Sulphur dioxide	milligrams per cubic metre	1	1	970				
Oct-17	15/11/2017	Total fluoride	milligrams per cubic metre	1	1	9.2	50			
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 2 tested on 12 October 2017										

# Monthly Data Summary

## Discharge & Monitoring Point 12

### Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Nitrogen Oxides	parts per million	Continuous	One hour	100.0%	113.1	291.2	433.7	-
APRIL 2018	15/05/2018		milligrams per cubic metre				232.1	597.7	890.1	1500 mg/m <sup>3</sup>
APRIL 2018	15/05/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	176.4	318.0	396.2	600 ppm
APRIL 2018	15/05/2018		milligrams per cubic metre				504.1	908.9	1132.3	-
APRIL 2018	15/05/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	100.0%	3.5%	6.2%	11.2%	-
Comments:										

### Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>
May-17	3/07/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0
May-17	3/07/2017	Carbon monoxide	ppm	1	1	97	
May-17	3/07/2017	Chlorine	milligrams per cubic metre	1	1	<0.006	200
May-17	3/07/2017	Copper	milligrams per cubic metre	1	1	0.0007	
May-17	3/07/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.011	5
May-17	3/07/2017	Hydrogen chloride	milligrams per cubic metre	1	1	22.0	100
May-17	3/07/2017	Mercury	milligrams per cubic metre	1	1	0.00130	1.0
May-17	3/07/2017	Nitrogen oxides	milligrams per cubic metre	1	1	720	1500
May-17	3/07/2017	Solid particles	milligrams per cubic metre	1	1	24.0	100
May-17	3/07/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	1.90	100
May-17	3/07/2017	Sulphur dioxide	milligrams per cubic metre	1	1	1100	
May-17	3/07/2017	Total fluoride	milligrams per cubic metre	1	1	11.0	50
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 3 tested on 30 May 2017							

# Monthly Data Summary

## Discharge & Monitoring Point 13

### Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	Sampling / measurement frequency	Averaging period	Data capture %	Lowest sample value	Mean of samples	Highest sample value	EPL Limit
APRIL 2018	15/05/2018	Nitrogen Oxides	parts per million	Continuous	One hour	98.4%	100.4	234.8	427.2	-
APRIL 2018	15/05/2018		milligrams per cubic metre				206.0	481.9	876.8	1500 mg/m <sup>3</sup>
APRIL 2018	15/05/2018	Sulphur dioxide	parts per million	Continuous	One hour	100.0%	190.2	278.2	349.2	600 ppm
APRIL 2018	15/05/2018		milligrams per cubic metre				543.5	795.2	998.0	-
APRIL 2018	15/05/2018	Opacity -Undifferentiated particles	Percent	Continuous	One hour	99.4%	0.6%	2.9%	7.7%	-
Comments:										

## Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	Samples collected and analysed	Sample value	EPL Limit mg/m <sup>3</sup>			
Jul-17	5/09/2017	Cadmium	milligrams per cubic metre	1	1	<0.0002	1.0			
Jul-17	5/09/2017	Carbon monoxide	ppm	1	1	90				
Jul-17	5/09/2017	Chlorine	milligrams per cubic metre	1	1	0.0	200			
Jul-17	5/09/2017	Copper	milligrams per cubic metre	1	1	0.0017				
Jul-17	5/09/2017	Hazardous substances (Metals)	milligrams per cubic metre	1	1	≤0.025	5			
Jul-17	5/09/2017	Hydrogen chloride	milligrams per cubic metre	1	1	17.0	100			
Jul-17	5/09/2017	Mercury	milligrams per cubic metre	1	1	0.00061	1.0			
Jul-17	5/09/2017	Nitrogen oxides	milligrams per cubic metre	1	1	650	1500			
Jul-17	5/09/2017	Solid particles	milligrams per cubic metre	1	1	48.0	100			
Jul-17	5/09/2017	Sulfuric acid mist and sulfur trioxide	milligrams per cubic metre	1	1	2.40	100			
Jul-17	5/09/2017	Sulphur dioxide	milligrams per cubic metre	1	1	750				
Jul-17	5/09/2017	Total fluoride	milligrams per cubic metre	1	1	10.0	50			
Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. This table contains the results from Boiler 4 tested on 27 July 2017										

# Monthly Data Summary

<b>Details of Non-Compliance with Licence Conditions</b>
Licence condition number not complied with
Condition L3.6
Summary of particulars of the non-compliance <b>(NO MORE THAN 50 WORDS)</b>
pH exceedance at EPL point 7 of 8.51 at 0955hrs before returning below the limit of 8.5 at 1000hrs
If required, further details on particulars of non-compliance
-
Date(s) when the non-compliance occurred, if applicable
17-Apr-18
If relevant, precise location where the non-compliance occurred (attach a map or diagram)
If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
N/A
-
Cause of non-compliance
A blocked sample line issued false readings regarding cooling tower pH during discharge from the system
Action taken or that will be taken to mitigate any adverse effects of the non-compliance
Isolation of blowdown from affected tower and rectification of discharge water quality
Action taken or that will be taken to prevent a recurrence of the non-compliance
Regular checking/cleaning of samle lines in the cooling towers