

Monthly Data Summary

BAYSWATER MONTHLY DATA SUMMARY JULY 2019

| | |
|------------------|---------------|
| LICENCE NO | 779 |
| LICENCE HOLDER | AGL Macquarie |
| REPORTING PERIOD | JULY 2019 |

A1 Licence Holder

Licence Number 779
Licence Holder AGL Macquarie
Trading Name (if applicable)
ABN 18 402 904 344

A2 Premises to which Licence Applies (if applicable)

Common Name (if any) BAYSWATER POWER STATION
Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

A3 Activities to which Licence Applies

Electricity Generation

A4 Other Activities (if applicable) Crushing, Grinding or Separating Works Aircraft (helicopter) facilities

Crushing, Grinding or Separating Works
Sewage Treatment Systems
Chemical Storage Facilities
Aircraft (helicopter) facilities

A5 Fee-Based Activity Classifications

Note that the fee based activity classification is used to calculate the administrative fee.

| Fee-based activity | Activity scale | Unit of measure |
|--|----------------|----------------------------|
| Generation of electrical power from coal | > 4,000.00 | Gwh generated |
| Chemical Storage | > 100 | Tonnes Generated or Stored |
| Coal Works | > 5000000 | Tonnes handled |

Monthly Data Summary

Discharge & Monitoring Point 1

Discharge to waters

Effluent quality and volume monitoring, Discharge from main station oil separator hoBWinng basin and Treated Process Water Pond to Tinkers Creek, shown as "EPA ID No. 1" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurment frequency | Samples collected and analysed | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|------------------------|----------------------|---------------------------------|--------------------------------|---------------------|-----------------|----------------------|-----------|
| JULY 2019 | 14/08/2019 | Oil and Grease | milligrams per litre | Fortnightly | 5 | <5 | 2.5 | <5 | 10 mg/L |
| JULY 2019 | 14/08/2019 | Total suspended solids | milligrams per litre | Fortnightly | 5 | 1.0 | 2.0 | 3.0 | 20 mg/L |
| JULY 2019 | 14/08/2019 | Volume discharge | kilolitres per week | Weekly during discharge | 4 | 0 | 11,180 | 15,705 | 36,400 kL |
| Comments: | | | | | | | | | |

Discharge & Monitoring Point 7

Discharge to waters

Effluent quality and volume monitoring, Discharge from cooling towers to Tinkers Creek, shown as "EPA ID No. 7" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurment frequency | Samples collected and analysed | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|------------------|----------------------|---------------------------------|--------------------------------|---------------------|-----------------|----------------------|------------|
| JULY 2019 | 14/08/2019 | Conductivity | uS/cm | Continuous | 0.993 | 1427.0 | 2564.6 | 3921.6 | 4500 uS/cm |
| JULY 2019 | 14/08/2019 | pH | pH Units | Continuous | 0.993 | 7.8 | 8.2 | 8.6 | 6.5 - 8.5 |
| JULY 2019 | 14/08/2019 | Volume discharge | Megalitres per month | Weekly during discharge | 8 | 276.4 | | | 840 ML |
| Comments: | | | | | | | | | |

Discharge & Monitoring Point 8

Discharge to waters

Discharge & monitoring point under the Hunter River Salinity Trading Scheme, Discharge pipe from Lake Liddel dam wall, shown as "EPA ID No. 8" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurment frequency | Samples collected and analysed | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|---|---------------------|------------------------|----------------------|---------------------------------|--------------------------------|---------------------|-----------------|----------------------|-----------|
| JULY 2019 | 14/08/2019 | Conductivity | uS/cm | Continuous during discharge | 1 | 2790.0 | 2790.0 | 2790.0 | - |
| JULY 2019 | 14/08/2019 | pH | pH Units | Daily during discharge | 1 | 8.6 | 8.6 | 8.6 | 6.5 - 8.5 |
| JULY 2019 | 14/08/2019 | Total suspended solids | milligrams per litre | Monthly | 1 | <5 | 2.5 | <5 | 30 mg/L |
| JULY 2019 | 14/08/2019 | Volume discharge | Megalitres per day | Daily during discharge | - | - | - | - | 700 ML |
| Comments: HRSTS discharge did not occur during July. Results obtained from routine monthly sampling | | | | | | | | | |

Monthly Data Summary

Discharge & Monitoring Point 17

Discharge to waters

Ravensthorpe void. Inlet point located on the Void 4 pontoon pump system

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurement frequency | Samples collected and analysed | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---|------------------------|----------------------|----------------------------------|--------------------------------|---------------------|-----------------|----------------------|-----------|
| JULY 2019 | 14/08/2019 | Conductivity | uS/cm | Continuous during discharge | 1 | 8190.0 | 8190.0 | 8190.0 | - |
| JULY 2019 | 14/08/2019 | pH | pH Units | Daily during discharge | 1 | 8.8 | 8.8 | 8.8 | 6.5 - 9.5 |
| JULY 2019 | 14/08/2019 | Total suspended solids | milligrams per litre | Monthly | 1 | <5 | 2.5 | <5 | 30 mg/L |
| JULY 2019 | 14/08/2019 | Boron | milligrams per litre | Weekly during discharge | 1 | 2.9 | 2.9 | 2.9 | 0.81 |
| JULY 2019 | 14/08/2019 | Cadmium | milligrams per litre | Weekly during discharge | 1 | 0.0 | 0.0 | 0.0 | 0.0003 |
| JULY 2019 | 14/08/2019 | Copper | milligrams per litre | Weekly during discharge | 1 | <0.001 | 0.0 | <0.001 | 0.001 |
| JULY 2019 | 14/08/2019 | Iron | milligrams per litre | Weekly during discharge | 1 | 0.0 | 0.0 | 0.0 | 0.27 |
| JULY 2019 | 14/08/2019 | Molybdenum | milligrams per litre | Weekly during discharge | 1 | 0.4 | 0.4 | 0.4 | 0.29 |
| JULY 2019 | 14/08/2019 | Nickel | milligrams per litre | Weekly during discharge | 1 | 0.0 | 0.0 | 0.0 | 0.19 |
| JULY 2019 | 14/08/2019 | Silver | milligrams per litre | Weekly during discharge | 1 | <0.0001 | 0.0 | <0.0001 | 0.0005 |
| JULY 2019 | 14/08/2019 | Volume discharge | Megalitres per day | Daily during discharge | | | | | 20 ML |
| Comments: | HRSTS discharge did not occur during July. Results obtained from routine monthly sampling | | | | | | | | |

Discharge & Monitoring Point 18

Discharge to waters

Discharge from Bayswater Ash Dam unlined flood pillway located near left abutment

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurement frequency | Samples collected and analysed | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|------------------------|----------------------|----------------------------------|--------------------------------|---------------------|-----------------|----------------------|-----------|
| JULY 2019 | 14/08/2019 | Conductivity | uS/cm | Weekly during discharge | 0 | | | | - |
| JULY 2019 | 14/08/2019 | pH | pH Units | Weekly during discharge | 0 | | | | 6.5 - 9.5 |
| JULY 2019 | 14/08/2019 | Total suspended solids | milligrams per litre | Weekly during discharge | 0 | | | | 30 mg/L |
| JULY 2019 | 14/08/2019 | Boron | milligrams per litre | Weekly during discharge | 0 | | | | 0.81 |
| JULY 2019 | 14/08/2019 | Cadmium | milligrams per litre | Weekly during discharge | 0 | | | | 0.0003 |
| JULY 2019 | 14/08/2019 | Copper | milligrams per litre | Weekly during discharge | 0 | | | | 0.001 |

Monthly Data Summary

| | | | | | | | | | |
|-----------|-------------------------------------|------------|----------------------|-------------------------|---|--|--|--|--------|
| JULY 2019 | 14/08/2019 | Iron | milligrams per litre | Weekly during discharge | 0 | | | | 0.27 |
| JULY 2019 | 14/08/2019 | Molybdenum | milligrams per litre | Weekly during discharge | 0 | | | | 0.29 |
| JULY 2019 | 14/08/2019 | Nickel | milligrams per litre | Weekly during discharge | 0 | | | | 0.19 |
| JULY 2019 | 14/08/2019 | Silver | milligrams per litre | Weekly during discharge | 0 | | | | 0.0005 |
| Comments: | Discharge did not occur during July | | | | | | | | |

Monthly Data Summary

Discharge & Monitoring Point 10

Discharge to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 10" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurement frequency | Averaging period | Data capture % | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|-------------------------------------|----------------------------|----------------------------------|------------------|----------------|---------------------|-----------------|----------------------|------------------------|
| JULY 2019 | 14/08/2019 | Nitrogen Oxides | parts per million | Continuous | One hour | 98.7% | 100.3 | 185.6 | 272.1 | - |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 205.8 | 381.0 | 558.4 | 1500 mg/m ³ |
| JULY 2019 | 14/08/2019 | Sulphur dioxide | parts per million | Continuous | One hour | 100.0% | 106.3 | 160.3 | 216.3 | 600 ppm |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 303.7 | 458.0 | 618.1 | - |
| JULY 2019 | 14/08/2019 | Opacity -Undifferentiated particles | Percent | Continuous | One hour | 100.0% | 2.3% | 4.4% | 18.2% | - |
| Comments: | | | | | | | | | | |

Annual monitoring of discharges to air

Air emission monitoring, Boiler 1 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easments, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | No. of samples required by licence | Samples collected and analysed | Sample value | EPL Limit mg/m ³ |
|--|---------------------|--|----------------------------|------------------------------------|--------------------------------|--------------|-----------------------------|
| Oct-18 | 26/11/2018 | Cadmium | milligrams per cubic metre | 1 | 1 | <0.0002 | 1.0 |
| Oct-18 | 26/11/2018 | Carbon monoxide | ppm | 1 | 1 | 4 | |
| Oct-18 | 26/11/2018 | Chlorine | milligrams per cubic metre | 1 | 1 | 0.0 | 200 |
| Oct-18 | 26/11/2018 | Copper | milligrams per cubic metre | 1 | 1 | 0.0013 | |
| Oct-18 | 26/11/2018 | Hazardous Substances (Metals) | milligrams per cubic metre | 1 | 1 | ≤0.016 | 5 |
| Oct-18 | 26/11/2018 | Hydrogen chloride | milligrams per cubic metre | 1 | 1 | 11.0 | 100 |
| Oct-18 | 26/11/2018 | Mercury | milligrams per cubic metre | 1 | 1 | 0.00100 | 1.0 |
| Oct-18 | 26/11/2018 | Nitrogen oxides | milligrams per cubic metre | 1 | 1 | 860 | 1500 |
| Oct-18 | 26/11/2018 | Solid particles | milligrams per cubic metre | 1 | 1 | 15.0 | 100 |
| Oct-18 | 26/11/2018 | Sulfuric acid mist and sulfur trioxide | milligrams per cubic metre | 1 | 1 | 3.10 | 100 |
| Oct-18 | 26/11/2018 | Sulphur dioxide | milligrams per cubic metre | 1 | 1 | 930 | |
| Oct-18 | 26/11/2018 | Total fluoride | milligrams per cubic metre | 1 | 1 | 8.5 | 50 |
| Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. | | | | | | | |

Monthly Data Summary

Discharge & Monitoring Point 11

Discharge to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 11" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurement frequency | Averaging period | Data capture % | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|-------------------------------------|----------------------------|----------------------------------|------------------|----------------|---------------------|-----------------|----------------------|------------------------|
| JULY 2019 | 14/08/2019 | Nitrogen Oxides | parts per million | Continuous | One hour | 100.0% | 124.1 | 213.1 | 269.5 | - |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 254.7 | 437.4 | 553.3 | 1500 mg/m ³ |
| JULY 2019 | 14/08/2019 | Sulphur dioxide | parts per million | Continuous | One hour | 100.0% | 143.7 | 194.3 | 272.2 | 600 ppm |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 410.6 | 555.4 | 778.0 | - |
| JULY 2019 | 14/08/2019 | Opacity -Undifferentiated particles | Percent | Continuous | One hour | 100.0% | 2.6% | 5.3% | 9.9% | - |
| Comments: | | | | | | | | | | |

Annual monitoring of discharges to air

Air emission monitoring, Boiler 2 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | No. of samples required by licence | Samples collected and analysed | Sample value | EPL Limit mg/m ³ |
|--|---------------------|--|----------------------------|------------------------------------|--------------------------------|--------------|-----------------------------|
| Oct-18 | 26/11/2018 | Cadmium | milligrams per cubic metre | 1 | 1 | <0.0002 | 1.0 |
| Oct-18 | 26/11/2018 | Carbon monoxide | ppm | 1 | 1 | <2 | |
| Oct-18 | 26/11/2018 | Chlorine | milligrams per cubic metre | 1 | 1 | 0.0 | 200 |
| Oct-18 | 26/11/2018 | Copper | milligrams per cubic metre | 1 | 1 | 0.0008 | |
| Oct-18 | 26/11/2018 | Hazardous substances (Metals) | milligrams per cubic metre | 1 | 1 | ≤0.038 | 5 |
| Oct-18 | 26/11/2018 | Hydrogen chloride | milligrams per cubic metre | 1 | 1 | 8.5 | 100 |
| Oct-18 | 26/11/2018 | Mercury | milligrams per cubic metre | 1 | 1 | 0.00160 | 1.0 |
| Oct-18 | 26/11/2018 | Nitrogen oxides | milligrams per cubic metre | 1 | 1 | 760 | 1500 |
| Oct-18 | 26/11/2018 | Solid particles | milligrams per cubic metre | 1 | 1 | 17.0 | 100 |
| Oct-18 | 26/11/2018 | Sulfuric acid mist and sulfur trioxide | milligrams per cubic metre | 1 | 1 | 3.10 | 100 |
| Oct-18 | 26/11/2018 | Sulphur dioxide | milligrams per cubic metre | 1 | 1 | 760 | |
| Oct-18 | 26/11/2018 | Total fluoride | milligrams per cubic metre | 1 | 1 | 5.9 | 50 |
| Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. | | | | | | | |

Monthly Data Summary

Discharge & Monitoring Point 12

Discharge to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurement frequency | Averaging period | Data capture % | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|-------------------------------------|----------------------------|----------------------------------|------------------|----------------|---------------------|-----------------|----------------------|------------------------|
| JULY 2019 | 14/08/2019 | Nitrogen Oxides | parts per million | Continuous | One hour | 99.7% | 109.6 | 341.4 | 507.2 | - |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 225.0 | 700.7 | 1041.0 | 1500 mg/m ³ |
| JULY 2019 | 14/08/2019 | Sulphur dioxide | parts per million | Continuous | One hour | 99.8% | 167.8 | 331.7 | 445.4 | 600 ppm |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 479.5 | 947.9 | 1272.9 | - |
| JULY 2019 | 14/08/2019 | Opacity -Undifferentiated particles | Percent | Continuous | One hour | 100.0% | 2.1% | 5.4% | 10.9% | - |
| Comments: | | | | | | | | | | |

Annual monitoring of discharges to air

Air emission monitoring, Boiler 3 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | No. of samples required by licence | Samples collected and analysed | Sample value | EPL Limit mg/m ³ |
|--|---------------------|--|----------------------------|------------------------------------|--------------------------------|--------------|-----------------------------|
| Apr-19 | 9/05/2019 | Cadmium | milligrams per cubic metre | 1 | 1 | <0.0002 | 1.0 |
| Apr-19 | 9/05/2019 | Carbon monoxide | ppm | 1 | 1 | <2 | |
| Apr-19 | 9/05/2019 | Chlorine | milligrams per cubic metre | 1 | 1 | 0.0 | 200 |
| Apr-19 | 9/05/2019 | Copper | milligrams per cubic metre | 1 | 1 | 0.0007 | |
| Apr-19 | 9/05/2019 | Hazardous substances (Metals) | milligrams per cubic metre | 1 | 1 | ≤0.011 | 5 |
| Apr-19 | 9/05/2019 | Hydrogen chloride | milligrams per cubic metre | 1 | 1 | 9.3 | 100 |
| Apr-19 | 9/05/2019 | Mercury | milligrams per cubic metre | 1 | 1 | 0.00081 | 1.0 |
| Apr-19 | 9/05/2019 | Nitrogen oxides | milligrams per cubic metre | 1 | 1 | 710 | 1500 |
| Apr-19 | 9/05/2019 | Solid particles | milligrams per cubic metre | 1 | 1 | 7.5 | 100 |
| Apr-19 | 9/05/2019 | Sulfuric acid mist and sulfur trioxide | milligrams per cubic metre | 1 | 1 | 0.76 | 100 |
| Apr-19 | 9/05/2019 | Sulphur dioxide | milligrams per cubic metre | 1 | 1 | 1100 | |
| Apr-19 | 9/05/2019 | Total fluoride | milligrams per cubic metre | 1 | 1 | 7.6 | 50 |
| Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. | | | | | | | |

Monthly Data Summary

Discharge & Monitoring Point 13

Discharge to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 12" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | Sampling / measurement frequency | Averaging period | Data capture % | Lowest sample value | Mean of samples | Highest sample value | EPL Limit |
|-----------|---------------------|-------------------------------------|----------------------------|----------------------------------|------------------|----------------|---------------------|-----------------|----------------------|------------------------|
| JULY 2019 | 14/08/2019 | Nitrogen Oxides | parts per million | Continuous | One hour | 99.5% | 140.5 | 293.9 | 392.2 | - |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 288.5 | 603.2 | 805.0 | 1500 mg/m ³ |
| JULY 2019 | 14/08/2019 | Sulphur dioxide | parts per million | Continuous | One hour | 99.5% | 190.7 | 264.5 | 359.9 | 600 ppm |
| JULY 2019 | 14/08/2019 | | milligrams per cubic metre | | | | 545.0 | 755.9 | 1028.7 | - |
| JULY 2019 | 14/08/2019 | Opacity -Undifferentiated particles | Percent | Continuous | One hour | 100.0% | 3.4% | 6.3% | 11.3% | - |
| Comments: | | | | | | | | | | |

Annual monitoring of discharges to air

Air emission monitoring, Boiler 4 stack emissions, shown as "EPA ID No. 13" on plan titled "Bayswater Power Station Unit 1-4, Open Space, Easements, Site Survey" dated 24/12/2004.

| Month | Date of Publication | Pollutant | Unit of measure | No. of samples required by licence | Samples collected and analysed | Sample value | EPL Limit mg/m ³ |
|--|---------------------|--|----------------------------|------------------------------------|--------------------------------|--------------|-----------------------------|
| Mar-19 | 13/05/2019 | Cadmium | milligrams per cubic metre | 1 | 1 | <0.0002 | 1.0 |
| Mar-19 | 13/05/2019 | Carbon monoxide | ppm | 1 | 1 | <3 | |
| Mar-19 | 13/05/2019 | Chlorine | milligrams per cubic metre | 1 | 1 | 0.0 | 200 |
| Mar-19 | 13/05/2019 | Copper | milligrams per cubic metre | 1 | 1 | 0.0007 | |
| Mar-19 | 13/05/2019 | Hazardous substances (Metals) | milligrams per cubic metre | 1 | 1 | ≤0.032 | 5 |
| Mar-19 | 13/05/2019 | Hydrogen chloride | milligrams per cubic metre | 1 | 1 | 3.8 | 100 |
| Mar-19 | 13/05/2019 | Mercury | milligrams per cubic metre | 1 | 1 | 0.00120 | 1.0 |
| Mar-19 | 13/05/2019 | Nitrogen oxides | milligrams per cubic metre | 1 | 1 | 860 | 1500 |
| Mar-19 | 13/05/2019 | Solid particles | milligrams per cubic metre | 1 | 1 | 15.0 | 100 |
| Mar-19 | 13/05/2019 | Sulfuric acid mist and sulfur trioxide | milligrams per cubic metre | 1 | 1 | 5.20 | 100 |
| Mar-19 | 13/05/2019 | Sulphur dioxide | milligrams per cubic metre | 1 | 1 | 960 | |
| Mar-19 | 13/05/2019 | Total fluoride | milligrams per cubic metre | 1 | 1 | 5.3 | 50 |
| Comments: Monitoring of emission from each of the 4 boilers for the substances in this table is required annually. | | | | | | | |

Monthly Data Summary

| Details of Non-Compliance with Licence Conditions | |
|--|--|
| Licence condition number not complied with | |
| Condition L3.6 | |
| Summary of particulars of the non-compliance (NO MORE THAN 50 WORDS) | |
| On 26 July 2019 at approximately 19:30hrs EPL point 7 exceeded the pH limit of 8.5, recording a high of pH 8.58 at 19:45hrs. pH returned below 8.5 at 20:10. There was no actual or material environmental harm. | |
| If required, further details on particulars of non-compliance | |
| - | |
| Date(s) when the non-compliance occurred, if applicable | |
| 26-Jul-19 | |
| If relevant, precise location where the non-compliance occurred (attach a map or diagram) | |
| - | |
| If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance | |
| - | |
| Cause of non-compliance | |
| No immediate cause could be determined during the site investigation | |
| Action taken or that will be taken to mitigate any adverse effects of the non-compliance | |
| Blowdown on cooling towers was applied to manage water quality | |
| Action taken or that will be taken to prevent a recurrence of the non-compliance | |
| Continued monitoring and management of discharge. | |