LIDDELL MONTHLY DATA SUMMARY JANUARY 2015

LICENCE NO	2122
LICENCE HOLDER	AGL MACQUARIE
REPORTING PERIOD	01 / 01/2015 to 31 /01/2015

A1 Licence Holder

Licence Number 2122

Licence Holder AGL MACQUARIE

Trading Name (if applicable)

ABN 18 167 859 494

A2 Premises to which Licence Applies (if applicable)

Common Name (if any) LIDDELL POWER STATION

Premises NEW ENGLAND HIGHWAY MUSWELLBROOK NSW 2333

A3 Activities to which Licence Applies

Electricity Generating Works

Coal Works

A4 Other Activities (if applicable)

Helicopter-related facilities

Chemical storage

Operation of Emergency 1.5 MW diesel generator

Operation of Gas turbine

Sewage treatment

Waste storage

A5 Fee-Based Activity Classifications

Note that the fee based activity classification is used to calculate the administrative fee.						
Fee-based activity	Activity scale	Unit of measure				
Coal works	> 5,000,000.00	T handled				
Generation of electrical power from coal	> 4,000.00	Gwh generated				

Licence 2122 Page 1

Discharge & Monitoring Point 7 301204 East 6416350 North

Discharge to Air

In the flue gases of unit 1boiler labelled as "Unit 1 Boiler 1-2 Chimney Stack" on plan no. LD 800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Jan-15	15/02/2015	Nitrogen Oxides	milligrams per cubic meter	Continuous		-	-	-	1500	Note
Jan-15	15/02/2015	Nillogen Oxides	parts per million			-	-	-	700	Note
Jan-15	15/02/2015		milligrams per cubic metre		_	-	=	-	1600	Note
Jan-15	15/02/2015	Sulphur dioxide	parts per million	Continuous	-	-	-	-	600	Note
Jan-15	15/02/2015	Opacity	percent %	Continuous	-	-	-	-	20.0%	Note

Note - Unit 1 out of service for entire monitoring period

Discharge & Monitoring Point 8

301204 East 6416350 North

In the flue gases of unit 2 boiler labelled as "Unit 2 Boiler 1-2 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Jan-15	15/02/2015	Nitrogen Oxides	milligrams per cubic meter	Continuous	>99%	238	645	767	1500	Note
Jan-15	15/02/2015		parts per million	Continuous	2370	116	314	374	700	Note
Jan-15	15/02/2015	- Sulphur dioxide	milligrams per cubic metre	Continuous	>99%	799	1083	1374	1600	Note
Jan-15	15/02/2015		parts per million	Continuous	25376	280	379	481	600	Note
Jan-15	15/02/2015	Opacity	percent %	Continuous	>99%	0.3	1.5	3.5	20.0%	Note

Comments:

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Licence 2122 Page 2

Discharge & Monitoring Point 9

301204 East 6416350 North

In the flue gases of unit 3 boiler labelled as "Unit 3 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Jan-15	15/02/2015	- Nitrogen Oxides	milligrams per cubic meter	Continuous	>99%	260	602	752	1500	Note
Jan-15	15/02/2015		parts per million	Continuous	>99/6	127	293	366	700	Note
Jan-15	15/02/2015	0.1.1	milligrams per cubic metre	Continuous	>99%	815	1101	1362	1600	Note
Jan-15	15/02/2015	Sulphur dioxide	parts per million	Continuous	>33/6	285	385	476	600	Note
Jan-15	15/02/2015	Opacity	percent %	Continuous	>99%	3.4	6.8	9.7	20.0%	Note

Comments:

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Discharge & Monitoring Point 10

301204 East 6416350 North

In the flue gases of unit 4 boiler labelled as "Unit 4 Boiler 3-4 Chimney Stack" on plan no LD800474 amended 03 and dated 6/5/2003

Month	Date of Publication	Pollutant	Unit of measure	No. of samples required by licence	No. of samples you collected and analysed	Lowest sample value	Mean of sample	Highest sample value	EPL Limit	Notes
Jan-15	15/02/2015	Nitrogen Oxides	milligrams per cubic meter	Continuous	>99%	235	589	750	1500	Note 1
Jan-15	15/02/2015		parts per million			115	287	365	700	Note1
Jan-15	15/02/2015	- Sulphur dioxide	milligrams per cubic metre	Continuous	>99%	962	1153	1421	1600	Note 1
Jan-15	15/02/2015		parts per million	Continuous	>33 /6	337	403	497	600	Note 1
Jan-15	15/02/2015	Solid Particles	percent Opacity	Continuous	>99%	1.8	4.1	8.1	20.0%	Note 1

Comments:

Note - Results from continuous emission monitor located on chimney stack, as part of EPL 2122

Licence 2122 Page 3

C2	Details of Non-Compliance with Licence
	Nil
	Summary of particulars of the non-compliance (NO MORE THAN 50 WORDS)
	NA
	If required, further details on particulars of non-compliance
	NA
	Date(s) when the non-compliance occurred, if applicable
	NA
	If applicable, registration numbers of any vehicles or the chassis number of any mobile plant involved in the non-compliance
	NA
	Cause of non-compliance
	NA
	Action taken or that will be taken to mitigate any adverse effects of the non-compliance
	NA
	Action taken or that will be taken to prevent a recurrence of the non-compliance
	NA NA

Licence 2122 Page 4