

Correction Notice.

Annual Environmental Performance Report 2008-09 Correction Notice

Page 33 of the 2008-09 Annual Environmental Performance Report incorrectly states the following:

Rosalind Park Gas Plant - Continuous Monitoring

The licence requirement (M2.1) and DA-282-6-2003-i Schedule 4 Consent Condition 58 to provide continuous monitoring of NOx, temperature, flow rate, moisture and oxygen at Point 1, 2, and 3 was successfully undertaken in 2008/2009.

This statement is incorrect. During the reporting year, continuous monitoring was intermittent due to equipment limitations and breakdowns experienced in that year.

Results from the monitoring successfully carried undertaken are kept on file at the RPGP.

Page 35 of the 2008-09 Annual Environmental Performance Report states:

Nitrogen Oxides Generation of Gas Engines

Nitrogen oxide levels complied with the licence limits for all monitoring points throughout the reporting period.

This statement relates to the quarterly monitoring results only.

Energy in
action.®

AGL