

Energy in  
action.™



**AGL UPSTREAM INVESTMENTS PTY LTD  
ROSALIND PARK GAS PLANT  
Quarterly Air Monitoring Report**

Reporting Period: 1<sup>st</sup> Quarter – March 2017

AGL Upstream Investments Pty Ltd

ABN 58 115 063 744

Locked Bag 1837, St Leonards NSW 2065

200 George Street, Sydney, NSW 2000

Telephone: 02 9921 2999 Facsimile: 02 9921 2474

Complaints Line (24 hours): 1300 799 716



# Foreword

<b>PREMISES</b>	Rosalind Park Gas Plant Lot 35 Medhurst Road GILEAD NSW 2560
<b>LICENCE DETAILS</b>	<a href="#">Environment Protection Licence 12003</a>
<b>LICENCEE</b>	AGL Upstream Investments Pty Limited
<b>LICENCEE'S ADDRESS</b>	Locked Bag 1837, St Leonards, NSW 2065
<b>MONITORING DATE</b>	1 <sup>st</sup> Quarter – 23 and 24 March 2017
<b>MONITORING BY</b>	Ektimo
<b>ANALYSIS BY</b>	Ektimo (laboratory report number R003406)
<b>OBTAINED DATA DATE</b>	13 April 2017 (Ektimo Report R003406)
<b>REPORT DATE</b>	19 April 2017
<b>REPORT PREPARED BY</b>	Aaron Clifton Environment Business Partner

## SUMMARY OF ACTIVITY

Rosalind Park Gas Plant, located approximately 60km south west of Sydney, is a natural gas processing and treatment plant, used to process coal seam natural gas from the Camden Gas Project.

Produced natural gas is cleaned, dehydrated, compressed and odourised before being measured and transported by pipeline about 500 metres into the nearby Moomba to Sydney Natural Gas Pipeline. The premises are covered by Environment Protection Licence 12003 which includes all gas wells, gas gathering, reticulation systems, trunk lines and associated effluent storage areas and work areas of the Camden Gas Project.



This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of the Environment Protection Licence. The Licence conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.

This report sets out the results of quarterly monitoring. A separate report is issued for continuous monitoring.

This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, October 2013) (**Publication Requirements**).

## AIR MONITORING LOCATIONS

Point	Location	Monitoring Frequency
1	Exhaust Stack 1 on Compression Engine 1	Quarterly
2	Exhaust Stack 2 on Compression Engine 2	Quarterly
3	Exhaust Stack 3 on Compression Engine 3	Quarterly
4	Reboiler Flue	Quarterly
5	Reflux Column Vent	Quarterly
6	Carbon Scrubber Vent	Quarterly

Note: monitoring is only undertaken when the compression engines are running.

## AIR MONITORING TEST METHODS – POINTS 1, 2, 3, 4 and 5

Parameter	NSW EPA Test Method (Sampling Method)
Carbon dioxide	TM-24
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Nitrogen Oxides	TM-11
Oxygen (O <sub>2</sub> )	TM-25
Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	TM-3
Sulphur dioxide	TM-4
Temperature	TM-2
Velocity	TM-2
Volumetric flowrate	TM-2



## AIR MONITORING TEST METHODS – POINT 6

<b>Parameter</b>	<b>NSW EPA Test Method (Sampling Method)</b>
Carbon dioxide	TM-24
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Odour	OM-7
Oxygen (O <sub>2</sub> )	TM-25
Temperature	TM-2
Velocity	TM-2
Volumetric flowrate	TM-2



## Air Monitoring Results

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
1	Compressor Engine 1  (Sampled 23 March 2017)	Carbon dioxide	Percent		TM-24	Quarterly	4.9	Not applicable
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.31	Not applicable
		Moisture	Percent		TM-22	Quarterly	7.7	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29.4	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	330	461
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Quarterly	11.7	Not applicable
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Quarterly	0.095	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<5	7
		Temperature	Degrees Celsius		TM-2	Quarterly	365	Not applicable
		Velocity	Metres per second		TM-2	Quarterly	27	Not applicable
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	3.1	Not applicable

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
2	Compressor Engine 2  (Sampled 24 March 2017)	Carbon dioxide	Percent		TM-24	Quarterly	10.8	Not applicable
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.33	Not applicable
		Moisture	Percent		TM-22	Quarterly	14	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29.9	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	18	461
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Quarterly	0.6	Not applicable
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Quarterly	0.025	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<5	7
		Temperature	Degrees Celsius		TM-2	Quarterly	359	Not applicable
		Velocity	Metres per second		TM-2	Quarterly	13	Not applicable
Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.55	Not applicable		



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
3	Compressor Engine 3  (Sampled 23 March 2017)	Carbon dioxide	Percent		TM-24	Quarterly	11.1	Not applicable
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.34	Not applicable
		Moisture	Percent		TM-22	Quarterly	14	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29.9	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	52	461
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Quarterly	0.7	Not applicable
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Quarterly	<0.02	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<5	7
		Temperature	Degrees Celsius		TM-2	Quarterly	354	Not applicable
		Velocity	Metres per second		TM-2	Quarterly	12	Not applicable
	Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.52	Not applicable	



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
4	Reboiler Flue (Sampled 23 March 2017)	Carbon dioxide	Percent		TM-24	Quarterly	3.7	Not applicable
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.31	Not applicable
		Moisture	Percent		TM-22	Quarterly	9.8	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29.3	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	84	110
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Quarterly	13.9	Not applicable
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Quarterly	<0.01	3.5
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<5	35
		Temperature	Degrees Celsius		TM-2	Quarterly	249	Not applicable
		Velocity	Metres per second		TM-2	Quarterly	3	Not applicable
Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.076	Not applicable		





Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
5	Reflux Column Vent  (Sampled 23 March 2017)	Carbon dioxide	Percent		TM-24	Quarterly	13.8	Not applicable
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.35	Not applicable
		Moisture	Percent		TM-22	Quarterly	49	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	30.4	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	<2	13
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Quarterly	<0.4	Not applicable
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Quarterly	<0.06	35
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<5	1042
		Temperature	Degrees Celsius		TM-2	Quarterly	83	Not applicable
		Velocity	Metres per second		TM-2	Quarterly	<2	Not applicable
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	<0.006	Not applicable



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
6	Carbon Scrubber Vent  (Sampled 23 March 2017)	Carbon dioxide	Percent		TM-24	Quarterly	<0.3	Not applicable
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.29	Not applicable
		Moisture	Percent		TM-22	Quarterly	1.2	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29	Not applicable
		Odour	Odour Units		OM-7	Quarterly	59	Not applicable
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Quarterly	20.9	Not applicable
		Temperature	Degrees Celsius		TM-2	Quarterly	26	Not applicable
		Velocity	Metres per second		TM-2	Quarterly	7	Not applicable
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.18	Not applicable