

AGL UPSTREAM INVESTMENTS PTY LTD ROSALIND PARK GAS PLANT Air Monitoring Report

Reporting Period: September 2013

AGL Upstream Investments Pty Ltd
ABN 58 115 063 744
Locked Bag 1837, St Leonards NSW 2065
Level 22, 101 Miller Street, North Sydney NSW 2060
Telephone: 02 9921 2999 Facsimile: 02 9921 2474

Complaints Line (24 hours): 02 9963 1318



Foreword

PREMISES Rosalind Park Gas Plant

Lot 35 Medhurst Road GILEAD NSW 2560

LICENCE DETAILS Environment Protection Licence 12003

LICENCEE AGL Upstream Investments Pty Limited

LICENCEE'S ADDRESS Locked Bag 1837, North Sydney, NSW 2060

REPORTING PERIOD 01 September to 30 September 2013

REPORT DATE 11 October 2013

REPORT PREPARED BY Aaron Clifton

Environmental Manager

SUMMARY OF ACTIVITY

Rosalind Park Gas Plant, located approximately 60km south west of Sydney, is a natural gas processing and treatment plant, used to process coal seam natural gas from the Camden Gas Project.

Produced natural gas is cleaned, dehydrated, compressed and odourised before being measured and transported by pipeline about 500 metres into the nearby Moomba to Sydney Natural Gas Pipeline. The premises covered by this Environment Protection Licence also includes all gas wells, gas gathering, reticulation systems, trunk lines and associated effluent storage areas and work areas of the Camden Gas Project.

This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of the Environment Protection Licence. The Licence conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.

This report sets out the results of continuous monitoring summarized on a monthly basis. A separate report is issued for quarterly monitoring.



This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, March 2012) (**Publication Requirements**).

AIR MONITORING LOCATIONS

Point	Location	Monitoring Frequency		
1	Exhaust Stack 1 on Compression Engine 1	Continuous		
2	Exhaust Stack 2 on Compression Engine 2	Continuous		
3	Exhaust Stack 3 on Compression Engine 3	Continuous		

Note: monitoring is only undertaken when the compression engines are running.

AIR MONITORING TEST METHODS

Parameter	NSW EPA Test Method (Sampling Method)	Reference Method		
Oxides of Nitrogen	CEM-2	USEPA Performance Specification 2		
Temperature	TM-2	USEPA Method 2		
Moisture content	TM-22	USEPA Method 4		
Volumetric Flow Rate	CEM-6	USEPA Performance Specification 6		
Oxygen	CEM-3	USEPA Performance Specification 3		

USEPA Method refers to the US Environmental Protection Agency 2000, Code of Federal Regulations, Title 40, Part 60, Appendix A Methods.

USEPA Performance Specification refers to the US Environmental Protection Agency 2000, Code of Federal Regulations, Title 40, Part 60, Appendix B, Performance Specifications.



Air Monitoring Results

Continuous monitoring results are based on test results obtained over a one-hour averaging period as set out in Schedule 5 of the *Protection of the Environment Operations (Clean Air) Regulation* 2010 (NSW).

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Number of times measured during sampling period	Minimum value	Average value	Maximum value	Concentration limit
1	Compressor Engine 1	Oxides of Nitrogen	milligrams per cubic metre	7% oxygen	CEM-2	Continuous	Compressor Engine 1 operated from 1-14, 16-18 and 20-30	239	304	399	461
		Temperature	degrees Celsius		TM-2	Continuous	September. See Note 1.	302	321	338	
		Moisture	percent		See Note 2	Continuous		5.6	7.2	9.8	
		Volumetric flow rate	cubic metres per second		CEM-6	Continuous		2.6	2.8	3.0	
		Oxygen	percent		CEM-3	Continuous		12.3	12.7	13.2	
2	Compressor Engine 2	Oxides of Nitrogen	milligrams per cubic metre	7% oxygen	CEM-2	Continuous	The CEMS of Compressor Engine 2 was operating on 5,	115	147	183	461
		Temperature	degrees Celsius		TM-2	Continuous	6, 14-30 September for 45 minutes of	400	463	509	
	V	Moisture	percent		TM-22	Continuous	every one hour period. The remaining	See Note 3	See Note 3	See Note 3	
		Volumetric flow rate	cubic metres per second		CEM-6	Continuous	15 minute period was down time for cleaning purposes. See Note 3.	See Note 3	See Note 3	See Note 3	
		Oxygen	percent		CEM-3	Continuous	See Note 3.	0.38	0.48	0.60	



3	Compressor Engine 3	Oxides of Nitrogen	milligrams per cubic metre	7% oxygen	CEM-2	Continuous	The CEMS of Compressor Engine 3	28	82	231	461
		Temperature	degrees Celsius	, ,	TM-2	Continuous	was operating from 1-22 and 25	299	430	529	
		Moisture	percent		TM-22	Continuous	September for 45 minutes of every one	See Note 4	See Note 4	See Note 4	
		Volumetric flow rate	cubic metres per second		CEM-6	Continuous	hour period. The remaining 15 minute	See Note 4	See Note 4	See Note 4	
							period was down time for cleaning purposes.				
		Oxygen	percent		CEM-3	Continuous	See Note 4.	0.55	0.75	0.96	



Notes:

In accordance with Section 3.4.1 of the EPA Publication Requirements, the
following data points have not been included for Monitoring Point 1
(Compressor #1 exhaust stack) as AGL knows that the data collected is
incorrect. The data is incorrect because the component of the equipment
measuring the relevant parameter has either failed or was not operating.
AGL has taken and is currently taking actions to rectify the issue (e.g.
replacement of failed components of measuring equipment).

	Approximate total	
Date	hours	Pollutant
10.09.2013	2	Oxides of Nitrogen, Moisture
10.09.2013	1	Oxygen
14.09.2013	1	Oxides of Nitrogen, Moisture

- 2. The test method specified for Moisture (TM-22) refers to manual stack sampling methods. Moisture is measured on a continuous basis with the CEMS manufacturer's Opsis analyser and verified during RATA and on a periodic basis by the stack sampling team by means of TM-22.
 - The CEMS for monitoring point 1 is built and tested against a known moisture concentration, and calibrated by reference to TM-22. The CEMS' continuous moisture quality measurement is undertaken based on an equivalent method, being certified according to European standards for continuous emission monitoring.
- 3. In accordance with Section 3.4.1 of the EPA Publication Requirements, the following data points have not been included for Monitoring Point 2 (Compressor #2 exhaust stack) as AGL knows that the data collected is incorrect. The data is incorrect because the component of the equipment measuring the relevant parameter has either failed or was not operating. AGL has taken and is currently taking actions to rectify the issue (e.g. replacement of failed components of measuring equipment).

Approximate to hours		Pollutant
5,6,14-30.09.2013	463	Volumetric Flow Rate, Moisture

4. In accordance with Section 3.4.1 of the EPA Publication Requirements, the following data points have not been included for Monitoring Point 3 (Compressor #3 exhaust stack) as AGL knows that the data collected is incorrect. The data is incorrect because the component of the equipment measuring the relevant parameter has either failed or was not operating. AGL has taken and is currently taking actions to rectify the issue (e.g. replacement of failed components of measuring equipment).

	Approximate total				
Date	hours	Pollutant			
01-22, 25.09.2013	453	Volumetric Flow Rate, Moisture			
5,6,7,10.09.2013	12	Oxides of Nitrogen			