

Energy in  
action.™



**AGL UPSTREAM INVESTMENTS PTY LTD  
ROSALIND PARK GAS PLANT  
Quarterly Air Monitoring Report**

Reporting Period: 1<sup>st</sup> Quarter – March 2014

AGL Upstream Investments Pty Ltd

ABN 58 115 063 744

Locked Bag 1837, St Leonards NSW 2065

Level 22, 101 Miller Street, North Sydney NSW 2060

Telephone: 02 9921 2999 Facsimile: 02 9921 2474

Complaints Line (24 hours): 02 9963 1318



## Foreword

<b>PREMISES</b>	Rosalind Park Gas Plant Lot 35 Medhurst Road GILEAD NSW 2560
<b>LICENCE DETAILS</b>	<a href="#"><u>Environment Protection Licence 12003</u></a>
<b>LICENCEE</b>	AGL Upstream Investments Pty Limited
<b>LICENCEE'S ADDRESS</b>	Locked Bag 1837, St Leonards, NSW 2065
<b>MONITORING DATE</b>	1 <sup>st</sup> Quarter – 13 and 19 March 2014
<b>MONITORING BY</b>	Emission Testing Consultants (Report 140108r, 23 April 2014)
<b>REPORT DATE</b>	02 May 2014
<b>REPORT PREPARED BY</b>	Aaron Clifton Environmental Manager

### SUMMARY OF ACTIVITY

Rosalind Park Gas Plant, located approximately 60km south west of Sydney, is a natural gas processing and treatment plant, used to process coal seam natural gas from the Camden Gas Project.

Produced natural gas is cleaned, dehydrated, compressed and odourised before being measured and transported by pipeline about 500 metres into the nearby Moomba to Sydney Natural Gas Pipeline. The premises covered by this Environment Protection Licence also includes all gas wells, gas gathering, reticulation systems, trunk lines and associated effluent storage areas and work areas of the Camden Gas Project.

This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of the Environment Protection Licence. The Licence



conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.

This report sets out the results of quarterly monitoring. A separate report is issued for continuous monitoring.

This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, March 2012) (**Publication Requirements**).

## AIR MONITORING LOCATIONS

Point	Location	Monitoring Frequency
1	Exhaust Stack 1 on Compression Engine 1	Quarterly
2	Exhaust Stack 2 on Compression Engine 2	Quarterly
3	Exhaust Stack 3 on Compression Engine 3	Quarterly
4	Reboiler Flue	Quarterly
5	Reflux Column Vent	Quarterly
6	Carbon Scrubber Vent	Quarterly

## AIR MONITORING TEST METHODS – POINTS 1, 2, 3, 4, 5

Parameter	NSW EPA Test Method (Sampling Method)
Carbon dioxide	TM-24
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Nitrogen Oxides	TM-11
Oxygen (O <sub>2</sub> )	TM-25
Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	TM-3
Sulphur dioxide	TM-4
Temperature	TM-2



Velocity	TM-2
Volumetric flowrate	TM-2

## AIR MONITORING TEST METHODS – POINT 6

Parameter	NSW EPA Test Method (Sampling Method)
Carbon dioxide	TM-24
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Odour	OM-7
Oxygen (O <sub>2</sub> )	TM-25
Temperature	TM-2
Velocity	TM-2
Volumetric flowrate	TM-2



## Air Monitoring Results

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
1	Compressor Engine 1	Carbon dioxide	Percent		TM-24	Quarterly	No Result*	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	No Result*	
		Moisture	Percent		TM-22	Quarterly	No Result*	
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	No Result*	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	No Result*	461
		Oxygen (O2)	Percent		TM-25	Quarterly	No Result*	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	No Result*	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	No Result*	7
		Temperature	Degrees Celsius		TM-2	Quarterly	No Result*	
		Velocity	Metres per second		TM-2	Quarterly	No Result*	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	No Result*	

\*Due to mechanical issues, Compressor Engine 1 was not operating during the 1<sup>st</sup> quarter 2014.

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
2	Compressor Engine 2	Carbon dioxide	Percent		TM-24	Quarterly	11.6	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.3	
		Moisture	Percent		TM-22	Quarterly	18	
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	30	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	83	461
		Oxygen (O2)	Percent		TM-25	Quarterly	0.51	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	<0.2	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<3	7
		Temperature	Degrees Celsius		TM-2	Quarterly	500	
		Velocity	Metres per second		TM-2	Quarterly	31	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	1.0	

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
3	Compressor Engine 3	Carbon dioxide	Percent		TM-24	Quarterly	11.7	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.3	
		Moisture	Percent		TM-22	Quarterly	18	
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	30	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	190	461
		Oxygen (O2)	Percent		TM-25	Quarterly	0.56	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	<0.2	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<3	7
		Temperature	Degrees Celsius		TM-2	Quarterly	504	
		Velocity	Metres per second		TM-2	Quarterly	31	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	1.1	

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
4	Reboiler Flue	Carbon dioxide	Percent		TM-24	Quarterly	4.3	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.3	
		Moisture	Percent		TM-22	Quarterly	8.1	
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	110	110
		Oxygen (O2)	Percent		TM-25	Quarterly	13.4	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	<0.3	3.5
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<3	35
		Temperature	Degrees Celsius		TM-2	Quarterly	281	
		Velocity	Metres per second		TM-2	Quarterly	3.2	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.076	





Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
5	Reflux Column Vent	Carbon dioxide	Percent		TM-24	Quarterly	9.8	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.3	
		Moisture	Percent		TM-22	Quarterly	77	
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	30	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	<3	13
		Oxygen (O2)	Percent		TM-25	Quarterly	<0.4	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	<1	35
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<3	1042
		Temperature	Degrees Celsius		TM-2	Quarterly	92	
		Velocity	Metres per second		TM-2	Quarterly	<2	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	<0.003	



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
6	Carbon Scrubber Vent	Carbon dioxide	Percent		TM-24	Quarterly	<0.3	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.3	
		Moisture	Percent		TM-22	Quarterly	2.2	
		Molecular weight of stack gases	Grams per gram mole		TM-23	Quarterly	29	
		Odour	Odour Units		OM-7	Quarterly	60	
		Oxygen (O2)	Percent		TM-25	Quarterly	20.9	
		Temperature	Degrees Celsius		TM-2	Quarterly	29	
		Velocity	Metres per second		TM-2	Quarterly	5.6	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.15	