

AGL UPSTREAM INVESTMENTS PTY LTD ROSALIND PARK GAS PLANT Quarterly Air Monitoring Report

Reporting Period: 2nd Quarter - June 2012

AGL Upstream Investments Pty Ltd
ABN 58 115 063 744
Locked Bag 1837, St Leonards NSW 2065
Level 22, 101 Miller Street, North Sydney NSW 2060
Telephone: 02 9921 2999 Facsimile: 02 9921 2474
Complaints Line (24 hours) 02 9963 1318



Foreword

PREMISES Rosalind Park Gas Plant

Lot 35 Medhurst Road GILEAD NSW 2560

LICENCE DETAILS Environment Protection Licence 12003

LICENCEE AGL Upstream Investments Pty Limited

LICENCEE'S ADDRESS Locked Bag 1837, North Sydney, NSW 2060

MONITORING DATE 2nd Quarter - 14 June 2012

MONITORING BY EML Air Pty Ltd (Report N89381, 06 August 2012)

REPORT DATE 14 September 2012

REPORT PREPARED BY Aaron Clifton

Environmental Manager

SUMMARY OF ACTIVITY

Rosalind Park Gas Plant, located approximately 60km south west of Sydney, is a natural gas processing and treatment plant, used to process coal seam natural gas from the Camden Gas Project.

Produced natural gas is cleaned, dehydrated, compressed and odourised before being measured and transported by pipeline about 500 metres into the nearby Moomba to Sydney Natural Gas Pipeline. The premises covered by this Environment Protection Licence also includes all gas wells, gas gathering, reticulation systems, trunk lines and associated effluent storage areas and work areas of the Camden Gas Project.

This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of the Environment Protection Licence. The Licence conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.



This report sets out the results of quarterly monitoring. A separate report is issued for continuous monitoring.

This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, March 2012) (**Publication Requirements**).

AIR MONITORING LOCATIONS

Point	Location	Monitoring Frequency
1	Exhaust Stack 1 on Compression Engine 1	Quarterly
2	Exhaust Stack 2 on Compression Engine 2	Quarterly
3	Exhaust Stack 3 on Compression Engine 3	Quarterly
4	Reboiler Flue	Quarterly
5	Reflux Column Vent	Quarterly
6	Carbon Scrubber Vent	Quarterly

AIR MONITORING TEST METHODS - POINTS 1, 2, 3, 4, 5

Parameter	NSW EPA Test Method (Sampling Method)
Carbon dioxide	TM-24
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Nitrogen Oxides	TM-11
Oxygen (O2)	TM-25
Sulfuric acid mist and sulphur trioxide (as SO3)	TM-3
Sulphur dioxide	TM-4
Temperature	TM-2
Velocity	TM-2
Volumetric flowrate	TM-2



AIR MONITORING TEST METHODS - POINT 6

Parameter	NSW EPA Test Method (Sampling Method)
Carbon dioxide	TM-24
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Odour	OM-7
Oxygen (O2)	TM-25
Temperature	TM-2
Velocity	TM-2
Volumetric flowrate	TM-2



Air Monitoring Results

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
1	Compressor Engine 1	Carbon dioxide	Percent		TM-24	Quarterly	5.3	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.32	
		Moisture	Percent		TM-22	Quarterly	12	
		Molecular weight of stack gases	Grams per ram mole		TM-23	Quarterly	29.5	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	350	461
		Oxygen (O2)	Percent		TM-25	Quarterly	13.1	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	0.034	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<0.055	7
		Temperature	Degrees Celsius		TM-2	Quarterly	344	
		Velocity	Metres per second		TM-2	Quarterly	25	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	2.8	



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
2	Compressor Engine 2	Carbon dioxide	Percent		TM-24	Quarterly	11.2	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.34	
		Moisture	Percent		TM-22	Quarterly	15	
		Molecular weight of stack gases	Grams per ram mole		TM-23	Quarterly	30.0	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	290	461
		Oxygen (O2)	Percent		TM-25	Quarterly	2.2	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	<0.014	5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<0.071	7
		Temperature	Degrees Celsius		TM-2	Quarterly	447	
		Velocity	Metres per second		TM-2	Quarterly	23	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.84	



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
3	Compressor Engine 3	Carbon dioxide	Percent		TM-24	Quarterly	Compressor Engine 3 is	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	currently not operating as it is a standby unit.	
		Moisture	Percent		TM-22	Quarterly	See Note 1.	
		Molecular weight of stack gases	Grams per ram mole		TM-23	Quarterly		
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly		461
		Oxygen (O2)	Percent		TM-25	Quarterly		
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly		5.0
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly		7
		Temperature	Degrees Celsius		TM-2	Quarterly		
		Velocity	Metres per second		TM-2	Quarterly		
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly		



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
4	Reboiler Flue	Carbon dioxide	Percent		TM-24	Quarterly	5.1	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.32	
		Moisture	Percent		TM-22	Quarterly	6.3	
		Molecular weight of stack gases	Grams per ram mole		TM-23	Quarterly	29.5	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	100	110
		Oxygen (O2)	Percent		TM-25	Quarterly	13.8	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	0.064	3.5
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<0.14	35
		Temperature	Degrees Celsius		TM-2	Quarterly	267	
		Velocity	Metres per second		TM-2	Quarterly	3.1	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.078	



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
5	Reflux Column Vent	Carbon dioxide	Percent		TM-24	Quarterly	11.8	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.34	
		Moisture	Percent		TM-22	Quarterly	61	
		Molecular weight of stack gases	Grams per ram mole		TM-23	Quarterly	30.0	
		Nitrogen Oxides	Milligrams per cubic metre	7% oxygen	TM-11	Quarterly	<2.8	13
		Oxygen (O2)	Percent		TM-25	Quarterly	0.3	
		Sulfuric acid mist and sulphur trioxide (as SO3)	Milligrams per cubic metre		TM-3	Quarterly	2	35
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Quarterly	<0.26	1042
		Temperature	Degrees Celsius		TM-2	Quarterly	87	
		Velocity	Metres per second		TM-2	Quarterly	1.9	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.0042	



Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Concentration	Concentration limit
6	Carbon Scrubber Vent	Carbon dioxide	Percent	COTTCCTOTT	TM-24	Quarterly	<0.1	
		Dry gas density	Kilograms per cubic metre		TM-23	Quarterly	1.29	
		Moisture	Percent		TM-22	Quarterly	1.1	
		Molecular weight of stack gases	Grams per ram mole		TM-23	Quarterly	29.0	
		Odour	Odour Units		OM-7	Quarterly	180	
		Oxygen (O2)	Percent		TM-25	Quarterly	20.9	
		Temperature	Degrees Celsius		TM-2	Quarterly	24	
		Velocity	Metres per second		TM-2	Quarterly	6.7	
		Volumetric flowrate	Cubic metres per second		TM-2	Quarterly	0.17	



Note:

1. As Compressor Engine 3 is not operating, there are no pollutants or parameters that could be monitored.