

# AGL UPSTREAM INVESTMENTS PTY LTD

## Newcastle Gas Storage Facility

### Air Monitoring Report

**Reporting Period: March 2020**

AGL Upstream Investments Pty Ltd

ABN 58 115 063 744

Locked Bag 3013, Australia Square, NSW 1215

200 George Street, Sydney NSW 2000

Telephone: 02 9921 2999 Facsimile: 02 9921 2472

Complaints Line (24 hours): 1800 039 600



# Foreword

## **PREMISES**

Newcastle Gas Storage Facility  
5 Old Punt Road  
TOMAGO NSW 2323

## **LICENCE DETAILS**

[Environment Protection Licence 20130](#)

## **LICENCEE**

AGL Upstream Investments Pty Limited (AGL)

## **LICENCEE'S ADDRESS**

Locked Bag 3013, Australia Square, NSW 1215

## **MONITORING DATE**

04 & 05 March 2020

## **MONITORING BY**

Ektimo

## **ANALYSIS BY**

Ektimo (Report Number **R008805**)

## **OBTAINED DATA DATE**

03 April 2020

## **REPORT DATE**

06 April 2020

## **REPORT PREPARED BY**

David Mudd  
Environment Business Partner

## Summary of Activity

The Newcastle Gas Storage Facility (NGSF) is located in Tomago, New South Wales.

The NGSF includes:

A processing plant that converts pipeline natural gas to liquefied natural gas (LNG) by cooling it to -162°C. It is capable of processing up to 66,500 tonnes of LNG per year.

- An insulated, non-pressurised LNG storage tank capable of containing 30,000 tonnes or 63,000 m<sup>3</sup> of LNG, equivalent to 1.5 petajoules (PJ) of natural gas, and an associated containment area.
- A re-gasification unit to convert the LNG in the storage tank back into natural gas.
- A flare stack with a height of approximately 15m to combust hydrocarbons discharged from the process.
- A truck loading facility to allow the dispatch of up to 1,000 tankers of LNG per year.
- Infrastructure and utility connection and an emergency access road.

This Monitoring Report relates to those air monitoring activities specified in Part 5, Monitoring and Recording Conditions, of the Environment Protection Licence. The Licence conditions stipulate air monitoring is required to be carried out at the locations, at the frequency and using the test methods as set out in the tables below.

This report is prepared in accordance with the *Requirements for Publishing Pollution Monitoring Data* (EPA, October 2013) (**Publication Requirements**).

## AIR MONITORING LOCATIONS

EPA Monitoring Point	Location	Monitoring Frequency
7	Stack associated with the Gas Liquefaction System (H101)	Twice per year
8	Stack associated with the LNG Vaporiser (H501A)	Twice per year*
10	Stack associated with the LNG Vaporiser (H501B)	Twice per year*
11	Stack associated with the LNG Vaporiser (H501C)	Twice per year*

Note: Monitoring is only undertaken when the equipment is operating

\*Not operating at the time of monitoring.

## AIR MONITORING TEST METHODS

Parameter	NSW EPA Test Method (Sampling Method)
Carbon dioxide	TM-24
Carbon monoxide	TM-32
Dry gas density	TM-23
Moisture	TM-22
Molecular weight of stack gases	TM-23
Nitrogen Oxides	TM-11
Oxygen (O <sub>2</sub> )	TM-25
Solid Particles	TM-15
Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	TM-3
Sulphur dioxide	TM-4
Temperature	TM-2
Velocity	TM-2
Volatile organic compounds	OM-2
Volumetric flowrate	TM-2

## AIR MONITORING RESULTS

Monitoring Date: 04 March 2020

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
7	Stack associated with Gas Liquefaction System (H101)	Carbon dioxide	Percent		TM-24	Twice per year	< 6	Not applicable
		Carbon monoxide	Milligrams per cubic metre	3%	TM-32	Twice per year	16	100
		Dry gas density	Kilograms per cubic metre		TM-23	Twice per year	1.33	Not applicable
		Moisture	Percent		TM-22	Twice per year	17	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Twice per year	29.8	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre		TM-11	Twice per year	58	250
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Twice per year	2.4	Not applicable
		Solid Particles	Milligrams per cubic metre		TM-15	Twice per year	< 3	5
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Twice per year	1.8	60
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Twice per year	< 6	Not applicable
		Temperature	Kelvin		TM-2	Twice per year	508	Not applicable
		Velocity	Metres per second		TM-2	Twice per year	5.8	Not applicable
		Volatile organic compounds	Milligrams per cubic metre	3%	OM-2	Twice per year	< 0.1	5
Volumetric flowrate	Cubic metres per second		TM-2	Twice per year	0.76	Not applicable		

Monitoring Date: 05 March 2020

Monitoring Point	Description	Pollutant	Units of measure	Oxygen correction	Sampling method	Monitoring frequency required by licence	Average Concentration	Concentration limit
7	Stack associated with Gas Liquefaction System (H101)	Carbon dioxide	Percent		TM-24	Twice per year	10.1	Not applicable
		Carbon monoxide	Milligrams per cubic metre	3%	TM-32	Twice per year	58	100
		Dry gas density	Kilograms per cubic metre		TM-23	Twice per year	1.33	Not applicable
		Moisture	Percent		TM-22	Twice per year	17	Not applicable
		Molecular weight of stack gases	Grams per gram mole		TM-23	Twice per year	29.8	Not applicable
		Nitrogen Oxides (as NO <sub>2</sub> equivalent)	Milligrams per cubic metre		TM-11	Twice per year	54	250
		Oxygen (O <sub>2</sub> )	Percent		TM-25	Twice per year	1.8	Not applicable
		Solid Particles	Milligrams per cubic metre		TM-15	Twice per year	< 3	5
		Sulfuric acid mist and sulphur trioxide (as SO <sub>3</sub> )	Milligrams per cubic metre		TM-3	Twice per year	0.43	60
		Sulphur dioxide	Milligrams per cubic metre		TM-4	Twice per year	10.1	Not applicable
		Temperature	Kelvin		TM-2	Twice per year	506	Not applicable
		Velocity	Metres per second		TM-2	Twice per year	5.9	Not applicable
		Volatile organic compounds	Milligrams per cubic metre	3%	OM-2	Twice per year	< 0.1	5
		Volumetric flowrate	Cubic metres per second		TM-2	Twice per year	0.78	Not applicable